

INCIDENT REPORT

INCIDENT

Fire Department: Garden Grove Fire Department
Incident Number: G1508684
Exposure Number: 00
Multi-Agency IC#: A1523131
Incident Date: 08/01/15
Dispatch Time: 11:27:39
Arrival Time: 11:33:03
Controlled Time:
Ending Time: 11:44:18
First-In Company: GE21
District: G2422
Incident Type: Heat from short circuit (wiring), defective/worn
Mutual Aid: None
Method of Alarm: E911
Type of Weather:
Air Temperature: 73
Address, CSZ: COLONY OF PERFORMING ARTS, 129
Census Tract:
Fire Haz Sev Zone: Medium

RESOURCES & CASUALTIES

Actions Taken 1: Investigate
Actions Taken 2: Refer to proper authority
Actions Taken 3:
#Apparatus Resp Engine: 1
#Apparatus Resp Trk: 1
#Apparatus Resp Med: 0
#Apparatus Resp Oth: 4
Fire Svs Injury: 0
Fire Svs Fatal: 0
Non-FS Injury:
Non-FS Fatal:

PROPERTY & STUDIES

Property Losses:
Content Losses:
Property Value:
Contents Value:
Insurance Co:
Building Ins:
Mixed Prop Use:
Property Use: Personal service, including barber & bea
Detector

INCIDENT REPORT

Hazmat Rel: None
Critical Inc:
Special Studies:

COMMENTS

***** GE21 *****

ELECTRICAL ISSUE

RESPONDED ON A REPORTED STRUCTURE FIRE. UPON ARRIVAL FOUND AN ELECTRICAL VULT THAT WAS SMOKING. POWER WAS SHUT OFF TO THE BUILDING AND BUSINESS OWNER WAS INFORMED TO NOT TURN POWER BACK ON UNTIL EDISON WAS ABEL TO EVALUATE THE PROBLEM.

CAPTAIN JEFFREY LEE WILKINS