



**CITY OF GARDEN GROVE**  
**FIRE DEPARTMENT**

---

September 3, 2015

Chandel Davis  
Terracon  
2817 McGaw Ave.  
Irvine, Ca 92614

Records Search for 11162 Garden Grove Blvd., Garden Grove, CA 92843

Dear Ms. Davis:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

A handwritten signature in black ink, appearing to read 'Nate Brady', written over a white background.

Nate Brady  
Division Chief/Fire Marshal

# GARDEN GROVE



## FIRE DEPARTMENT

### HAZARDOUS MATERIALS DISCLOSURE PROGRAM

#### REPORTING FORMS PACKET: PART 1

**FOR OFFICIAL USE ONLY**

APPROVED BY: SHIRLEY DATE: 7-24-00

NEW BUSINESS  EXISTING  UPDATE

FEE: 1 2 3 4 5 6

OWNERSHIP CHANGE \_\_\_\_\_

ADDRESS CHANGE: \_\_\_\_\_

TIER II  FAC:  CON.  BUS LIST:  PICK:



**Hamid R. Amir**  
Firouzkouhi  
Dealer  
Phone 714 530 3585  
Fax 714 530 5526

**Garden Grove Chevron**  
11162 Garden Grove Blvd.  
Garden Grove, CA 92843

Auto Service • Food Mart • 24 Hours



# CITY OF GARDEN GROVE, FIRE DEPARTMENT

11301 ACACIA PARKWAY, GARDEN GROVE, CALIFORNIA 92842

(714) 741-5600

(714) 741-5636

## HAZARDOUS MATERIALS BUSINESS INFORMATION FORM

**FORM 1**

### BUSINESS INFORMATION

CALENDAR YEAR BEGINNING (1)		ENDING (2)		(3) PAGE 1 OF	
BUSINESS NAME (4)	GARDEN GROVE CHEVRON		BUSINESS PHONE: (5)	714 530 3585	
SITE ADDRESS (6)	1162 GARDEN GROVE BL.				
CITY (7)	GARDEN GROVE	STATE (8)	CA	ZIP (9)	92843
DUN & BRADSTREET (OPTIONAL) OPERATOR NAME (12)	N/A		SIC CODE (4 DIGIT #) (11)	5541	
			OPERATOR PHONE (13)		

### OWNER INFORMATION

OWNER NAME (14)	HAMID AMIR FIROUZKOUHI		OWNER PHONE (15)	714 530 3585	
OWNER MAILING ADDRESS (16)	1162 GARDEN GROVE BLVD.				
CITY (17)	GARDEN GROVE	STATE (18)	CA	ZIP (19)	92843

### ENVIRONMENTAL CONTACT

CONTACT NAME (20)	FRED AZARNIA		CONTACT PHONE (21)	714 530 3585	
MAILING ADDRESS (22)	1162 GARDEN GROVE BLVD.				
CITY (23)	GARDEN GROVE	STATE (24)	CA	ZIP (25)	92843

Primary

### EMERGENCY CONTACTS

Secondary

NAME: (26)	FRED AZARNIA		NAME: (31)	HAMID AMIR FIROUZKOUHI	
TITLE: (27)	MANAGER		TITLE: (32)	OWNER	
BUSINESS PHONE: (28)	714 530 3585		BUSINESS PHONE: (33)	714 530 3585	
24-HOUR PHONE: (29)	714 530 3585		24-HOUR PHONE: (34)	714 530 3585	
PAGER #: (30)			PAGER #: (35)		

### ACUTELY HAZARDOUS MATERIALS (AHM) / EXTREMELY HAZARDOUS SUBSTANCE (EHS)

ON SITE AHM/EHS (36)  Yes  No

If yes, and above Threshold Planning Quantities, attach a sheet of paper with a general description of the process and principal equipment.

### ADDITIONAL LOCALLY COLLECTED INFORMATION

(37)

A. Type of Business Operation	SERVICE STATION	G. Underground Storage Tanks	<input checked="" type="checkbox"/> Y <input type="checkbox"/> N
B. Hours of Business Operation	24 HOURS	H. Above ground Tank over 660 gal.	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N
C. Total Number of Employees	4		
D. Property Owner Name	CHEVRON	Address	
E. Schools, hospitals within 1,000 ft. of business property	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>		
F. EPA I.D. Number			

Certification: I certify under penalty of law that I have personally examined and that I am familiar with the information submitted in this inventory and believe the information is true, accurate, and complete.

Print Name of Document Preparer (38)	FRED AZARNIA		
Signature of Owner/Operator (39)	<i>Hamid Firouz Kouhi</i>	Date (40)	6/23/00

**CALIFORNIA CHEMICAL INVENTORY FORM - DESCRIPTION PAGE**

(1)  ADD  DELETE  REVISE  NO CHANGE

PAGE (2)  OF 3)

BUSINESS NAME (4) GARDEN GROVE CHEVRON  
 CHEMICAL LOCATION (5) (Address, Area, Building, etc.) SOUTH SIDE OUTSIDE BUILDING  
 MAP # (if more than one) (6)  GRID # (7) N L-4

CHEMICAL NAME (8) WASTE OIL TRADE SECRET (11)  Y  N  
 COMMON NAME (9) USED OIL WASTE AHM/\*EHS (12)  Y  N  
 CAS # (10) MIXTURE \*IF EHS BOX IS "Y" ALL AMOUNTS MUST BE IN LBS  
 FIRE CODE HAZARD CLASSES\* (13) CIB9

**\*COMPLETE BLOCK (13) IF REQUESTED BY THE LOCAL FIRE CHIEF - REFER TO INSTRUCTIONS.**

TYPE (14)  PURE  MIXTURE  WASTE CHECK IF RADIOACTIVE (15)  (16) NR  
 PHYSICAL STATE (17)  SOLID  LIQUID  GAS CURIES  
 FED HAZARD CATEGORIES (18)  FIRE  REACTIVE  PRESSURE RELEASE  ACUTE HEALTH  CHRONIC HEALTH  
 STATE WASTE CODE (19) 221 UNITS (22)  GAL  CU FT  LBS  TONS MAX DAILY AMT (23) 250  
 DAYS ON SITE (20) 365 \*If EHS, amounts must be in lbs. AVG DAILY AMT (24) 120  
 LARGEST CONTAINER (21) 250 ANNUAL WASTE AMT (25) 100  
 STORAGE CONTAINER (26)  ABOVE GROUND TANK - ~~INSIDE~~  CAN  BOX(S)  TANK WAGON  
 UNDER GROUND TANK OUTSIDE  CARBOY  CYLINDER  RAIL CAR  
 TANK INSIDE BUILDING  SILO  GLASS CONTAINER  
 STEEL DRUM  FIBER DRUM  PLASTIC CONTAINER  Other  
 PLASTIC/NONMETALLIC DRUM  BAG(S)  IN MACHINERY OR EQUIP.  
 PRESSURE STORAGE (27)  AMBIENT  ABOVE AMBIENT  BELOW AMBIENT  
 STORAGE TEMPERATURE (28)  AMBIENT  ABOVE AMBIENT  BELOW AMBIENT  CRYOGENIC

(29) % WT	(30) HAZARDOUS COMPONENTS	(31) EHS/AHM	(32) CAS #
1. 85-90	PETROLEUM Lubo oil	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N	64742-65-0
2.		<input type="checkbox"/> Y <input type="checkbox"/> N	
3.		<input type="checkbox"/> Y <input type="checkbox"/> N	

**(33) ADDITIONAL LOCALLY COLLECTED INFORMATION**  
 \*COMPLETE BLOCK (33) IF REQUESTED BY THE LOCAL FIRE CHIEF - REFER TO INSTRUCTIONS.

NFPA CLASSIFICATION \_\_\_\_\_  
 UN/DOT # \_\_\_\_\_ Refer to shipping papers or MSDS  
 DOT HAZARD CLASS \_\_\_\_\_ Refer to shipping papers or MSDS  
 UFC HAZARD CLASS \_\_\_\_\_

**NFPA 704 HAZARD DIAMOND**

HEALTH BLUE → [DIAMOND] ← REACTIVE YELLOW  
 SPECIAL HAZARD ↗ [DIAMOND] ↖ WHITE OX/W

CALIFORNIA CHEMICAL INVENTORY FORM - DESCRIPTION PAGE

(1)  ADD  DELETE  REVISE  NO CHANGE

PAGE (2)  OF 3)

BUSINESS NAME (4) GARDEN GROVE CHEVRON  
 CHEMICAL LOCATION (Address, Area, Building, etc.) (5) SOUTH WESTWALL INSIDE BUILDING # S.E & S INSIDE BUILDING 6  
 MAP # (if more than one) (6)    GRID # (7) MSDS/FERE & W ~~#7~~ L-5

CHEMICAL NAME (8) ANTI FREEZE ETHYLENE GLYCOL TRADE SECRET (11)  Y  N  
 COMMON NAME (9) COOLANT & WASTE AHM / \*EHS (12)  Y  N  
 CAS # (10) MIXTURE \*IF EHS BOX IS "Y" ALL AMOUNTS MUST BE IN LBS  
 FIRE CODE HAZARD CLASSES\* (13) IRRITANT, CUB

\*COMPLETE BLOCK (13) IF REQUESTED BY THE LOCAL FIRE CHIEF - REFER TO INSTRUCTIONS.

TYPE (14)  PURE  MIXTURE  WASTE CHECK IF RADIOACTIVE (15)  N/A (16) N/A  
 PHYSICAL STATE (17)  SOLID  LIQUID  GAS CURIES  
 FED HAZARD CATEGORIES (18)  FIRE  REACTIVE  PRESSURE RELEASE  ACUTE HEALTH  CHRONIC HEALTH  
 STATE WASTE CODE (19) UNITS (22)  GAL  CU FT  LBS  TONS MAX DAILY AMT (23) 3 GAL  
 DAYS ON SITE (20) 365 \*If EHS, amounts must be in lbs. AVG DAILY AMT (24) 20 GAL  
 LARGEST CONTAINER (21) 355 ANNUAL WASTE AMT (25) 120 GAL  
 STORAGE CONTAINER (26)  ABOVE GROUND TANK - INSIDE  CAN  BOX(S)  TANK WAGON  
 UNDER GROUND TANK  CARBOY  CYLINDER  RAIL CAR  
 TANK INSIDE BUILDING  SILO  GLASS CONTAINER  
 STEEL DRUM  FIBER DRUM  PLASTIC CONTAINER  Other  
 PLASTIC/NONMETALLIC DRUM  BAG(S)  IN MACHINERY OR EQUIP.  
 PRESSURE STORAGE (27)  AMBIENT  ABOVE AMBIENT  BELOW AMBIENT  
 STORAGE TEMPERATURE (28)  AMBIENT  ABOVE AMBIENT  BELOW AMBIENT  CRYOGENIC

(29) % WT	(30) HAZARDOUS COMPONENTS	(31) EHS/AHM	(32) CAS #
1. <u>94</u>	<u>ETHYLENE GLYCOL</u>	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N	<u>107-21-1</u>
2. <u>2</u>	<u>PHOSPHATES</u>	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N	<u>7758-11-4</u>
3. <u>4</u>	<u>PROPRIETARY</u>	<input type="checkbox"/> Y <input checked="" type="checkbox"/> N	<u>N/A</u>

(33) ADDITIONAL LOCALLY COLLECTED INFORMATION  
 \*COMPLETE BLOCK (33) IF REQUESTED BY THE LOCAL FIRE CHIEF - REFER TO INSTRUCTIONS.

NFPA CLASSIFICATION

UN/DOT # \_\_\_\_\_ Refer to shipping papers or MSDS

DOT HAZARD CLASS \_\_\_\_\_ Refer to shipping papers or MSDS

UFC HAZARD CLASS \_\_\_\_\_

NFPA 704 HAZARD DIAMOND

The diagram is a diamond shape divided into four quadrants. The top quadrant is labeled 'FIRE RED'. The left quadrant is labeled 'HEALTH BLUE'. The right quadrant is labeled 'REACTIVE YELLOW'. The bottom quadrant is labeled 'SPECIAL HAZARD' with 'WHITE OX/W' written below it. Arrows point from each label to its respective quadrant.

MAKE AS MANY COPIES OF CHEMICAL INVENTORY FORM AS NEEDED

**CALIFORNIA CHEMICAL INVENTORY FORM - DESCRIPTION PAGE**

(1)  ADD  DELETE  REVISE  NO CHANGE

PAGE (2)   OF 3)  

BUSINESS NAME (4) GARDEN GROVE CHEVRON

CHEMICAL LOCATION (5)  

MAP # (if more than one) (6)   GRID # (7) K-J-I 2

CHEMICAL NAME (8) ALL GRADES GASOLINE TRADE SECRET (11)  Y  N

COMMON NAME (9) GASOLINE AHM / \*EHS (12)  Y  N

CAS # (10) 1634044 (mixture) \*IF EHS BOX IS "Y"  
ALL AMOUNTS MUST BE IN LBS

FIRE CODE HAZARD CLASSES\* (13) FIA

**\*COMPLETE BLOCK (13) IF REQUESTED BY THE LOCAL FIRE CHIEF - REFER TO INSTRUCTIONS.**

TYPE (14)  PURE  MIXTURE  WASTE CHECK IF RADIOACTIVE (15)  (16)  

PHYSICAL STATE (17)  SOLID  LIQUID  GAS CURIES  

FED HAZARD CATEGORIES (18)  FIRE  REACTIVE  PRESSURE RELEASE  ACUTE HEALTH  CHRONIC HEALTH

STATE WASTE CODE (19) N/A UNITS (22)  GAL  CU FT  LBS  TONS MAX DAILY AMT (23) 30,000

DAYS ON SITE (20) 365 \*If EHS, amounts must be in lbs. AVG DAILY AMT (24) 15,000

LARGEST CONTAINER (21) 10,000 ANNUAL WASTE AMT (25) 0

STORAGE CONTAINER (26)  ABOVE GROUND TANK - INSIDE  CAN  BOX(S)  TANK WAGON  
 UNDER GROUND TANK  CARBOY  CYLINDER  RAIL CAR  
 TANK INSIDE BUILDING  SILO  GLASS CONTAINER  
 STEEL DRUM  FIBER DRUM  PLASTIC CONTAINER  Other  
 PLASTIC/NONMETALLIC DRUM  BAG(S)  IN MACHINERY OR EQUIP.

PRESSURE STORAGE (27)  AMBIENT  ABOVE AMBIENT  BELOW AMBIENT

STORAGE TEMPERATURE (28)  AMBIENT  ABOVE AMBIENT  BELOW AMBIENT  CRYOGENIC

(29) % WT	(30) HAZARDOUS COMPONENTS	(31) EHS/AHM	(32) CAS #
1.		<input type="checkbox"/> Y <input type="checkbox"/> N	
2.		<input type="checkbox"/> Y <input type="checkbox"/> N	
3.		<input type="checkbox"/> Y <input type="checkbox"/> N	

**(33) ADDITIONAL LOCALLY COLLECTED INFORMATION**  
**\*COMPLETE BLOCK (33) IF REQUESTED BY THE LOCAL FIRE CHIEF - REFER TO INSTRUCTIONS.**

NFPA CLASSIFICATION \_\_\_\_\_

UN/DOT # \_\_\_\_\_ Refer to shipping papers or MSDS


DOT HAZARD CLASS \_\_\_\_\_ Refer to shipping papers or MSDS

UFC HAZARD CLASS \_\_\_\_\_

**NFPA 704 HAZARD DIAMOND**

HEALTH BLUE →   ← REACTIVE YELLOW

SPECIAL HAZARD ↗   ↖ WHITE OX/W.



CITY OF GARDEN GROVE, CALIFORNIA  
 MAILING ADDRESS: P.O. BOX 3070, GARDEN GROVE, CALIFORNIA 92842  
 714-741-5600

BUSINESS EMERGENCY PLAN

Business Name Garden Grove Chevron  
 Business Address 11162 Garden Grove Blvd City GG State CA Zip 92843  
 Mailing Address P.O. Box 7066 City NB State CA Zip 92658  
 Business Phone (714) 530-3585 Business License # 152151  
 Fax Number (714) 530-5526

Owner/Operator: Name Hamid R. Amir Frouzkouhi Phone Number (714) 703-3857  
 Address P.O. Box 7066 City NB State CA Zip 92658

Type of Business Operation Service Station (Gasoline Sales / Snack Shop / Garage)  
 EPA # CAL 000016632 SIC Code 5541

Emergency Contacts: Name Hamid R. Amir Frouzkouhi / Farzadoun Azarnia  
 Address \_\_\_\_\_ City \_\_\_\_\_ Zip 92691  
 24 Hour Phone Number \_\_\_\_\_ Phone Number \_\_\_\_\_

Property Owner: Name Chevron Phone Number (562) 694-7237  
 Address \_\_\_\_\_ City La Habra State CA Zip \_\_\_\_\_

Total Number of Employees 7-9 Dun and Brad Street Numbers \_\_\_\_\_

REC'D/APPRV'D: SHIRLEY DATE: 4-1-98

Office Use Only

FEE: 1 2 3 4 NEW BUS: \_\_\_\_\_ EXISTG: \_\_\_\_\_ UPDATE: X

MISC: \_\_\_\_\_

MLI# \_\_\_\_\_ Short \_\_\_\_\_ Long \_\_\_\_\_

TIER II: \_\_\_\_\_ FAC: \_\_\_\_\_ CON: \_\_\_\_\_ BUS LIST: OK / PICK - 4/8/98

BUSINESS NAME: Garden Grove Chevron  
 ADDRESS: 1162 Garden Grove Blvd / GG / CA / 92843  
 MLI # \_\_\_\_\_ (office use only)

**HAZARDOUS MATERIALS**  
 THIS FORM I

1. TRADE NAME	2. HAZARDOUS SUBSTANCES IN PRODUCT (top 3 as per % weight on MSDS)	3. CAS NO.	4. SARA Hazard Class Table 1	5. Physical State Table 2	6. MAX. DAILY AMOUNT Table 3
1. Chevron Premium Unleaded Gasoline	Gasoline (Generic) Tert-Amyl Methyl Ether Methyl tert BUTYL ETHER	994058 1634044	1-4	M-L	05
2. Chevron Mid-Grade Unleaded Gasoline	Gasoline (Generic) Tert-Amyl Methyl Ether Methyl tert BUTYL ETHER	994058 1634044	1-4	M-L	05
3. Chevron Regular Unleaded Gasoline	Gasoline (Generic) Tert-Amyl Methyl Ether Methyl tert BUTYL ETHER	994058 1634044	1-4	M-L	05
4. Chevron Motor oil SAE 10W30 20W50 5W30	Lubricating Base Oil	64741884	3-4	M-L	03
5. Chevron Supreme Synthetic Motor oil SAE 5W30	Synthetic Hydrocarbon Base Oil Synthetic Hydrocarbon Base Oil	68037014 27178161	3-4	M-L	03
6. Chevron Delo 400 SAE 15W40, 30	Lubricating Base Oil Phosphoric acid, 0-DI-CI-4-ALKYL ESTERS, zinc salt	64741884 68649423	3-4	M-L	03
7. Chevron Automatic Transmission Fluid Dexron III Mercon	Solvent Dewaxed Heavy PARAFFINIC Solvent-Refined Light Naphthenic Hydrotreated Light Paraffinic	64742650 64741875 64742558	3-4	M-L	03
8. Chevron Automatic Transmission Fluid TYPE F	Hydrotreated Heavy Naphthenic Hydrotreated Light Naphthenic Hydrotreated Heavy Paraffinic	64742525 64742536 64742547	3-4	M-L	03
9. Atlas Antifreeze Perma-Guard	Diethylene Glycol Ethylene Glycol Phosphates Acid	111-46-6 107-21-1 2758-11-4	1-5	M-L	00
10. Batteries			1-4	M-L	00
11. Freon 12			2-4	M-G	00
12. Safety Clean Solvent Tank	Anti-static agents Dye Mineral Spirits		1-4	M-L	00
13.					
14. Used oil filters			3-4	M-L	00
15. USED TIRES			1-4	M-G	00

Table#1 SARA Hazard		Table#2	TABLE # 3 Amount Chart	Table#4 Container Type	
Physical	Health	Physical State	Value	Amount	Range
1-Fire	4-Immediate (Acute)	P-Pure M-Mixture	00	0	99
2-Sudden Release of Pressure	5-Delayed (Chronic)	S-Solid (Report pounds) L-Liquid (Report gallons) G-Gas (Report cubic feet)	01	100	299
3-Reactivity			02	300	599
			03	600	999
			04	1000	5999
			05	6000	9999
			06	10000	19999
			07	20000	49999+

A- Aboveground Tank	I- Insulated Tank
B- Bag(s)	J- Metal Container
C- Box(s)	K- Movable Pressu
D- Carboy(s)	L- Plastic Containe
E- Drum(s) or Barrel(s)	M- Rail Car
F- Fixed Pressurized Cylinders	N- Silo
G- Glass Containers	O- Tank inside buil
H- In Machinery or Equip.	P- Underground Ta
	Q- Other




# HAZARD DISCLOSURE FORM

BE TYPEWRITTEN.

DATE: 03-23-98

PAGE # 1



8. DAYS ON SITE	9. CONTAINER TYPE <small>Table 4</small>	10. STORAGE CODE PRESSURE/ TEMP. <small>Table 5</small>	11. LOCATION <small>(NOTE BY QUADRANT AND DESCRIBE AREA)</small>	12. STATE WASTE NUMBER <small>(3 DIGIT CODE)</small>	13. DOT/ UN/NA NUMBER	14. HAZARD CLASS <small>Table 6</small>
365	P	1-1	(E3) to (E1)	1	1996	11
365	P	1-1	(F3) to (F1)	1	1996	11
365	P	1-1	(G3) to (G1)	1	1996	11
365	P	1-1	F7, E6	1	—	3
365	P	1-1	F7, E6	1	—	3
365	P	1-1	F7, E6	1	—	3
365	P	1-1	F7, E6	1	—	3
365	P	1-1	F7, E6	1	—	3
365	E	1-1	E7	1	—	3
365	Q	1-1	E7, D7, C7	1	—	8
365	K	1-1	D7	1	—	7
365	A	1-1	E6	1	—	11
365	E	1-1	E7	1	—	3
365	Q	1-1	E7	1	—	3

nics)  ylinders	<b>Table#5 Storage Code</b> Pressure / Temperature	<b>Table#6 Hazard Class (see MSDS sheets for info)</b>
	1- Ambient 2- Less than ambient 3- Greater than ambient  1- Ambient 2 - Less than ambient, but not cryogenic 3 - Greater than ambient 4 - Cryogenic  * Ambient = room pressure or temperature	1- Blasting Agent 2- Carcinogen 3- Combustible Liquids 4- Corrosive 5- Cryogenics 6- Etiologic Agents 7- Explosive A 8- Explosive B 9- Explosive C 10- Flammable Compressed Gas 11- Flammable Liquid 12- Flammable Solid 13- Hypergolic 14- Irritant 15- Non Flammable Compressed Gas 16- Organic Peroxide 17- Oxidizer 18- Pesticide 19- Poison A (Compressed Poisonous Gas) 20- Poison B (Solid/Liquid) 21- Pyrophoric or Spontaneously Combustible 22- Radioactive

A Hazardous Materials Disclosure Business is required by law to notify the Garden Grove Fire Department within 15 days of any of the following events:

1. Change of business address.
2. Change of business ownership.
3. Change of business name.
4. Cessation of business.
5. Use of a previously undisclosed hazardous material.
6. A 100% increase in the quantity of a previously disclosed material.

	YES	NO
1. Are there any underground storage containers located on the business property?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Is trade secret protection requested for any of the information included in this disclosure?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3. Are there school(s), hospital(s), extended day care or long term health facilities within 1000 feet (straight line distance) of business property?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are extremely Hazardous Materials or Acutely Hazardous Materials being handled on business property (State and Federal reporting)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

I certify, under penalty of law that I have personally examined and am familiar with the information submitted and believe the submitted information is true, accurate, and complete.


Print Name of Owner: Hamid, R., Amir Firouzkouhi

Print Name of Document Preparer: SAME AS ABOVE

Signature of Owner/Operator: Hamid R. Amir Firouzkouhi Date: 03-31-98

NOTE: Keep a copy of entire disclosure packet for your records.

RETURN THE ORIGINAL DISCLOSURE FORM, BUSINESS PLAN, AND MSDS SHEETS TO THE GARDEN GROVE FIRE DEPARTMENT



# CITY OF GARDEN GROVE, CALIFORNIA

MAILING ADDRESS: P.O. BOX 3070, GARDEN GROVE, CALIFORNIA 92642  
714-741-5600

GARDEN GROVE  
FIRE DEPARTMENT  
APR 13 11 20 AM '92

## BUSINESS EMERGENCY PLAN

MAR 01 1992

GARDEN GROVE CHEVRON  
11162 GARDEN GROVE BLVD.  
GARDEN GROVE, CA 92643  
PH. 714-530-3585

Business Name \_\_\_\_\_

Business Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

Mailing Address \_\_\_\_\_ City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

Business Phone (714) 530-3585 Business License # 133740

Fax Number ( ) \_\_\_\_\_

Owner/Operator: Name JAMES S. ROBERTS  
ROBERT E. MARTIN Phone Number \_\_\_\_\_

Address \_\_\_\_\_

Type of Business Operation RETAIL GASOLINE STATION / MINOR AUTO REPAIR

EPA # 000-016-632 SIC Code \_\_\_\_\_

Emergency Contacts: Name ROBERT E. MARTIN

Address \_\_\_\_\_

24 Hour Phone Number \_\_\_\_\_ Phone Number ( ) \_\_\_\_\_

Property Owner: Name CHEVRON USA Phone Number (310) 694-7000

Address 1300 S. BEACH BLDG. 4516 City LA HABRA State CA Zip \_\_\_\_\_

Total Number of Employees 6 Dun and Brad Street Numbers NOVE

### Office Use Only

MLI# 62880 Short \_\_\_\_\_ Long \_\_\_\_\_

OK  
5-2-18-92 J

4

**BUSINESS NAME:** GARDEN GROVE CHEVRON  
 11162 GARDEN GROVE BLVD.  
**ADDRESS:** GARDEN GROVE, CA 92643  
 PH. 714 536 3505  
**MLI #** \_\_\_\_\_ (office use only)

**HAZARDOUS MATERIALS**  
 THIS FORM IS

1. TRADE NAME	2. HAZARDOUS SUBSTANCES IN PRODUCT (top 3 as per % weight on MSDS)	3. CAS NO.	4. SARA Hazard Class Table 1	5. Physical State Table 2	6. MAX. DAILY AMOUNT Table 3	7. ICA
1. Regular UNLEADED GAS	1590 METHYL TERT BUTYL ETHER 6590 TOLUENE 4990 BENZENE		145	L	4	L
2. PLUS UNLEADED GAS	1590 METHYL TERT BUTYL ETHER 9590 TOLUENE 6390 XYLENE-M		145	L	4	L
3. Supreme UNLEADED GAS	6590 TOLUENE 4990 BENZENE 1590 METHYL TERT BUTYL ETHER		145	L	4	L
4. ANTI FREEZE COOLANT	ETHYLENE GLYCOL DIPOTASSIUM PHOSPHATE		4	L	01	C
5. BRAKE FLUID	GLYCOLS POLYGLYCOLS GLYCOL ETHERS POLYALKYLENE GLYCOL ETHERS		4	L	00	C
6.						
7.						
8.						
9.						
10.						
11.						
12.						
13.						
14.						
15.						

Table#1 SARA Hazard		Table#2	TABLE # 3 Amount Chart			Table#4 Container Type	
Physical	Health	Physical State	Value	Amount	Range	A- Aboveground Tank	I- Insulated Tank(Ci)
1-Fire	4-Immediate	P-Pure	00	0	99	B- Bag(s)	J- Metal Containers
2-Sudden Release of Pressure	(Acute)	M-Mixture	01	100	299	C- Box(s)	K- Movable Pressuriz
3-Reactivity	5-Delayed (Chronic)	S-Solid (Report pounds)	02	300	599	D- Carboy(s)	L- Plastic Containers
		L-Liquid (Report gallons)	03	600	999	E- Drum(s) or Barrel(s)	M- Rail Car
		G-Gas (Report cubic feet)	04	1000	5999	F- Fixed Pressurized Cylinders	N- Silo
			05	6000	9999	G- Glass Containers	O- Tank inside buildir
			06	10000	19999	H- In Machinery or Equip.	P- Underground Tank
			07	20000	49999		Q- Other

# LS DISCLOSURE FORM

BE TYPEWRITTEN.

DATE: 2-12-92

PAGE # 1 OF 1



GARDEN GROVE

8. DAYS ON SITE	9. CONTAINER TYPE <small>Table 4</small>	10. STORAGE CODE PRESSURE/ TEMP. <small>Table 5</small>	11. LOCATION <small>(NOTE BY QUADRANT AND DESCRIBE AREA)</small>	12. STATE WASTE NUMBER <small>(3 DIGIT CODE)</small>	13. DOT/ UN/NA NUMBER	14. HAZARD CLASS <small>Table 6</small>
365	P	1-1	X QUAD FRONT OF LUBE BAYS		UN1203	11
365	P	1-1	X QUAD " " " "		UN1203	11
365	P	1-1	X QUAD " " " "		UN1203	11
365	L	1-1	X QUAD STORAGE AREA			20
365	J	1-1	X QUAD STORAGE AREA			20

(s)  nders	<b>Table#5 Storage Code</b>		<b>Table#6 Hazard Class (see MSDS sheets for info)</b>			
	Pressure  1- Ambient 2 - Less than ambient 3 - Greater than ambient  * Ambient = room pressure or temperature	Temperature  1-Ambient 2-Less than ambient,but not cryogenic. 3-Greater than ambient 4-Cryogenic	1- Blasting Agent 2- Carcinogen 3- Combustible 4- Corrosive 5- Cryogenics 6- Etiologic Agents 7- Explosive A 8- Explosive B	9- Explosive C 10- Flammable Compressed Gas 11- Flammable Liquid 12- Flammable Solid 13- Hypergolic 14- Irritant 15- Non Flammable Compressed Gas 16- Organic Peroxide	17- Oxidizer 18- Pesticide 19- Poison A (Compressed Poisonous Gas) 20- Poison B (Solid/Liquid) 21- Pyrophic or Spontaneously Combustible 22- Radioactive	

A Hazardous Materials Disclosure Business is required by law to notify the Garden Grove Fire Department within 15 days of any of the following events:

1. Change of business address.
2. Change of business ownership.
3. Change of business name.
4. Cessation of business.
5. Use of a previously undisclosed hazardous material.
6. A 100% increase in the quantity of a previously disclosed material.

---

	YES	NO
1. Is trade secret protection requested for any of the information included in this disclosure?	_____	<u>  X  </u>
2. Are there any underground storage containers located on the business property?	<u>  X  </u>	_____
3. Are there school(s), hospital(s), extended day care or long term health facilities within 1000 feet (straight line distance) of business property?	_____	<u>  X  </u>
4. Are extremely Hazardous Materials or Acutely Hazardous Materials being handled on business property (State and Federal reporting)?	_____	<u>  X  </u>

---

I certify, under penalty of law that I have personally examined and am familiar with the information submitted and believe the submitted information is true, accurate, and complete.

Print Name of Owner: Robert E. Martin

Print Name of Document Preparer: Robert E. Martin

Signature of Owner/Operator: Robert E. Martin Date: 2-12-92

---

NOTE: Keep a copy of entire disclosure packet for your records.

RETURN THE ORIGINAL DISCLOSURE FORM, BUSINESS PLAN, AND COPIES OF MSDS SHEETS REPORTED TO THE GARDEN GROVE FIRE DEPARTMENT

Dbas GARDEN GROVE CHEVRON

Complex

Address

11162

GARDEN GROVE

Blvd

92843

Business Information

Business License No. 166804

Dunn and Bradstreet -

Sic Code- 5541

Fax

E-Mail

Business Owner Name Hamid Amir Firouzkouhi Home Phone 7145303585 Property Use

Construction Information

Construction type-

Occupany group- S3

Occupany Load- 0

Building Sq.ft- 0

Contacts Information

Property Owner

Chevron

Building Owner

Contacts

Inspection Information

Deleted and Archived by James

File number 228

Inspector- FPB N

Leveled - No longer in business. 12/16/03

Inspection History

2/3/03 Time 09:09

Employee No. - 6691Name - Valerie Thorpe

Action Performed - Permit Invoice

Notes - Permit Invoice Printed

\*\*\*\*\*

2/27/03 Time 10:11

Employee No. - 6691Name - Valerie Thorpe

Action Performed - Fire Code Permit

Notes - Fire Code Permit printed for a paid Invoice

\*\*\*\*\*

4/24/03 Time 10:12

1/21/03 Time 10:42

Employee No. - AdminName - Administrator

Action Performed - Life Safety Inspection

Notes - System generated Life Safety inspection printed for - Inspector FPB shift N FPB

\*\*\*\*\*

2/13/03 Time 07:26

Employee No. - 6691Name - Valerie Thorpe

Action Performed - Inspection Cleared

Notes - Inspection cleared using Status field on input form- Inspector 1705 Patrick Collins by Valerie Thorpe

\*\*\*\*\*

## Visits

12/16/03

Inspector Id- 0910Name - Nathan Brady

Insp. Type - Annual Life Safety

Category - Life Safety

Comments - Leveled - no longer in business. -Linderman

\*\*\*\*\*

2/12/03

Inspector Id- SI003Name - Steve Kriha

Insp. Type -

Category - Life Safety

Comments - No Violations

\*\*\*\*\*

## Violations

## Permits

Permit No- 291021

Permit description- MOTOR VEHICLE REPAIR / SERVICING

\*\*\*\*\*

Permit No- 791201

Permit description- FLAMMABLE / COMBUSTIBLE LIQUID - more than 120 gallons storage / transport

\*\*\*\*\*

Permit No- 791038

Permit description- FUEL DISPENSING STATION - flammable/combustible liquids + (Additional \$25 fee per each fuel dispenser over 3.)

\*\*\*\*\*

Permit No- 791032

Permit description- LEAK DETECTION MONITOR(S) for underground storage of flammable/ combustible liq.

\*\*\*\*\*

Permit No- 801031

Permit description- HAZARDOUS MATERIALS - use, handling or storage

\*\*\*\*\*

## EPS Information

Business Operator -

Phone -

Environmental Contact - Fred Anania



**Environmental Contact - Fred Azarnia**  
phone - 7145303585  
address - 11162 Garden Grove Blvd., Garden Grove CA 92843

**Chemical Information**

**Chemical Name - WASTE OIL**  
**Common name - WASTE OIL**  
\*\*\*\*\*

**Chemical Name - WASTE ETHYLENE GLYCOL**  
**Common name - WASTE ANTI-FREEZE**  
\*\*\*\*\*

**Chemical Name - GASOLINE**  
**Common name - GASOLINE**  
\*\*\*\*\*

**Tank Information**

**Tank Owner Name -**  
**Phone -**  
**Address-**

**Disclosure Local Information**

**Invoices**

**Date Billed 1/30/03**  
**- Bill type - Chemical/Tank**  
**Items**  
\*\*\*\*\*

**Date Billed 2/3/03**  
**- Bill type - Permit Bill**  
**Items**  
\*\*\*\*\*

**Date Billed 1/2/03**  
**- Bill type - Permit Bill**  
**Items**  
\*\*\*\*\*

**External Invoices**

**Notes**

0. PERMIT# : 000085  
 1. INSPECTION# : 004221  
 2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
 3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:152151  
 4. PHONE: 530-3585 10. OCC CLASS :S3  
 5. BILL-TO-NAME : GARDEN GROVE CHEVRON 11. ISSUE DATE :03-20-00  
 6. BILL-TO-ADDR : P.O. BOX 7066 12. EXPIRATION :02-28-01  
 7. BILL-TO-CSZ : NEWPORT BEACH CA 92658 13. TOTAL FEES :290.00  
 8. REMARKS : 14. INSPECTOR :5190  
 LUKAS JR, EDWARD F

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791201	FLAM/COMB +120 HAND/TRANS STORAGE, HANDLING, AND/OR TRANSPORTATION OF MORE THAN 120 GALLONS OF A FLAMMABLE/COMBUSTIBLE LIQUID IN A CONTAINER, TANK OR TANK VEHICLE.	105.00
2	791038	DISPENSING OF FLAM/COMB OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES. FOUR DISPENSERS	130.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDER-GROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	55.00
4	801031	HAZARDOUS MATERIALS USE, HANDLING OR STORAGE OF HAZARDOUS MATERIALS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	00.00

0. PERMIT# : 010047  
 1. INSPECTION# : 014169  
 2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
 3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:152151  
 4. PHONE: 530-3585 10. OCC CLASS :S3  
 5. BILL-TO-NAME : GARDEN GROVE CHEVRON 11. ISSUE DATE :03-08-01  
 6. BILL-TO-ADDR : PO BOX 7066 12. EXPIRATION :02-28-02  
 7. BILL-TO-CSZ : NEWPORT BEACH CA 92658 13. TOTAL FEES :290.00  
 8. REMARKS : 14. INSPECTOR :5190  
 LUKAS JR, EDWARD F

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791201	FLAM/COMB +120 HAND/TRANS STORAGE, HANDLING, AND/OR TRANSPORTATION OF MORE THAN 120 GALLONS OF A FLAMMABLE/COMBUSTIBLE LIQUID IN A CONTAINER, TANK OR TANK VEHICLE.	105.00
2	791038	DISPENSING OF FLAM/COMB	130.00

OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.

FOUR DISPENSERS

3 791032 FLAM/COMB MONITOR(S) 55.00

OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDER-GROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.

4 801031 HAZARDOUS MATERIALS 0.00

USE, HANDLING OR STORAGE OF HAZARDOUS MATERIALS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.

0. PERMIT# : 020066

1. INSPECTION# : 024130

2. PERMIT LOC : 11162 GARDEN GROVE BLVD

3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:166804

4. PHONE: 530-3585 10. OCC CLASS :S3

5. BILL-TO-NAME : GARDEN GROVE CHEVRON 11. ISSUE DATE :02-05-02

6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD 12. EXPIRATION :02-28-03

7. BILL-TO-CSZ : GARDEN GROVE CA 92843 13. TOTAL FEES :395.00

8. REMARKS : 14. INSPECTOR :1705

COLLINS, PATRICK S

=====  
NO. CODE DESCRIPTION / CONDITION FEE  
=====

1 791201 FLAM/COMB +120 HAND/TRANS 110.00  
STORAGE, HANDLING, AND/OR TRANSPORTATION OF MORE THAN 120 GALLONS OF A FLAMMABLE/COMBUSTIBLE LIQUID IN A CONTAINER, TANK OR TANK VEHICLE.

2 791038 DISPENSING OF FLAM/COMB 135.00  
OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.

3 791032 FLAM/COMB MONITOR(S) 60.00  
OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDER-GROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.

4 801031 HAZARDOUS MATERIALS 00.00  
USE, HANDLING OR STORAGE OF HAZARDOUS MATERIALS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.

5 291021 MOTOR VEH. REPAIR & SERVICING 90.00  
OPERATION OF A BUSINESS FOR THE PURPOSE OF REPAIRING OR SERVICING MOTOR VEHICLES SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES

0. PERMIT# : 030030

1. INSPECTION# :

2. PERMIT LOC : 11162 GARDEN GROVE BLVD

3. BUSINESS NAME: CHEVRON STATION                      9. BUS LICENSE:  
 4. PHONE: 375-2500                      10. OCC CLASS :UG TANK  
 5. BILL-TO-NAME : RBS ENTERPRISES                      11. ISSUE DATE :05-22-03  
 6. BILL-TO-ADDR : 19172 STEWART ST                      12. EXPIRATION :11-30-03  
 7. BILL-TO-CSZ : HUNTINGTON BEACH CA 92648                      13. TOTAL FEES :440.00  
 8. REMARKS : UG TANK REMOVAL                      14. INSPECTOR :2512

WAIDELICH, SUSAN C

```
=====
```

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791151	UNDERGROUND TANK REMOVAL UNDERGROUND FLAM/COMB STORAGE TANKS SHALL BE REMOVED IN ACCORDANCE WITH ALL APPLICABLE STATE AND LOCAL CODES.	440.00

0. PERMIT# : 10064  
 1. INSPECTION# : 014169  
 2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
 3. BUSINESS NAME: GARDEN GROVE CHEVRON                      9. BUS LICENSE:152151  
 4. PHONE: 530-3585                      10. OCC CLASS :S3  
 5. BILL-TO-NAME : GARDEN GROVE CHEVRON                      11. ISSUE DATE :02-28-01  
 6. BILL-TO-ADDR : P.O. BOX 7066                      12. EXPIRATION :  
 7. BILL-TO-CSZ : NEWPORT BEACH CA 92658                      13. TOTAL FEES :290.00  
 8. REMARKS :                      14. INSPECTOR :5190  
 LUKAS JR, EDWARD F

```
=====
```

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791201	FLAM/COMB +120 HAND/TRANS STORAGE, HANDLING, AND/OR TRANSPORTATION OF MORE THAN 120 GALLONS OF A FLAMMABLE/COMBUSTIBLE LIQUID IN A CONTAINER, TANK OR TANK VEHICLE.	105.00
2	791038	DISPENSING OF FLAM/COMB OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES. FOUR DISPENSERS	130.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDER- GROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	55.00
4	801031	HAZARDOUS MATERIALS USE, HANDLING OR STORAGE OF HAZARDOUS MATERIALS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	00.00

0. PERMIT# : 20043  
 1. INSPECTION# : 024130

2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
 3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:152151  
 4. PHONE: 530-3585 10. OCC CLASS :S3  
 5. BILL-TO-NAME : GARDEN GROVE CHEVRON 11. ISSUE DATE :02-28-02  
 6. BILL-TO-ADDR : PO BOX 7066 12. EXPIRATION :  
 7. BILL-TO-CSZ : NEWPORT BEACH CA 92658 13. TOTAL FEES :290.00  
 8. REMARKS : 14. INSPECTOR :5190  
 LUKAS JR, EDWARD F

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791201	FLAM/COMB +120 HAND/TRANS STORAGE, HANDLING, AND/OR TRANSPORTATION OF MORE THAN 120 GALLONS OF A FLAMMABLE/COMBUSTIBLE LIQUID IN A CONTAINER, TANK OR TANK VEHICLE.	105.00
2	791038	DISPENSING OF FLAM/COMB OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES. FOUR DISPENSERS	130.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDERGROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	55.00
4	801031	HAZARDOUS MATERIALS USE, HANDLING OR STORAGE OF HAZARDOUS MATERIALS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	0.00

0. PERMIT# : 900040  
 1. INSPECTION# : 903573  
 2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
 3. BUSINESS NAME: JIM'S CHEVRON SERVICE, #2 9. BUS LICENSE:104729  
 4. PHONE: 530-3585 10. OCC CLASS :B1  
 5. BILL-TO-NAME : JIM TREVORROW 11. ISSUE DATE :03-08-90  
 6. BILL-TO-ADDR : 520 W. 19TH 12. EXPIRATION :03-08-91  
 7. BILL-TO-CSZ : SANTA ANA, CA 92706 13. TOTAL FEES :420.00  
 8. REMARKS : 14. INSPECTOR :3515  
 HALBERSTADT, GERALD L

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791038	DISPENSING OF FLAM/COMB OPERATION OF (15) DISPENSING NOZZLES	220.00
2	791201	FLAM/COMB +120 HAND/TRANS OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANKS	100.00
3	451021	SPRAYING/DIPPING OPERATION OF (1) PARTS CLEANER UTILIZING FLAMMABLE/COMBUSTI-	100.00

BLE LIQUIDS

0. PERMIT# : 910109  
1. INSPECTION# : 913137  
2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
3. BUSINESS NAME: JIM'S CHEVRON SERVICE, #2 9. BUS LICENSE:104729  
4. PHONE: 530-3585 10. OCC CLASS :B1  
5. BILL-TO-NAME : JIM'S CHEVRON SERVICE, #2 11. ISSUE DATE :03-27-91  
6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD 12. EXPIRATION :03-26-92  
7. BILL-TO-CSZ : GARDEN GROVE, CA 92843 13. TOTAL FEES :400.00  
8. REMARKS : 14. INSPECTOR :4593  
KEIM, TARA E

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791038	DISPENSING OF FLAM/COMB OPERATION OF (18) GASOLINE DISPENSING NOZZLES SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	250.00
2	791201	FLAM/COMB +120 HAND/TRANS OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANKS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	100.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK-MONITORING SYSTEM FOR UNDERGROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	50.00

0. PERMIT# : 920353  
1. INSPECTION# : 922936  
2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
3. BUSINESS NAME: JIM'S CHEVRON SERVICE, #2 9. BUS LICENSE:104729  
4. PHONE: 530-3585 10. OCC CLASS :B1  
5. BILL-TO-NAME : JIM'S CHEVRON SERVICE, #2 11. ISSUE DATE :07-07-92  
6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD. 12. EXPIRATION :07-07-93  
7. BILL-TO-CSZ : GARDEN GROVE, CA 92843 13. TOTAL FEES :400.00  
8. REMARKS : 14. INSPECTOR :5190  
LUKAS JR, EDWARD F

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791038	DISPENSING OF FLAM/COMB OPERATION OF (18) GASOLINE DISPENSING NOZZLES SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	250.00
2	791201	FLAM/COMB +120 HAND/TRANS OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID	100.00

STORAGE TANKS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.

3 791032 FLAM/COMB MONITOR(S) 50.00  
OPERATION OF LEAK-MONITORING SYSTEM FOR UNDERGROUND STORAGE TANKS.

0. PERMIT# : 930424  
1. INSPECTION# : 932767  
2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:104729  
4. PHONE: 530-3585 10. OCC CLASS :B1  
5. BILL-TO-NAME : GARDEN GROVE CHEVRON 11. ISSUE DATE :08-10-93  
6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD 12. EXPIRATION :08-31-94  
7. BILL-TO-CSZ : GARDEN GROVE CA 92843 13. TOTAL FEES :400.00  
8. REMARKS : 14. INSPECTOR :3055  
GAMBA, TERESA K

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791038	DISPENSING OF FLAM/COMB OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES. (18 NOZZLES)	250.00
2	791201	FLAM/COMB +120 HAND/TRANS OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANK(S) SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	100.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDERGROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	50.00

0. PERMIT# : 940547  
1. INSPECTION# :  
2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
3. BUSINESS NAME: CHEVRON 9. BUS LICENSE:  
4. PHONE: 10. OCC CLASS :B1  
5. BILL-TO-NAME : ROBERT FISCUS AND ASSOC. 11. ISSUE DATE :11-22-94  
6. BILL-TO-ADDR : 12. EXPIRATION :11-22-95  
7. BILL-TO-CSZ : 13. TOTAL FEES :100.00  
8. REMARKS : NEW PRODUCT LINE INSTALLATION 14. INSPECTOR :5190  
LUKAS JR, EDWARD F

NO.	CODE	DESCRIPTION / CONDITION	FEE
-----	------	-------------------------	-----

1 791031 FLAM/COMB U/G TANKS 100.00  
 INSTALLATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID  
 STORAGE TANK, PIPING AND VAPOR RECOVERY SYSTEM SHALL COMPLY  
 WITH ALL APPLICABLE STATE AND LOCAL CODES.

0. PERMIT# : 950101  
 1. INSPECTION# :  
 2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
 3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:104729  
 4. PHONE: 530-3585 10. OCC CLASS :B1  
 5. BILL-TO-NAME : GARDEN GROVE CHEVRON 11. ISSUE DATE :02-22-95  
 6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD 12. EXPIRATION :02-28-96  
 7. BILL-TO-CSZ : GARDEN GROVE CA 92843 13. TOTAL FEES :460.00  
 8. REMARKS : 14. INSPECTOR :3055  
 GAMBA, TERESA K

```
=====
```

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791038	DISPENSING OF FLAM/COMB OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES. (24 NOZZLES)	310.00
2	791201	FLAM/COMB +120 HAND/TRANS OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANK(S) SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	100.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDER- GROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	50.00

```
=====
```

0. PERMIT# : 960021  
 1. INSPECTION# : 964808  
 2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
 3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:144707  
 4. PHONE: 530-3585 10. OCC CLASS :S3  
 5. BILL-TO-NAME : HAMID R. AMIR FIROUZKOUHI 11. ISSUE DATE :02-06-96  
 6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD 12. EXPIRATION :02-28-97  
 7. BILL-TO-CSZ : GARDEN GROVE CA 92843 13. TOTAL FEES :460.00  
 8. REMARKS : 14. INSPECTOR :5190  
 LUKAS JR, EDWARD F

```
=====
```

NO.	CODE	DESCRIPTION / CONDITION	FEE
-----	------	-------------------------	-----

```
=====
```



- 1 791201 FLAM/COMB +120 HAND/TRANS 100.00  
OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANK(S) SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.
- 2 791032 FLAM/COMB MONITOR(S) 50.00  
OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDERGROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.
- 3 791038 DISPENSING OF FLAM/COMB 310.00  
OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.  
24 DISPENSING NOZZLES

0. PERMIT# : 970017

- 1. INSPECTION# : 974401
- 2. PERMIT LOC : 11162 GARDEN GROVE BLVD
- 3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:144707
- 4. PHONE: 530-3585 10. OCC CLASS :S3
- 5. BILL-TO-NAME : HAMID R. AMIR FIROUZKOUHI 11. ISSUE DATE :02-28-97
- 6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD 12. EXPIRATION :02-28-98
- 7. BILL-TO-CSZ : GARDEN GROVE CA 92843 13. TOTAL FEES :460.00
- 8. REMARKS : 14. INSPECTOR :5190  
LUKAS JR, EDWARD F

```

=====
NO. CODE DESCRIPTION / CONDITION FEE
=====
1 791201 FLAM/COMB +120 HAND/TRANS 100.00
OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANK(S) SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.
2 791032 FLAM/COMB MONITOR(S) 50.00
OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDERGROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.
3 791038 DISPENSING OF FLAM/COMB 310.00
OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.
24 DISPENSING NOZZLES

```

0. PERMIT# : 970549

- 1. INSPECTION# : 974401
- 2. PERMIT LOC : 11162 GARDEN GROVE BLVD
- 3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:144707
- 4. PHONE: 530-3585 10. OCC CLASS :S3
- 5. BILL-TO-NAME : HAMID R. AMIR FIROUZKOUHI 11. ISSUE DATE :02-10-97
- 6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD 12. EXPIRATION :02-10-98

7. BILL-TO-CSZ : GARDEN GROVE CA 92843      13. TOTAL FEES :460.00  
 8. REMARKS       :                              14. INSPECTOR :5190  
   LUKAS JR, EDWARD F

```
=====
```

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791201	FLAM/COMB +120 HAND/TRANS OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANK(S) SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	100.00
2	791038	DISPENSING OF FLAM/COMB OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	310.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDERGROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	50.00

0. PERMIT#     : 980041  
 1. INSPECTION# : 984296  
 2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
 3. BUSINESS NAME: GARDEN GROVE CHEVRON      9. BUS LICENSE:144707  
 4. PHONE:     530-3585                           10. OCC CLASS :S3  
 5. BILL-TO-NAME : GARDEN GROVE CHEVRON      11. ISSUE DATE :02-11-98  
 6. BILL-TO-ADDR : 11162 GARDEN GROVE BLVD    12. EXPIRATION :02-11-99  
 7. BILL-TO-CSZ : GARDEN GROVE CA 92843      13. TOTAL FEES :460.00  
 8. REMARKS       :                              14. INSPECTOR :5190  
   LUKAS JR, EDWARD F

```
=====
```

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791201	FLAM/COMB +120 HAND/TRANS OPERATION OF UNDERGROUND FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANK(S) SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	100.00
2	791038	DISPENSING OF FLAM/COMB OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	310.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDERGROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	50.00

0. PERMIT#     : 980434  
 1. INSPECTION# :  
 2. PERMIT LOC : 11162 GARDEN GROVE BLVD

3. BUSINESS NAME: CHEVRON 9. BUS LICENSE:  
4. PHONE: 10. OCC CLASS :UG TANK  
5. BILL-TO-NAME : ACM DESIGN 11. ISSUE DATE :08-18-98  
6. BILL-TO-ADDR : 2001 LA FREMONTIA 12. EXPIRATION :08-18-99  
7. BILL-TO-CSZ : SOUTH PASADENA CA 91030 13. TOTAL FEES :210.00  
8. REMARKS : REMOVE 1M GALLON UG W.O. TANK 14. INSPECTOR :5190  
LUKAS JR, EDWARD F

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791151	UNDERGROUND TANK REMOVAL UNDERGROUND FLAM/COMB STORAGE TANKS SHALL BE REMOVED IN ACCORDANCE WITH ALL APPLICABLE STATE AND LOCAL CODES.	210.00

0. PERMIT# : 990061  
1. INSPECTION# : 994262  
2. PERMIT LOC : 11162 GARDEN GROVE BLVD  
3. BUSINESS NAME: GARDEN GROVE CHEVRON 9. BUS LICENSE:152151  
4. PHONE: 530-3585 10. OCC CLASS :S3  
5. BILL-TO-NAME : GARDEN GROVE CHEVRON 11. ISSUE DATE :03-01-99  
6. BILL-TO-ADDR : P.O. BOX 7066 12. EXPIRATION :02-28-00  
7. BILL-TO-CSZ : NEWPORT BEACH CA 92658 13. TOTAL FEES :290.00  
8. REMARKS : 14. INSPECTOR :5190  
LUKAS JR, EDWARD F

NO.	CODE	DESCRIPTION / CONDITION	FEE
1	791201	FLAM/COMB +120 HAND/TRANS STORAGE, HANDLING, AND/OR TRANSPORTATION OF MORE THAN 120 GALLONS OF A FLAMMABLE/COMBUSTIBLE LIQUID IN A CONTAINER, TANK OR TANK VEHICLE.	105.00
2	791038	DISPENSING OF FLAM/COMB OPERATION OF A FUEL DISPENSING STATION SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	130.00
3	791032	FLAM/COMB MONITOR(S) OPERATION OF LEAK DETECTION MONITORING SYSTEM FOR UNDER- GROUND STORAGE OF FLAMMABLE/COMBUSTIBLE LIQUIDS SHALL COMPLY WITH ALL APPLICABLE STATE AND LOCAL CODES.	55.00

# GARDEN GROVE FIRE DEPARTMENT PERMIT

11301 Acacia Parkway, 638-6721

11162 GC CLUD  
STANDARD STATION

In accordance with the Uniform Fire Code  
Permission is hereby granted to:

Name of Business PETROLEUM FACILITIES COAST Date 11/23

Address 15532 PONDWOOD DR. ANAHEIM Bus. Ph. 630 1672

- For the purpose of  installing  using  maintaining  operate
- Flammable Liquids  Candles  Public Assembly  Other
- Hazardous Materials  Gases/LPG  High-Pile Storage

Safety Requirements: INSTALLATIONS OF FOUR FIREWEAR TANK  
TO COMPLY WITH ALL MANUFACTURER RECOMMENDED PROCEDURES  
AND ACCORDING WITH UFC INT. 79 AND UFC WITH REGARD TO  
INSTALLATION TANK AND PRODUCT & VARIOUS LINES. EXISTING  
WELDED JOINTS SHALL BE TO PASSIVE TEST OF JOINT LINE

Time issued for: TERM OF JOB Signed Don Peters

Subject to revocation for proper cause or when necessary  
for public safety. Noncompliance with any provisions  
stipulated herein constitutes a violation of above code.

B. Spill ENG  
INSPECTOR RANK

PLEASE POST IN A CONSPICUOUS PLACE

F5-4401.2 WHITE: PERMITTEE, BLUE: INSP. FILE, ORANGE: FPB

# GARDEN GROVE FIRE DEPARTMENT PERMIT

11301 Acacia Parkway, 638-6721

11162 GC CLUD  
STANDARD STATION

In accordance with the Uniform Fire Code  
Permission is hereby granted to:

Name of Business PETROLEUM FACILITIES COAST Date 11/23/02

Address 15532 PONDWOOD DR. ANAHEIM Bus. Ph. 630 1672

- For the purpose of  installing  using  maintaining  operate
- Flammable Liquids  Candles  Public Assembly  Other
- Hazardous Materials  Gases/LPG  High-Pile Storage

Safety Requirements: TANKS TO BE REMOVED SHALL BE COMPLET  
LY DEFLAMMABLE LIQUIDS. DRY ICE SHALL BE USED  
TO COOL TANKS OF FLAMMABLE LIQUIDS TO 10 DEGREES OR LOWER  
BEFORE TANKS REMOVED. SEE INSTRUCTIONS TO BE PROVIDED  
BY THE MANUFACTURER OF TANKS

Time issued for: TERM OF JOB Signed Don Peters

Subject to revocation for proper cause or when necessary  
for public safety. Noncompliance with any provisions  
stipulated herein constitutes a violation of above code.

B. Spill ENG  
INSPECTOR RANK

PLEASE POST IN A CONSPICUOUS PLACE

F5-4401.2 WHITE: PERMITTEE, BLUE: INSP. FILE, ORANGE: FPB