



CITY OF GARDEN GROVE
FIRE DEPARTMENT

October 22, 2015

Ken Ledermann
A/E West Consultants Inc.

Re: Records Search for 7422 Chapman Ave. Garden Grove CA 92841

Dear Mr. Ledermann:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Don Nguyen'.

Don Nguyen
Senior Fire Protection Specialist

Visits

Violations

10/06/2015 Type of Visit - Annual Life Safety Inspector- William Shakespeare

Date issued - 10/06/2015
Violation - Provide Haz Mat placard. ADD 2- 704 PLACARDS. Inspector- William Shakespeare Date Cleared 00/00/00

04/05/2012 Type of Visit - Annual Life Safety Inspector- MAURILLIO TORRES

Date issued - 02/08/2011
Violation - Discontinue use of extension cords - vending. Sprinkler in computer room. Inspector- FPB Intern Date Cleared 02/24/2011

04/07/2011 Type of Visit - Reinspection Inspector- BENJAMIN KOSKY

Date issued - 03/04/2010
Violation - Michelle's office - hole in wall needs patching. Inspector- FPB Intern Date Cleared 03/18/2010

02/08/2011 Type of Visit - Mail Back Returned Inspector- FPB Intern

Date issued - 03/04/2010

Violation - Provide and maintain approved emergency lighting.- customer service East side Inspector- FPB Intern Date Cleared 03/18/2010

03/18/2010 Type of Visit - Reinspection Inspector- FPB Intern

03/04/2010 Type of Visit - Annual Life Safety Inspector- FPB Intern

Date issued - 01/22/2009

Violation - Keep 30" clear in front of elec. panel- molding area "clear wall onsite"
Inspector- Sabrina Soltis Date Cleared 02/05/2009

02/05/2009 Type of Visit - Inspector- Sabrina Soltis

01/22/2009 Type of Visit - Annual Life Safety Inspector- Sabrina Soltis

Date issued - 01/22/2009

Violation - Discontinue use of extension cords.- Armando's office
Inspector- Sabrina Soltis Date Cleared 02/05/2009

02/26/2008 Type of Visit - Reinspection Inspector- FPB Intern

02/14/2008 Type of Visit - Annual Life Safety Inspector- FPB Intern

Date issued - 02/14/2008

Violation - Lower storage - top rack west side Inspector- FPB Intern Date Cleared 02/26/2008

01/24/2007 Type of Visit - Annual Life Safety Inspector- FPB Intern

Date issued - 02/14/2008

Violation - Provide approved flammable liquid cabinet - ink

01/25/2006 Type of Visit - Annual Life Safety Inspector-