



CITY OF GARDEN GROVE
FIRE DEPARTMENT

TEL: (714) 741-5600
FAX: (714) 741-5640

January 14, 2016

Ashley Park
Environ Phase Consulting Company
(213) 738-6003

Records Search for 11711 Monarch Street, Garden Grove, CA 92841

Dear Ma'am:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Department.

Sincerely,

A handwritten signature in black ink, appearing to read 'Nate Brady', written over the word 'Sincerely,'.

Nate Brady
Division Chief/Fire Marshal

A handwritten signature in black ink, appearing to read 'Thanh Nguyen', written below the signature of Nate Brady.

By: Thanh Nguyen
Fire Captain/Senior Fire Protection Specialist

Inspection # :002494 1.Insp_Date:09-11-00
 2. Permit # :
 3. Address :11711 MONARCH ST
 4. Business Name/DBA :SEA AND SUN GRAPHICS
 5. Address Info : 6.Buslic :161385
 7. Business Owner :HUGO FLORES
 8. Business Address :11711 MONARCH ST 10.Bus Phone714-897-4020
 9. Business CityStZip:GARDEN GROVE, 92841 11.EmerPhone714-606-1211
 12.Occ Group :S1 16.5yr Cert. :11-30-98 20.MBCC :
 13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :09-11-00
 14.No of Ext :9.9 18.Haz Mat'l :N 22.InspectorId:2475
 15.Sprinklers:Y 19.ReInsp date: DUMAS, WILLIAM T

=====

Violation Code Violation description

=====

1 NO VIOLATIONS
 2

Inspection # :012462 1.Insp_Date:08-29-01
 2. Permit # :
 3. Address :11711 MONARCH ST
 4. Business Name/DBA :SEA AND SUN GRAPHICS
 5. Address Info : 6.Buslic :161385
 7. Business Owner :HUGO FLORES
 8. Business Address :11711 MONARCH ST 10.Bus Phone714-897-4020
 9. Business CityStZip:GARDEN GROVE, 92841 11.EmerPhone714-606-1211
 12.Occ Group :S1 16.5yr Cert. :11-30-98 20.MBCC :N
 13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :08-29-01
 14.No of Ext :9.9 18.Haz Mat'l :N 22.InspectorId:0928

15.Sprinklers:Y 19.ReInsp date: MARQUEZ JR, JOHN M

=====
Violation Code Violation description
=====

1 NO VIOLATIONS

2

Inspection # :022436 1.Insp_Date:
2. Permit # :
3. Address :11711 MONARCH ST
4. Business Name/DBA :SEA AND SUN GRAPHICS
5. Address Info : 6.Buslic :161385
7. Business Owner :HUGO FLORES
8. Business Address :11711 MONARCH ST 10.Bus Phone714-897-4020
9. Business CityStZip:GARDEN GROVE, 92841 11.EmerPhone714-606-1211
12.Occ Group :S1 16.5yr Cert. :11-30-98 20.MBCC :
13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :
14.No of Ext :9.9 18.Haz Mat'l :N 22.InspectorId:
15.Sprinklers:Y 19.ReInsp date:

=====
Violation Code Violation description
=====

1

2

Inspection # :933371 1.Insp_Date:09-13-93
2. Permit # :
3. Address :11711 MONARCH ST
4. Business Name/DBA :VACANT

5. Address Info : 6.Buslic :142098
7. Business Owner :NEW HERMES INC.
8. Business Address :11711 MONARCH ST 10.Bus Phone898-4509
9. Business CityStZip:GARDEN GROVE CA 92841 11.EmerPhone891-4647
12.Occ Group :B2 16.5yr Cert. : 20.MBCC :
13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :09-13-93
14.No of Ext :10.10 18.Haz Mat'l : 22.InspectorId:8253
15.Sprinklers:Y 19.ReInsp date: SPELL, MORRIS B

=====

Violation Code Violation description

=====

1 VACANT
2

Inspection # :943227 1.Insp_Date:08-29-94
2. Permit # :
3. Address :11711 MONARCH ST
4. Business Name/DBA :WILLIAM DETTMAN ENT.
5. Address Info : 6.Buslic :142098
7. Business Owner :
8. Business Address : 10.Bus Phone891-3990
9. Business CityStZip: 11.EmerPhone310-424-7220
12.Occ Group :B2 16.5yr Cert. :12-9-93 20.MBCC :Y
13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :09-17-94
14.No of Ext : 18.Haz Mat'l : 22.InspectorId:6567
15.Sprinklers:Y 19.ReInsp date: OWENS, MICHAEL J

=====

Violation Code Violation description

=====

- 1 UFC10.505 INSTALL 4 FIRE EXTINGUISHERS OF A 2A-10BC RATING
- 2 DO NOT TAPE ELECTRICAL CIRCUIT BREAKERS
- 3

Inspection # :953064 1.Insp_Date:08-22-95
 2. Permit # :
 3. Address :11711 MONARCH ST
 4. Business Name/DBA :WILLIAM DETTMAN ENT.
 5. Address Info : 6.Buslic :142098
 7. Business Owner :
 8. Business Address : 10.Bus Phone891-3990
 9. Business CityStZip: 11.EmerPhone310-424-7220
 12.Occ Group :B2 16.5yr Cert. :12-9-93 20.MBCC :
 13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :08-22-95
 14.No of Ext : 18.Haz Mat'l : 22.InspectorId:1404
 15.Sprinklers:Y 19.ReInsp date: CARTER, RICHARD L

=====

Violation Code Violation description

=====

- 1
- 2

Inspection # :962788 1.Insp_Date:09-03-96
 2. Permit # :
 3. Address :11711 MONARCH ST
 4. Business Name/DBA :WILLIAM DETTMAN ENT.
 5. Address Info : 6.Buslic :142098
 7. Business Owner :DETTA, WILLIAM
 8. Business Address :11711 MONARCH ST 10.Bus Phone891-3990

9. Business CityStZip:GARDEN GROVE CA 92841 11.EmerPhone310-424-0344
12.Occ Group :S1 16.5yr Cert. :12-9-93 20.MBCC :N
13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :09-20-96
14.No of Ext :9.9 18.Haz Mat'l :N 22.InspectorId:0258
15.Sprinklers:Y 19.ReInsp date:09-17-96 ASHBY, DOUGLAS E

=====
Violation Code Violation description
=====

- 1 UFC 1001.5 HAVE YOUR FIRE EXTINGUISHER(S) SERVICED ANNUALLY
- 2 BY A STATE FIRE MARSHAL-LICENSED BUSINESS.
- 3 HAVE FIRE EXTINGUISHER SERVICED
- 4 REMOVE EXIT SIGN IN BACK OFFICE.
- 5 VERBAL WARNING TO KEEP CLEAR COMBUSTIBLES FROM HEAT
- 6 PRODUCING UNITS.
- 7 PROVIDE FOR A TOTAL OF FIRE EXTINGUISHERS OF 2A10BC.

Inspection # :972595 1.Insp_Date:11-04-97
2. Permit # :
3. Address :11711 MONARCH ST
4. Business Name/DBA :WILLIAM DETTMAN ENT.
5. Address Info : 6.Buslic :142098
7. Business Owner :DETTMAN,WILLIAM
8. Business Address :11711 MONARCH ST 10.Bus Phone891-3990
9. Business CityStZip:GARDEN GROVE CA 92841 11.EmerPhone536-3677
12.Occ Group :S1 16.5yr Cert. :12-9-93 20.MBCC :Y
13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :11-25-97
14.No of Ext :9.9 18.Haz Mat'l :N 22.InspectorId:2821
15.Sprinklers:Y 19.ReInsp date:11-25-97 FERGUSON, B BRENT

=====

Violation Code Violation description

- =====
- 1 UFC 1203 ALL REQUIRED EXIT DOORS MUST BE UNOBSTRUCTED AND OPERATIONAL
 - 2 AT ALL TIMES WHEN THE PUBLIC IS PRESENT.
 - 3 INSTALL SIGN " THESE DOORS TO REMAIN OPEN DURING
 - 4 BUSINESS HOURS"
 - 5 DEAD BOLT TO REMAIN OPEN DURING BUSINESS HOURS
 - 6 MOUNT EXTINGUISHER AT NW CORNER OF WAVE HOUSE
 - 7 REMOVE HIGH PILE STOCK A MIN. OF 18" BELOW SPRINKLER HEADS

Inspection # :982533 1.Insp_Date:09-18-98
2. Permit # :
3. Address :11711 MONARCH ST
4. Business Name/DBA :WILLIAM DETTMAN ENT.
5. Address Info : 6.Buslic :142098
7. Business Owner :DETTMAN,WILLIAM
8. Business Address :11711 MONARCH ST 10.Bus Phone891-3990
9. Business CityStZip:GARDEN GROVE CA 92841 11.EmerPhone536-3677
12.Occ Group :S1 16.5yr Cert. :11-30-98 20.MBCC :
13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :09-18-98
14.No of Ext :9.9 18.Haz Mat'l :N 22.InspectorId:1404
15.Sprinklers:Y 19.ReInsp date: CARTER, RICHARD L

=====

Violation Code Violation description

=====

- 1 NO VIOLATIONS
- 2

Inspection # :992516 1.Insp_Date:11-17-99
 2. Permit # :
 3. Address :11711 MONARCH ST
 4. Business Name/DBA :SEA AND SUN GRAPHICS
 5. Address Info : 6.Buslic :161385
 7. Business Owner :HUGO FLORES
 8. Business Address :11711 MONARCH ST 10.Bus Phone714-897-4020
 9. Business CityStZip:GARDEN GROVE, 92841 11.EmerPhone714-606-1211
 12.Occ Group :S1 16.5yr Cert. :11-30-98 20.MBCC :N
 13.Occ Load : 17.FDC loc :NORTHSIDE OF BL 21.Clear date :11-17-99
 14.No of Ext :9.9 18.Haz Mat'l :N 22.InspectorId:0359
 15.Sprinklers:Y 19.ReInsp date: BARANGER, JOHN D

=====

Violation Code Violation description

====

1 NO VIOLATIONS
 2

GARDEN GROVE



FIRE DEPARTMENT

HAZARDOUS MATERIALS DISCLOSURE PROGRAM

REPORTING FORMS PACKET

SHORT VERSION

FOR OFFICIAL USE ONLY	
FACILITY ID NO.	<u>2734</u>
BUSINESS NAME	<u>Synertech P/M Inc</u>
BUSINESS ADDRESS	<u>11711 monarch st #B</u>
APPROVED BY	<u>G</u> DATE <u>10/2011</u>
NEW BUSINESS	<input type="checkbox"/> YES <input type="checkbox"/> NO UPDATE _____
PICK	<u>4D</u> BUSLIST <u> </u> CALARP: <u> </u> CUPA: <u> </u> GIS <u> </u>
FEE	_____



CITY OF GARDEN GROVE FIRE DEPARTMENT

11301 Acacia Parkway, Garden Grove, CA 92842 (714) 741-5600 (714) 741-5636

FORM 1

Hazardous Materials Business Information Form

Page ___ of ___ 3

BUSINESS INFORMATION

FACILITY # (Supplied by CGFD)		3 0 0 3 5	BEGINNING DATE	1	ENDING DATE	2	
BUSINESS NAME					4	BUSINESS PHONE	5
SYNERTECH PM, INC.						714-898-9151	
BUSINESS SITE ADDRESS							6
11711 MONARCH ST							
CITY			7	STATE	8	ZIP	9
GARDEN GROVE				CA		92841	
DUN & BRADSTREET		10	SIC CODE (4 DIGIT #)		11	FIRE DISTRICT	12
COUNTY							13
ORANGE							
BUSINESS OPERATOR NAME					14	OPERATOR'S PHONE	15
CHARLES BARRE						714-745-8950	

BUSINESS OWNER

OWNER NAME					16	OWNER PHONE	17
CHARLES BARRE						714-745-8950	
OWNER MAILING ADDRESS							18
12421 AMETHYST ST.							
CITY			19	STATE	20	ZIP	21
GARDEN GROVE				CA		92845	

ENVIRONMENTAL CONTACT

CONTACT NAME					22	CONTACT PHONE	23
KEVIN BARRE						714-745-8952	
CONTACT MAILING ADDRESS							24
11832 BLACKMER ST.							
CITY			25	STATE	26	ZIP	27
GARDEN GROVE				CA		92845	

PRIMARY

EMERGENCY CONTACTS

SECONDARY

NAME		28	NAME		33
KEVIN BARRE			CHARLES BARRE		
TITLE		29	TITLE		34
QUALITY MANAGER			PRESIDENT		
BUSINESS PHONE		30	BUSINESS PHONE		35
714-745-8952			714-745-8950		
24-HR. PHONE		31	24-HR. PHONE		36
SAME AS ABOVE			SAME AS ABOVE		
PAGER #		32	PAGER #		37
N/A			N/A		

ADDITIONAL LOCALLY COLLECTED INFORMATION

DESCRIBE THE TYPE OF BUSINESS OPERATION:			38	TOTAL # OF EMPLOYEES	39	
MANUFACTURING (CASTINGS/METAL PARTS)				17		
BILLING ADDRESS (IF DIFFERENT FROM ABOVE)				40	ATTENTION	41
PROPERTY OWNER NAME				42	ADDRESS	43
PHONE				43	PHONE	44

Certification: Based on my inquiry of those individuals responsible for obtaining the information, I certify under penalty of law that I have personally examined and am familiar with the information submitted and believe the information is true, accurate, and complete.

SIGNATURE OF OWNER/OPERATOR OR DESIGNATED REPRESENTATIVE			45	DATE	46
<i>Kevin D. Barre</i>				7-15-08	
NAME OF SIGNER (print)		47	NAME OF DOCUMENT PREPARER (print)		49
KEVIN D. BARRE			KEVIN BARRE		
TITLE OF SIGNER		48	TITLE OF DOCUMENT PREPARER		50
QUALITY MANAGER			Q.M.		



CITY OF GARDEN GROVE
11301 ACACIA PARKWAY
GARDEN GROVE, CALIFORNIA 92842
(714) 741-5636

CUPA

FACILITY INFORMATION

BUSINESS ACTIVITIES

KITTY HAWK

Page 1 of 1

I. FACILITY IDENTIFICATION

FACILITY ID#	3	0	0	3	5													1. EPA ID # (Hazardous Waste Only)	2.
--------------	---	---	---	---	---	--	--	--	--	--	--	--	--	--	--	--	--	------------------------------------	----

BUSINESS NAME (Same as FACILITY NAME or DBA-Doing Business As) 3.

II. ACTIVITIES DECLARATION

NOTE: If you check YES to any part of this list, please submit the Business Owner/Operator Identification page.

Does your facility...

If Yes, please complete these pages of the UPCF...

A. HAZARDOUS MATERIALS

Have on site (for any purpose) hazardous materials at or above 55 gallons for liquids, 500 pounds for solids, or 200 cubic feet for compressed gases (include liquids in ASTs and USTs); or the applicable Federal threshold quantity for an extremely hazardous substance specified in 40 CFR Part 355, Appendix A or B; or handle radiological materials in quantities for which an emergency plan is required pursuant to 10 CFR Parts 30, 40 or 70?

YES NO 4.

HAZARDOUS MATERIALS INVENTORY - CHEMICAL DESCRIPTION (Form 3)

B. UNDERGROUND STORAGE TANKS (USTs)

1. Own or operate underground storage tanks?

YES NO 5.

UST FACILITY (Formerly SWRCB Form A)
 UST TANK (one page per tank) (Formerly Form B)

2. Intent to upgrade existing or install new USTs?

YES NO 6.

UST FACILITY
 UST TANK (one per tank)
 UST INSTALLATION - CERTIFICATE OF COMPLIANCE (one page per tank) (Formerly Form C)

3. Need to report closing a UST?

YES NO 7.

UST TANK (closure portion-one page per tank)

C. ABOVE GROUND PETROLEUM STORAGE TANKS (ASTs)

Own or operate ASTs above these thresholds:
- any tank capacity is greater than 660 gallons, or
- the total aggregate capacity for the entire facility (ASTs, drums and portable containers) greater than 1,320 gallons?

YES NO 8.

NO FORM REQUIRED TO CUPAS

D. HAZARDOUS WASTE

1. Generate hazardous waste?

YES NO 9.

EPA ID NUMBER - provide at the top of this page

2. Recycle more than 100 kg/month of excluded or exempted recyclable materials (per HSC §25143.2)?

YES NO 10.

RECYCLABLE MATERIALS REPORT (one per recycler)

3. Treat hazardous waste on site?

YES NO 11.

ONSITE HAZARDOUS WASTE TREATMENT - FACILITY (Formerly DTSC Forms 1772)

ONSITE HAZARDOUS WASTE TREATMENT - UNIT (one page per unit) (Formerly DTSC Forms 1772A,B,C,D and L)

4. Treatment subject to financial assurance requirements (for Permit by Rule and Condition Authorization)?

YES NO 12.

CERTIFICATION OF FINANCIAL ASSURANCE (Formerly DTSC Form 1232)

5. Consolidate hazardous waste generated at a remove site?

YES NO 13.

REMOTE WASTE/CONSOLIDATION SITE ANNUAL NOTIFICATION (Formerly DTSC Form 1196)

6. Need to report the closure/removal of a tank that was classified waste and cleaned onsite?

YES NO 14.

HAZARDOUS WASTE TANK CLOSURE CERTIFICATION (Formerly DTSC Form 1249)

E. LOCAL REQUIREMENTS

Cal-ARP: California Accidental Release Prevention Program
H&SC Chapter 6.95, Article 2, §25531 et seq

YES NO 15.

REGULATED SUBSTANCE REPORTING FORM (Orange County CUPA)

--- Stationary Source with more than a Threshold Quantity of a Regulated Substance in a Process



HAZARDOUS MATERIALS INVENTORY FORM

FORM 3

ADD

DELETE

REVISED 1

Page 1 of 2 2

FACILITY ID#	3 0 0 3 5	BUSINESS NAME	SUNERTECH Plm, Inc.
--------------	-----------	---------------	---------------------

I. FACILITY INFORMATION

CHEMICAL LOCATION	CENTER WALL, CENTER OF BUILDING		
-------------------	---------------------------------	--	--

CONFIDENTIAL LOCATION EPCRA	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	MAP #	1	GRID #	G-6
-----------------------------	---	-------	---	--------	-----

II. CHEMICAL INFORMATION

CHEMICAL NAME	WASTE <input type="checkbox"/> Yes	TRADE SECRET <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
---------------	------------------------------------	--

COMMON NAME	Simple Green	An EHS Chemical <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
-------------	--------------	---

CAS #	10	FIRE CODE HAZARD CLASSES (supplied by GGFD)	13
-------	----	---	----

TYPE (Check one item only)	<input checked="" type="checkbox"/> a. PURE <input type="checkbox"/> b. MIXTURE <input type="checkbox"/> c. WASTE	RADIOACTIVE <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	CURIES	16
----------------------------	---	---	--------	----

PHYSICAL STATE (Check one item only)	<input type="checkbox"/> a. SOLID <input checked="" type="checkbox"/> b. LIQUID <input type="checkbox"/> c. GAS	FED HAZARD CATEGORIES	<input type="checkbox"/> a. FIRE <input type="checkbox"/> b. REACTIVE <input type="checkbox"/> c. PRESSURE RELEASE <input checked="" type="checkbox"/> d. ACUTE HEALTH <input checked="" type="checkbox"/> e. CHRONIC HEALTH	18
--------------------------------------	---	-----------------------	--	----

AVERAGE DAILY AMOUNT	55	MAXIMUM DAILY AMOUNT	55	ANNUAL WASTE AMOUNT	0	STATE WASTE CODE	22
----------------------	----	----------------------	----	---------------------	---	------------------	----

UNITS	<input checked="" type="checkbox"/> a. GALLONS <input type="checkbox"/> b. CUBIC FEET <input type="checkbox"/> c. POUNDS <input type="checkbox"/> d. TONS	DAYS ON SITE	1 YEAR	LARGEST CONTAINER	55 gal Drum
-------	---	--------------	--------	-------------------	-------------

STORAGE CONTAINER (Check all that apply)	<input type="checkbox"/> a. ABOVEGROUND TANK <input checked="" type="checkbox"/> e. PLASTIC DRUM <input type="checkbox"/> i. VAT <input type="checkbox"/> m. CYLINDER <input type="checkbox"/> q. TANK WAGON	<input type="checkbox"/> b. UNDERGROUND TANK <input type="checkbox"/> f. NONMETALLIC DRUM <input type="checkbox"/> l. FIBER DRUM <input type="checkbox"/> n. GLASS CONTAINER <input type="checkbox"/> r. RAIL CAR	<input type="checkbox"/> c. TANK INSIDE BLDG <input type="checkbox"/> g. METAL CONTAINER <input type="checkbox"/> o. PLASTIC CONTAINER <input type="checkbox"/> s. TOTE BIN	<input type="checkbox"/> d. STEEL DRUM <input type="checkbox"/> h. CARBOY <input type="checkbox"/> j. BOX(S) <input type="checkbox"/> p. IN MACH OR EQUIP <input type="checkbox"/> t. OTHER	26
--	--	---	---	---	----

STORAGE PRESSURE	<input checked="" type="checkbox"/> a. AMBIENT <input type="checkbox"/> b. ABOVE AMBIENT <input type="checkbox"/> c. BELOW AMBIENT	27
------------------	--	----

STORAGE TEMPERATURE	<input checked="" type="checkbox"/> a. AMBIENT <input type="checkbox"/> b. ABOVE AMBIENT <input type="checkbox"/> c. BELOW AMBIENT <input type="checkbox"/> d. CRYOGENIC	28
---------------------	--	----

%WT	HAZARDOUS COMPONENT (For mixture or waste only)	EHS	CAS #
1 29		<input type="checkbox"/> Yes <input type="checkbox"/> No 31	32
2 29		<input type="checkbox"/> Yes <input type="checkbox"/> No 31	32
3 29		<input type="checkbox"/> Yes <input type="checkbox"/> No 31	32
4 29		<input type="checkbox"/> Yes <input type="checkbox"/> No 31	32
5 29		<input type="checkbox"/> Yes <input type="checkbox"/> No 31	32

If more hazardous components are present at greater than 1% by weight if non-carcinogenic, or 0.1% by weight if carcinogenic, attach additional sheets of paper capturing the required information.


PLACARDING INFORMATION

UNDOT # _____ 33
Refer to shipping papers or MSDS

DOT HAZARD CLASS _____ 34
Refer to shipping papers or MSDS

EPCRA YES NO 35

X _____ 36
If EPCRA, Please Sign Here



MAKE AS MANY COPIES OF CHEMICAL INVENTORY FORM AS NEEDED



HAZARDOUS MATERIALS INVENTORY FORM

FORM 3

ADD

DELETE

REVISED 1

Page 1 of 2

FACILITY ID#	30035	BUSINESS NAME	SYNERTECH P/M, INC
--------------	-------	---------------	--------------------

I. FACILITY INFORMATION

CHEMICAL LOCATION CENTER WALL, MIDDLE OF BUILDING

CONFIDENTIAL LOCATION EPCRA Yes No 5 MAP # 1 6 GRID # G-8 7

II. CHEMICAL INFORMATION

CHEMICAL NAME Titanium, Aluminum, Steel WASTE Yes 8 TRADE SECRET Yes No 11
* If EPCRA see instructions

COMMON NAME Assorted Metal Powders 9 An EHS Chemical Yes No 12
*If EHS is "Yes", all amounts must be LBS

CAS # 10 FIRE CODE HAZARD CLASSES (supplied by GGFD) 13

TYPE (Check one item only) a. PURE b. MIXTURE c. WASTE 14 RADIOACTIVE Yes No 15 CURIES 16

PHYSICAL STATE (Check one item only) a. SOLID b. LIQUID c. GAS 17 FED HAZARD CATEGORIES a. FIRE b. REACTIVE c. PRESSURE RELEASE 18
 d. ACUTE HEALTH e. CHRONIC HEALTH

AVERAGE DAILY AMOUNT 1000 lbs 19 MAXIMUM DAILY AMOUNT 3500 lbs. 20 ANNUAL WASTE AMOUNT 0 21 STATE WASTE CODE 22

UNITS a. GALLONS b. CUBIC FEET 23 DAYS ON SITE 1 year - 4 years 24 LARGEST CONTAINER 30 gal. Bucket 25
 c. POUNDS d. TONS
*If EHS, amount must be in pounds.

STORAGE CONTAINER (Check all that apply) a. ABOVEGROUND TANK e. PLASTIC DRUM i. VAT m. CYLINDER q. TANK WAGON 26
 b. UNDERGROUND TANK f. NONMETALLIC DRUM j. FIBER DRUM n. GLASS CONTAINER r. RAIL CAR
 c. TANK INSIDE BLDG g. METAL CONTAINER k. BAG(S) o. PLASTIC CONTAINER s. TOTE BIN
 d. STEEL DRUM h. CARBOY l. BOX(S) p. IN MACH OR EQUIP t. OTHER

STORAGE PRESSURE a. AMBIENT b. ABOVE AMBIENT c. BELOW AMBIENT 27

STORAGE TEMPERATURE a. AMBIENT b. ABOVE AMBIENT c. BELOW AMBIENT d. CRYOGENIC 28

%WT	HAZARDOUS COMPONENT (For mixture or waste only)	EHS	CAS #
1	29	<input type="checkbox"/> Yes <input type="checkbox"/> No 30	31
2	29	<input type="checkbox"/> Yes <input type="checkbox"/> No 30	31
3	29	<input type="checkbox"/> Yes <input type="checkbox"/> No 30	31
4	29	<input type="checkbox"/> Yes <input type="checkbox"/> No 30	31
5	29	<input type="checkbox"/> Yes <input type="checkbox"/> No 30	31

If more hazardous components are present at greater than 1% by weight if non-carcinogenic, or 0.1% by weight if carcinogenic, attach additional sheets of paper capturing the required information.

PLACARDING INFORMATION

UNDOT # _____ 33
Refer to shipping papers or MSDS

DOT HAZARD CLASS _____ 34
Refer to shipping papers or MSDS

EPCRA YES NO 35

X _____ 36
If EPCRA, Please Sign Here

NFPA 704 HAZARD DIAMOND

HEALTH (BLUE) →

→ FIRE (RED)

← REACTIVE (YELLOW)

← WHITE OX/W

SPECIAL HAZARD →

MAKE AS MANY COPIES OF CHEMICAL INVENTORY FORM AS NEEDED



Hazardous Material Disclosure

Business Information / Chemical Inventory / Business Emergency Plan



GARDEN GROVE FIRE DEPARTMENT

11301 Acacia parkway

Garden Grove, CA 92840

Bus. (714) 741-5600 Fax (714) 741-5640

Hazardous Materials Coordinator

(714) 741-5636 → Mike Sanouick

Address: 11711 Monarch
Occupant or DBA: Synertech P/M, Inc
Owner/Manager: Kevin Barre'

Date: 07/09/08

File No: _____

Phone: 714-898-9151

California Health and Safety Code, Section 6.95, you are required to properly complete the Business Emergency Plan (BMP) packet. You are required to return the BEP packet, Hazardous Materials Disclosure Forms, and all material safety data sheets within fifteen (15) days to the Garden Grove Fire Department. HazMat Coord. (714) 741-5636

An inspection at the above location/occupancy revealed the following violation(s):

Violation(s): CA Health and Safety Code Chapter 6.95, Article 1 and Title 19, §2729 et seq. California Code of Regulations (CCR)

- Complete Hazardous Materials Disclosure packet, HSC Chapter 6.95, Title 19 Div 2 Chapter 3, CFC 8001.3.2
- Failure to submit a Business Emergency Plan. [HSC 25505(a)(1)]; CFC 8001.3.2
- Failure to review and/or revise the Business Emergency Plan as required [HSC 25505(b)&(c)]
- Chemical inventory is incomplete and/or requires update. [HSC 25509]
- The Emergency Response Plan is inadequate and/or does not address the following issues and shall be immediately revised and resubmitted: [HSC 25504(b)&(c)]
 - Notification Procedures
 - Mitigation Procedures
 - Evacuation Procedures
 - Employee Training
- Business Owner/Operator page is incomplete or needs to be updated. [HSC 25509]
- Failure to provide name, title, and 24-hour number of emergency contact(s). [HSC 25509(a)(7)]
- Site Map is incomplete or insufficient. [HSC 25509]
- Failure to report a release or threatened release. [HSC 25507]
- Failure to report a change in business or chemical inventory within 30 days of the following event(s): [HSC 25510]
 - 100% or more increase in the quantity of a disclosed material
 - Addition of a previously undisclosed material
 - Change in business address
 - Change in business ownership
 - Change of business name
 - Other (See comments below):

Violation(s): California Fire Code 2001, Articles 79 & 80, Title 19, Part 9, California Code of Regulations (CCR)

- Provide for secondary containment for hazardous materials liquids and solids (CFC 8003.1.3.3)
- Provide spill control for hazardous materials liquids (CFC 8003.1.3.2)
- Provide approved cabinet if more than 10 gallons of flammable liquids (CFC 7902.5)
- Provide placarding and signs (NFPA 704, CFC Article 79 §7901.9, Article 80 §8001.7-8)
- No Violations Found

Additional Violations and/or Notes:

Needs to update form 1 & 2

Responsible Party: X [Signature] 7-9-08

Re-inspection Date: 07/16/2008

The above are violations of California law and require immediate correction. Failure to correct violations is subject to civil penalties.

Fire Dept. Inspector: R. Walden ID #: 3703

Condition Upon Re-inspection: * 07/16/08 paper work was Date: _____

sent in prior to re-inspection date.



GARDEN GROVE FIRE DEPARTMENT

11301 Acacia Parkway, P. O. Box 3070
Garden Grove, CA 92842 (714) 741-5600

FINAL NOTICE

AND ORDER OF THE FIRE CHIEF

Date 10/6/14

Address of violation(s): 11711 MONARCH ST. Insp. No. _____

Occupant or DBA: PUBLIC BIO RECYCLING INC.

Business Owner Information: DN

Building Owner Information:

Owner: KEVIN BARDEE

Owner: CHARLES BARRE

Address: 11711 MONARCH ST.

Address: 11711 MONARCH ST.

City: GARDEN GROVE CA

City: GARDEN GROVE CA

Phone: 714 833-9706 Zip: 92841

Phone: 714 898-9151 Zip: 92841

A fire safety inspection at the above-named occupancy revealed violation(s) of the California Fire Code. You were provided written notification of the violation(s) and a reinspection was scheduled for 10/6/14.

Upon reinspection, the following violation(s) was/were found to be uncorrected:

NO OPEN AIR CONTAINER, PROVIDE SECONDARY CONTAINMENT
TO CEILING, REMOVE EMPTY WASTE DRUMS

California Fire Code as adopted by Section 18.04.010
e, you are hereby ordered to make all corrections as
n 10/8, 2014. Failure to comply with
constitutes a criminal offense and may subject the
administrative fines in an amount up to \$1,000 per violation
available.

2867 NEUYER
Inspector

Secondary Business
for Synertech

CLEAR

Inspector Signature: [Signature] Date: 10/8/14

Administrative Citation issued on _____



GARDEN GROVE FIRE DEPARTMENT

11301 Acacia Parkway, P. O. Box 3070
Garden Grove, CA 92842 (714) 741-5600

FINAL NOTICE AND ORDER OF THE FIRE CHIEF

Date 10/6/14

Address of violation(s): 11711 MONARCH ST. Insp. No. _____

Occupant or DBA: PUBLIC BIO RECYCLING INC.

Business Owner Information: DN

Building Owner Information:

Owner: KEVIN BARDEG

Owner: CHARLES BARRE

Address: 11711 MONARCH ST.

Address: 11711 MONARCH ST.

City: GARDEN GROVE CA

City: GARDEN GROVE CA

Phone: 714 833-9706 Zip: 92841

Phone: 714.898.9151 Zip: 92841

A fire safety inspection at the above-named occupancy revealed violation(s) of the California Fire Code. You were provided written notification of the violation(s) and a reinspection was scheduled for 10/6/14.

Upon reinspection, the following violation(s) was/were found to be uncorrected:

NO OPEN AIR CONTAINERS, PROVIDE SECONDARY CONTAINMENT
TO CEILING, REMOVE EMPTY WASTE DRUMS

Pursuant to Section 110.4 of the 2013 California Fire Code as adopted by Section 18.04.010 of the Garden Grove Municipal Code, you are hereby ordered to make all corrections as listed.

A FINAL reinspection will be made on 10/8, 2014. Failure to comply with all items of this order listed above constitutes a criminal offense and may subject the violator to criminal prosecution, administrative fines in an amount up to \$1,000 per violation and/or other enforcement actions as available.

2867 NGUYEN
Inspector

Condition upon Final reinspection: _____

CLEAR

Inspector Signature: [Signature] Date: 10/8/14

Administrative Citation issued on _____

**GARDEN GROVE FIRE DEPARTMENT
HAZARDOUS MATERIALS DISCLOSURE PROGRAM**

**THE FOLLOWING FORMS ARE FOR USE IN THE EVENT OF
AN ACTUAL OR THREATENING HAZARDOUS MATERIALS EMERGENCY.**

BUSINESS EMERGENCY PLAN

All businesses using, handling or storing hazardous materials that are required to disclose must complete a Business Emergency Plan. The occupancy groups listed below will be permitted to complete a short version of the business plan. The completion of the short form shall be considered the application required in the Health and Safety Code, Title 20, Chapter 6.95, Section 25503.5.

The Chief of the Garden Grove Fire Department in the role of the Administering Agency, allows the following types of businesses to file the short version of the Business Emergency Plan.

1. Gasoline/Diesel service stations. S-3 occupancies
2. Repair Garages. H-4 occupancies
3. Dry Cleaners
4. Businesses, at the Fire Chief's discretion, with less than 10 employees and using materials that are not considered highly or acutely toxic.

The Fire Chief exempts the following portions from the business plan. These exemptions have been established because the materials used in the above-mentioned occupancies are common knowledge to first responding units. The materials pose no significant, unexpected hazard nor do they affect the ability of the administering agency to effectively respond to their release of a hazardous material and that there are unusual circumstances justifying this exemption.

Exemptions

1. Detailed evacuation plans.
2. Detailed key employee responsibilities.
3. Training outline.
4. Detailed prevention outline.

The following Short Business Emergency Plan must be completed in order for the exemption to be granted.

**GARDEN GROVE FIRE DEPARTMENT
HAZARDOUS MATERIALS DISCLOSURE PROGRAM**

BUSINESS EMERGENCY PLAN

Personnel Emergency Notifications and Responsibilities

Employee Evacuation and Staging Areas:

1. The type of alarm signal that will be used to initiate an evacuation at the facility (vocal, paging system, manual alarm, etc.).

--

2. All employees shall be trained to evacuate the facility through at least one exit. Alternate exit routes shall be designated if available.
3. Staging areas shall be designated for all employees. Staging areas will be the location that all employees shall report to in the event of an emergency.

One person shall be designated to account for all personnel at the staging area. That person will be responsible for meeting the incoming Fire units and reporting the conditions known about the incident.

The Staging area is at the following location as shown on your site plan map:

--

Employee Responsibilities:

At least one employee shall be responsible for the following minimum requirements in the event of an emergency response by the Fire Department.

1. Notify employees. Initiate evacuation procedures.
2. Notify the Garden Grove Fire Department. Dial 911.
3. Try to identify the nature of the incident.
4. Report to the staging area and account for evacuated employees.
5. Report to the incoming fire units.
6. Activate any emergency mitigation procedures that area available at your business. (List below any mitigation procedures specific to your business, if any.)

**GARDEN GROVE FIRE DEPARTMENT
HAZARDOUS MATERIALS DISCLOSURE PROGRAM**

BUSINESS EMERGENCY PLAN

Personnel Emergency Notifications and Responsibilities (Continued)

Training Requirements

State law requires training of employees where the business uses, handles or stores hazardous materials.

Employee training provided on:

- Appointment of person/persons on site who are trained in key role positions. Emergency coordinator, evacuation coordinators, staging area supervisors and documenting officers.
- Procedures to follow during a release or threatened release of a hazardous material (evacuation to staging areas).
- Information contained in material safety data sheets.
- Warning labels/placards.
- Safe work practices.
- Use of on-site emergency equipment and supplies.
- Use and location of personal protective equipment.
- Any chemical, hazardous material or substance that could be encountered in his/her work area.
- On site alarm system for evacuation.
- Discuss possible release of hazardous materials scenario.

Emergency Notifications

A handler of hazardous materials is required to immediately report any release or threatened release of hazardous materials to the Garden Grove Fire Department. Failure to do so may result in criminal and/or civil prosecution.

Required Notifications

In the event of a release or threatened release of hazardous materials, it is State law to notify each of the following agencies.

<u>Agency</u>	<u>Phone Numbers</u>
Garden Grove Fire Department, Police, Paramedics Office of Emergency Services (OES)	911 (800) 852-7550 or (916) 427-4341
National Response Center	(800) 424-8802

**GARDEN GROVE FIRE DEPARTMENT
HAZARDOUS MATERIALS DISCLOSURE PROGRAM**

BUSINESS EMERGENCY PLAN

Personnel Emergency Notifications and Responsibilities (Continued)

Prevention

All materials are stored, used and handled within the guidelines of the Uniform Fire Code, N.F.P.A. standards, California Administrative Code, Titles 19 and 20.

This section is meant to initiate a Prevention Plan at your business and to assist in preventing a release, or threatened release, of a hazardous material. In the spaces provided, place a checkmark by the preventive actions which have been initiated by your business to abate hazards relating to hazardous material handling, use of storage.

Consideration shall include:

1. Drum storage and/or above ground tank storage areas:
 - a. Isolation and separation of incompatible materials.
 - b. Diking areas to contain spills.
 - c. Storage on paved ground.

2. Compressed and/or cryogenic gas storage areas:
 - a. Cylinder stored upright and secured.
 - b. Isolation and/or separation of incompatible cylinders (oxygen and flammable gases, etc.).

3. General:
 - a. Safe work practices are exercised in daily routines.
 - b. Employees who handle hazardous materials are properly trained.
 - c. Material Safety Data Sheets (MSDS) readily available for each hazardous material on the premises.
 - d. Labeling of all materials and storage areas with the product name and hazards associated with the product (drums, piping, tanks, etc.).
 - e. Uniform Fire Code (UFC) requires separation between outside hazardous material storage area or tanks and combustible materials (wood, bush, etc.).
 - f. Posting of "No Smoking" signs where appropriate.

GARDEN GROVE FIRE DEPARTMENT

BUSINESS EMERGENCY PLAN

A BUSINESS IS REQUIRED BY LAW TO NOTIFY THE GARDEN GROVE FIRE DEPARTMENT WITHIN 30 DAYS OF ANY OF THE FOLLOWING EVENTS.

- | |
|---|
| <ol style="list-style-type: none">1. Change of business address.2. Change of business ownership.3. Change of business name.4. Cessation of business operation (quitting business).5. Use or handling of a previously undisclosed hazardous material.6. A 100% increase in the quantity of a previously disclosed hazardous material. |
|---|

Your business is required by State law (CFC 8001.3.2) to retain a copy of this entire Hazardous Materials Disclosure information, including the Business Plan, chemical inventory, material safety data sheets and site maps, for review by Fire Department personnel. State where your disclosure and Emergency Business Plan will be kept.

Show location on site map also using symbol in the legend.

Note: A fee is charged for a replacement copy from the Garden Grove Fire Department.

I certify, under penalty of perjury, that the enclosed information is true and correct to the best of my knowledge.

Signature: _____

Name: _____

Title: _____

Date: _____

**Violation List for
SYNERTECH P/M INC.
11711 MONARCH St**

Date Issued	Date Cleared	Code #	Violation Description
08/01/2012	06/18/2013		REPLACE MISSING CEILING TILE. SECURE LOOSE RECEPTICL
07/03/2008	08/14/2008	CFC 1008.1.1	Provide approved panic hardware
07/03/2008	08/14/2008	CFC 1006.1	Provide and maintain approved emergency lighting.
07/03/2008	08/14/2008		Repair electrical panel
07/03/2008	08/14/2008	CFC 2701.5.1	Complete Haz Mat Disclosure packet
07/03/2008	08/14/2008	CFC 3003.5.1	Secure compressed gas cylinders.
07/03/2008	08/14/2008		Secondary containment for machine oil drum in back storage, vacuu
07/09/2008	07/15/2008	HSC 25509	Chemical inventory is incomplete / requires update.
07/20/2009	10/26/2009	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
07/20/2009	10/26/2009		55 gal drum containment
08/03/2010	08/10/2010	CFC 906.1	Provide extinguisher(s)
08/03/2010	08/10/2010	CFC 605.6	Discontinue use of extension cords.
08/03/2010	08/10/2010	CFC 3003.5.1	Secure compressed gas cylinders.
07/26/2011	08/09/2011	CFC 605.6	Discontinue use of extension cords.
07/26/2011	08/09/2011	CFC 105.6	Post Business License and Fire Department Permit
03/25/2014	06/10/2014	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
03/25/2014	11/17/2014	HSC 25505(e)	Failure to submit a Business Emergency Plan.
03/25/2014	04/15/2014	CFC 605.3	Keep 30" clear in front of elec. panel
03/25/2014	05/20/2014	CFC 503.4	Remove obstructions to fire apparatus access
03/25/2014	11/17/2014	HSC 25509	Chemical inventory is incomplete / requires update.

File No	Permit No	DBA / Address/Permit description	Date Expires
2734	801031	SYNERTECH P/M INC. 11711 MONARCH St HAZARDOUS MATERIALS - use, handling or storage	<u>8</u> 2014
2734	491011	SYNERTECH P/M INC. 11711 MONARCH St HOT WORK - welding and cutting / open flame	<u>8</u> 2015

2734 SYNERTECH P/M INC.

11711 MONARCH St

Max Daily Amount

Not Used/Used

Common Name ASSORTED METAL POWDERS

3500 Pounds

Chemical Name TITANIUM ALUMINUM STEEL

Map 1

Grid G8

Delete __ Modify __

Cas #

Location CENTER WALL MIDDLE OF BLDG

Common Name SIMPLE GREEN

55 Gallons

Chemical Name

Map 1

Grid G6

Delete __ Modify __

Cas #

Location CENTER WALL CENTER OF BLDG
