



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

5/9/2016

Tina Hariu
Geoterren Environmental Services for Trinity
(415) 827-4654

RE: Records Search for 11652 Markon Drive, Garden Grove CA

Dear Tina Hariu:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

A handwritten signature in black ink, appearing to read 'Thanh Nguyen', with a long horizontal flourish extending to the right.

Thanh Nguyen
Fire Captain/Senior Fire Protection Specialist

**Violation List for
MICROSEMI INTEGRATED PRODUCTS
11652 MARKON Dr**

Date Issued	Date Cleared	Code #	Violation Description
05/21/2015	08/26/2015	CFC 2703.5	Provide Haz Mat placard
05/21/2015	08/26/2015	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
02/26/2013	04/04/2013	CFC 1011.2	Provide illuminated exit sign(s).
02/28/2011	05/25/2011		Exit sign Ext. gate. Placard on storage.
02/28/2011	05/25/2011		Electrical: Label electrical door, clear obstruction in electrical room
02/28/2011	05/25/2011		Emergency lighting @ front / rear.
07/05/2010	06/07/2010	CFC ARTICL	PLACARDING AND SIGNS
06/07/2010	07/05/2010		label electral room
06/07/2010	07/05/2010	CFC 1011.2	Provide illuminated exit sign(s).
05/04/2009	12/01/2009		Close all ceiling tiles
05/04/2009	12/01/2009		Water calc - for riser.
05/04/2009	12/01/2009		Remove flammable cabinet from South Hallway
05/04/2009	12/01/2009		Remove acetone bottle (loose) near back door exit.
05/04/2009	12/01/2009		Clean up oil from around house vacuum pump
05/04/2009	12/01/2009		Remove loose handrail from 8330 Chase
05/04/2009	12/01/2009		post up to date Fire Dept permit
05/04/2009	12/01/2009	CFC 605.1	Provide/ replace electrical
04/10/2008	12/23/2008		Move hazmat storage to bin - 30 day
03/08/2007	11/07/2007		Repair or replace back gate- Provide a Knox padlock or automatic g
03/08/2007	11/07/2007		Replace ceiling tiles in new Diffusion chase - seal all penetrations. /
03/08/2007	11/07/2007		Replace poorly illuminated exit signes (at least 3 known) Back Hallw
03/08/2007	11/07/2007		Verify that the electrical permit for the hydrogen installation has beer
03/08/2007	11/07/2007		Repair or replace back gate leading to hydrogen tank.
03/08/2007	11/07/2007		Rehang loose FDC connection sign (near street)
03/08/2007	11/07/2007		Plug holes in back hallway fromn Onan seitchgear removal.
03/08/2007	11/07/2007		Address weeds growing in the electrical room. Seal wall to prevent tl
03/08/2007	11/07/2007		Remove all but one flammable material cabinet from back hallway b
04/18/2006	09/13/2006		metals room (properly store hydrochloric acid on floor.)
04/18/2006	09/13/2006		service extinguishers (tegal chase, lam chase, EPI chase
04/18/2006	09/13/2006		Emergency lights (F-02B)
04/18/2006	09/13/2006		Fix test button on exit sign (lockerroom)
04/18/2006	09/13/2006		Provide sticker for outside knox box.

**Violation List for
MICROSEMI INTEGRATED PRODUCTS
11652 MARKON Dr**

Date Issued	Date Cleared	Code #	Violation Description
04/18/2006	09/13/2006	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
07/06/2005	09/20/2005	M19	Complete the 5 year fire sprinkler certification.
07/06/2005	08/02/2005	M18	Ship out drums from soil remediation project.
07/06/2005	08/02/2005	M17	In the outdoor cylinder racks "full" and "empty" - replace signs, and e
07/06/2005	09/20/2005	M16	Discuss with GGFD HazMat the maximum level of diesel storage all
07/06/2005	09/20/2005	M15	Install awning/cover over hazardous waste storage area.
07/06/2005	08/02/2005	M14	Replace weak exit sign in main corridor.
07/06/2005	09/20/2005	M13	Contact Edison about bollard height for main transformers. At minim
07/06/2005	08/02/2005	M12	Relocate anticalant (Vitec) drum for DI system into proper secondary
05/24/2005	09/20/2005	M11	Provide secondary containment for hazardous waste.
05/24/2005	09/20/2005	M10	Provide bollards for 3 bulk tanks.
05/24/2005	09/20/2005	M09	Replace missing escutcheon on sprinkler in Chem Mix Room.
05/24/2005	09/20/2005	M08	Repair or replace smoke detector in Chemical Mix Room.
05/24/2005	07/06/2005	M07	Improve housekeeping in Chemical Mix Room.
05/24/2005	09/20/2005	M06	Develop inventory management plan for corrosive and flammable st
05/24/2005	08/02/2005	M05	Abate weeds in vacant lot. Trim trees in South -East corner
05/24/2005	07/06/2005	M04	Replace electrical cover for the time clock.
05/24/2005	07/06/2005	M01	Disconnect extension sign used for feed timer on Tri-Mer scrubber.
05/24/2005	07/06/2005	M02	Replace electrical cover in Chem-Mix room.
05/24/2005	07/06/2005	M03	Provide permanent / fixed electrical power to trailers.
03/24/2004	05/13/2004	1001.5	Replace missing escutcheon on sprinkler in Chem. mix room.
03/24/2004	05/13/2004	1001.5	Repair or replace smoke detector in chem. mix room.
03/24/2004	05/13/2004	1103	Provide housekeeping in chemical mix room.
03/24/2004	11/24/2004	8001	Develop inventory management. Plan for corrosives storage & flamr
03/24/2004	05/13/2004	1003	Abate weeds on adjoining lot.
03/24/2004	05/13/2004	8504	Provide/ replace electrical cover, power strip - chem. mix room, cor
03/24/2004	05/13/2004	8506	Discontinue use of extension cords - feed timer.
03/27/2003	05/09/2003	1111.2.2	Maintain all fire rated doors closed unless provided with approved dc
03/27/2003	10/30/2003	8001.11.3	Provide vehicle protection through the use of bollards or other mean
03/27/2003	05/09/2003	901.4.3	Label Fire Dept. Connection to indicate what addresses it serves.
03/27/2003	10/30/2003	8003.1.3.2	Improve the secondary containment on the waste containment pad.
03/27/2003	05/09/2003	1103.2.4	Provide weed abatement on the adjoining vacant lot south of facility.

**Violation List for
MICROSEMI INTEGRATED PRODUCTS
11652 MARKON Dr**

Date Issued	Date Cleared	Code #	Violation Description
00/00/00	04/04/2013		T- Bar sagging affecting sprinkler spray pattern.
00/00/00	00/00/00		
00/00/00	00/00/00		