

INCIDENT REPORT

INCIDENT

Fire Department: Garden Grove Fire Department
Incident Number: G1406858
Exposure Number: 00
Multi-Agency IC#:
Incident Date: 07/23/14
Dispatch Time: 06:00:51
Arrival Time: 06:05:24
Controlled Time:
Ending Time: 07:37:12
First-In Company: GE6
District: G2325
Incident Type: Building fire
Mutual Aid: None
Method of Alarm: E911
Type of Weather:
Air Temperature: 66
Address, CSZ: 12234 CHOISSER RD
Census Tract:
Fire Haz Sev Zone: Medium

RESOURCES & CASUALTIES

Actions Taken 1: Extinguishment by fire service personnel
Actions Taken 2: Salvage & overhaul
Actions Taken 3:
#Apparatus Resp Engine: 0
#Apparatus Resp Trk: 1
#Apparatus Resp Med: 1
#Apparatus Resp Oth: 4
Fire Svs Injury: 0
Fire Svs Fatal: 0
Non-FS Injury: 0
Non-FS Fatal: 0

PROPERTY & STUDIES

Property Losses: \$20,000
Content Losses: \$10,000
Property Value:
Contents Value:
Insurance Co:
Building Ins:
Mixed Prop Use:
Property Use: 1 or 2 family dwelling
Detector

INCIDENT REPORT

Hazmat Rel: None
Critical Inc:
Special Studies:

FIRE/ EXPLOSION SITUATION

Residential Units:
Bldgs. Involved: 1
Acres Burned:
On-Site Mat/Stor:
Area of Origin Attic: vacant, crawl space above top story, cupola
Heat Source: Multiple heat sources including multiple
First Item: Structural member or framing
Confined to Object: Sawn wood, including all finished lumber
Material Type: Sawn wood
Factor Causing: Cause undetermined after investigation
Contributing Factors 1: Electrical failure, malfunction, other
Contributing Factors 2:
Human Factor Cont 1: None
Human Factor Cont 2:
Human Factor Cont 3:
Age
Sex
Equip Involved: Electrical branch circuit
Equip Brand:
Equip Model:
Equip Serial Number:
Equip Year:
Equip Power Source: Electrical line voltage (> 50 volts)
Equip Portability: Stationary
Mobile Prop Inv:
Mobile Prop Type:
Mobile Prop Make:
Mobile Prop Model:
Mobile Prop Year:
Mobile Prop Lic. Plate:
Mobile Prop Lic. State:
Mobile Prop VIN Number:
Mobile Prop Stolen?:
Suppression Factors:

STRUCTURE FIRE

Type:
Status: Enclosed building
St Above Grnd: Occupied and operating
St Below Grnd: 1

INCIDENT REPORT

Main Floor Size: 0
Fire Origin: 2000
Extent of Flame: Attic: vacant, crawl space above top sto
Number of Stories Damage: Confined to object of origin
Minor:
Sign:
Heavy;
Extreme:
Auto Ext Sys: None Present
AES Type:
AES Operation:
Sprinkler Heads:
AES Failure Reason:
Detectors: Not present
Detector Type:
Det. Power Supply:
Det. Operation:
Det. Effectiveness:
Det. Failure Reason:

ARSON

Agency Name:
Address:
City:
State:
Zip:
Phone:
Their Case No.
Their ORI:
Their FID:
Their FDID:
Case Status:
Avail of Mat:
Motivation Factors 1:
Motivation Factors 2:
Motivation Factors 3:
Group Involvement 1:
Group Involvement 2:
Group Involvement 3:
Entry Method:
Extent of Fire:
Container:
Ignit Device:
Fuel:
Other Inv Info 1:
Other Inv Info 2:
Other Inv Info 3:
Property Ownership:
Int Observations 1:

INCIDENT REPORT

Int Observations 2:
Int Observations 3:
Lab Used 1:
Lab Used 2:
Lab used 3:

COMMENTS

***** GE6 *****

FRIE- STRUCTURE FIRE
CAPT VELOTTA

GE6 ARRIVED TO FIND SMOKE COMING FROM ATTIC VENTS / KNOCKED ON DOOR AND EVACUATED RESIDENTS / INSPECTED THE ATTIC TO FIND SMALL FIRE OVER THE LIVINGROOM AREA / HEAT, PAINT BUBBLING AND DISCOLORATION (BROWN) AREA NEAR FURTHEST CAN LIGHT / SALVAGE COVERS WERE PLACED BEFORE OPENING THE CEILING / UPON OPENING THE CEILING, GE6 FOUND 3 OF THE 2X6 CEILING JOISTS ON FIRE AND HAD BEEN BURNED COMPLETELY THROUGH / GE6 EXTINGUISHED THE FIRE AND OVERHAULED WITH THE HELP OF GT1 / THE AREA OF ORIGIN APPEARED TO BE WHERE ROMEX WIRING MADE CONTACT WITH THE JOISTS / THE RESIDENCE WAS RELEASED TO THE HOMEOWNER WITH ALL UTILITIES IN TACT EXCEPT THE ELECTRICAL WHICH WAS SHUT OFF AT THE BOX / RESIDENTS ADVISED TO CONTACT ELECTRICIAN BEFORE RE-ENERGIZING.