



GARDEN GROVE PUBLIC WORKS DEPARTMENT SERVICE REQUEST #410238

Service Request: 410238
Department: Public Works
Status: CLOSED
Priority: NORMAL
Created at: June 27, 2016 04:49PM

Requester: Holmon
Home Phone:
Work Phone: 741-5956
Other Phone:
Created by: allens

Request: NPDES COMMERCIAL, FSE INSPECTION OF HOMETOWN BUFFET #704 - FOLLOW UP 6/23/16 INCIDENT GREASE TRAP INTERCEPTOR OVERFLOW IN PARKING LOT.

Location: 9635 CHAPMAN AVE,

Public Property: NO
Square Feet:

Eng. Permit:
Police Num.:
Fire Num.:

File attachments: 1

Note #1 (06/27/16 by allens): Met with Isaias Salinaz, advised of the need for more frequent preventative maintenance of hydro jetting cleaning sewer lateral lines at FSE & pumping out cleaning of grease trap interceptor. Advised the need for more better employee training, no records. Verbal on site, & sent out a letter Notice of Violation from ECD.

Note #2 (07/29/16 by allens): Certified Mail Letter Article Number 7014 0510 0001 3887 8234 - Returned To Sender Dated 07/06/16

Task #1

Status: CLOSED **Status changed:** June 27, 2016 04:49PM

Description: NPDES COMMERCIAL, FSE INSPECTION OF HOMETOWN BUFFET #704

Category: 115 NPDES INSPECTION **Assigned to:** Albert Holmon III

Division: ENVIRONMENTAL COMP **Requester contacted:** _____

Completed by: Allen Serna **Date completed:** _____ **ECD:** _____

Actions: B, 115.10, 115.11, 115.12, 115.15, 115.17, 115.3, 115.3G1

Comments:

Other comments: _____

Labor Costs

Name	Reg	OT	Total
TOTAL	0 hours	0 hours	\$ 0.00

Equipment/Material Costs

Num	Description	Cost
1		
2		
	TOTAL	\$ 0.00