

## INCIDENT REPORT

## INCIDENT

Fire Department: Garden Grove Fire Department  
Incident Number: G1613468  
Exposure Number: 00  
Multi-Agency IC#: 16-124818 A1635135  
Incident Date: 11/25/16  
Dispatch Time: 00:34:09  
Arrival Time: 00:40:24  
Controlled Time: 01:13:22  
Ending Time: 02:35:55  
First-In Company: GE2  
District: G2217  
Incident Type: Building fire  
Mutual Aid: None  
Method of Alarm: E911  
Type of Weather:  
Air Temperature: 55  
Address, CSZ: 11791 MAC DUFF ST  
Census Tract:  
Fire Haz Sev Zone: Medium

## RESOURCES &amp; CASUALTIES

Actions Taken 1: Extinguishment by fire service personnel  
Actions Taken 2: Salvage & overhaul  
Actions Taken 3:  
#Apparatus Resp Engine: 0  
#Apparatus Resp Trk: 1  
#Apparatus Resp Med: 0  
#Apparatus Resp Oth: 3  
Fire Svs Injury: 0  
Fire Svs Fatal: 0  
Non-FS Injury: 0  
Non-FS Fatal: 0

## PROPERTY &amp; STUDIES

Property Losses: \$30,000  
Content Losses: \$60,000  
Property Value:  
Contents Value:  
Insurance Co:  
Building Ins:  
Mixed Prop Use:  
Property Use: 1 or 2 family dwelling  
Detector

INCIDENT REPORT

---

Hazmat Rel: None  
Critical Inc:  
Special Studies:

---

EMERGENCY MEDICAL SERVICE

---

Number of Patients:  
Billing Care:  
Status:  
Transported to:  
# Patients Trans - Fire:  
# Patients Trans - Amb:

---

COMMENTS

---

\*\*\*\*\* GE2 \*\*\*\*\*

STRUCTURE FIRE

GE2 ARRIVED TO FIND HEAVY SMOKE COMING FROM THE GARAGE AREA AND VENTS ON THE ROOF. GE2 ATTACKED THE FIRE AND CONFIRMED A PRIMARY SEARCH/EVACUATIONS WERE COMPLETE. GE2 AND UNITS ASSIGNED VENTILATED THE STRUCTURE AND SEARCHED FOR EXTENSION. THE FIRE AND STRUCTURE WERE EXTINGUISHED AND OVERHAULED. THE CAUSE OF THE FIRE WAS ISOLATED TO THE WATER HEATER IN THE GARAGE.

CAPTAIN  
M.WEISS