



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

1/19/2017

Richard Macias
(626) 806-5069

RE: Records Search for 13631 Harbor Blvd. Suite C & D, Garden Grove CA

Dear Mr. Macias:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks. This address was last inspected September, 2015 and no violations were noted.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

Thanh Nguyen
Fire Captain/Senior Fire Protection Specialist

Life Safety - Inspection Information for - 13631 HARBOR Blvd C , 92843 District-2623


Refer to FP HMS Code Enforcement Building Department Local Id Number _____ File # 8869
 Area Inspector _____ Station/Div Bureau _____ In Disclosure Program Self - Insp Y/N : N
 Inspector FPB FPB Shift N Inspector HMS _____ Fire District 2623
 Start Date _____ Freq 24 Next FD Insp Date 5 / 2017 Freq _____ Next HMS Insp Date /

Business Information

Business Name PRO TOP TOUCH-UP Business Phone 714 534-0645
 Address 13631 HARBOR Blvd C Fax No. _____
 Complex name _____ E-Mail _____
 Contact Type Name Type Phone Type Phone More contacts on back
 Business Owner [REDACTED] Emergency [REDACTED] Office 714-534-0645
 Address type Address
 Emergency One [REDACTED] [REDACTED]
 Address type Address
 Address type Address
 Address type Address
 Address type Address

Building Information

Contacts - Inspection, Emergency, Business owner, Property Owner, Property Mgmt

Bus. Lic # _____ Exp. _____ Occ. Load _____ Group _____ Business Type: _____
 FDC Location _____ Gate Access Code _____ Fire Alarm Code _____ 704 placard 
 Construction Type _____ Stories 0 Building Sq. Ft. 0 Unit Sq. Ft. 0 Common Attic
 Description _____ Roof Type _____ # of Units in Building _____
 Sprinklers (F/P/N) N 5 yr Test Date 0 / 0 Supervised Alarm (Y/N) _____ # of Employees _____
 Protection Systems _____ # of Students 0
 Pvt. Hyd Date One _____ No of Private Hydrants _____ # of Beds 0
 Pvt. Hyd Date Two _____ Water district _____ # of Customers 0
 # of Patients 0



Visits

Lock Boxes

09/29/2015 4407 Annual Life Safety NV, CLEARED
 08/09/2012 3631 Annual Life Safety NO VIOLATIONS
 09/28/2011 0001 Annual Life Safety Cleared 0071 Janovick

Special Information

No auto repair at this time. Needs no permit. Spraying limited to 9 sq. feet only. Keep in the FPB to check next year to see if anything is different.

Responding Unit Comments

Permit Information

Violation History

09/14/2011 Verbal: extinguishers expire Novem
 09/14/2011 CFC 605.1 Provide/ replace electrical covers x
 09/14/2011 CFC 1011.2Provide illuminated exit sign(s).
 09/14/2009 CFC 901.6 Service and tag Fire Extinguishers.-
 09/14/2009 CFC 906.1 Provide extinguisher- work door

Date ___/___/___ Employee No. _____ Name _____ Type _____ Disp _____ Time Start _____ Time End _____

Life Safety - Inspection Information for - 13631 HARBOR Blvd D , 92843 District-2623

Refer to FP HMS Code Enforcement Building Department Local Id Number 024926 File # 5028
 Area Inspector E3 Engine 3 Station/Div 3 In Disclosure Program Self - Insp Y/N : N
 Inspector E3 Engine 3 Shift B Inspector HMS Fire District 2623
 Start Date _____ Freq 24 Next FD Insp Date 9 / 2017 Freq _____ Next HMS Insp Date /

Business Information

Business Name AUCTIONS PLUS Business Phone 714 539-1297
 Address 13631 HARBOR Blvd D Fax No. _____
 Complex name _____ E-Mail _____

Contact Type Name Type Phone Type Phone More contacts on back

Emergency One CHARLES RICHARDO
 Address type Address

Address type Address

Address type Address

Address type Address

Address type Address

Building Information

Contacts - Inspection, Emergency, Business owner, Property Owner, Property Mgmt

Bus. Lic # 157314 Exp. _____ Occ. Load _____ Group B Business Type: _____

FDC Location _____ Gate Access Code _____ Fire Alarm Code _____ 704 placard 

Construction Type _____ Stories 0 Building Sq. Ft. 0 Unit Sq. Ft. 0 Common Attic

Description _____ Roof Type _____ # of Units in Building _____

Sprinklers (F/P/N) _____ 5 yr Test Date 0 / 0 Supervised Alarm (Y/N) _____ # of Employees _____

Protection Systems _____ # of Students 0

Pvt. Hyd Date One _____ No of Private Hydrants _____ # of Beds 0

Pvt. Hyd Date Two _____ Water district _____ # of Customers 0

of Patients 0

| Visits | | Lock Boxes |
|------------|--------------------------------------------------------|------------|
| 09/16/2015 | 1705 Annual Life Safety NO VIOLATIONS. CLEARED. | |
| 09/20/2013 | 3767 Annual Life Safety NO VIOLATIONS. 9/18/13 CLOSED. | |
| 10/20/2011 | 1664 Annual Life Safety No Violations | |

Special Information

Responding Unit Comments

Permit Information

Violation History

11/10/2009 CFC 1028.3Remove exit obstruction

Date / / Employee No. _____ Name _____ Type _____ Disp _____ Time Start _____ Time End _____

**Violation List for
PRO TOP TOUCH-UP
13631 HARBOR Blvd C**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|---------------------------------------------------------------------|
| 09/14/2011 | 09/28/2011 | | Verbal: extinguishers expire November. Cover wires in upstairs offi |
| 09/14/2011 | 09/28/2011 | CFC 605.1 | Provide/ replace electrical |
| 09/14/2011 | 09/28/2011 | CFC 1011.2 | Provide illuminated exit sign(s). |
| 09/14/2009 | 09/28/2009 | CFC 901.6 | Service and tag Fire Extinguishers. |
| 09/14/2009 | 09/28/2009 | CFC 906.1 | Provide extinguisher(s) |
| 09/14/2009 | 09/28/2009 | CFC 505.1 | Provide address visible from the street |

**Violation List for
AUCTIONS PLUS
13631 HARBOR Blvd D**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|------------------------------|
| 11/10/2009 | 11/10/2009 | CFC 1028.3 | Remove exit obstruction |