



**CITY OF GARDEN GROVE**  
**FIRE DEPARTMENT**

**Tel: (714) 741-5600**  
**Fax: (714) 741-5640**

3/30/2017

Crystal Castellanos  
Avalon Environmental Consultants  
(714) 836-6632

RE: Records Search for 10372 & 10382 Stanford Ave., Garden Grove CA

Dear Crystal Castellanos:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

Brad Spell  
Fire Captain/Senior Fire Protection Specialist

**Violation List for  
JMN CUSTOM CABINET & MILLWORK SPECIALIST INC.  
10382 STANFORD Ave K**

---

<b>Date Issued</b>	<b>Date Cleared</b>	<b>Code #</b>	<b>Violation Description</b>
05/25/2010	06/10/2010	CFC 3404.3.	Provide approved safety container(s) for flammable liquids.

**Violation List for  
CONNECTION LOGISTICS  
10382 STANFORD Ave G**

---

<b>Date Issued</b>	<b>Date Cleared</b>	<b>Code #</b>	<b>Violation Description</b>
08/02/2012	08/13/2012	CFC 906.1	Provide extinguisher(s)

**Violation List for  
INTERNATIONAL MEAT & DELI  
10382 STANFORD Ave F**

---

<b>Date Issued</b>	<b>Date Cleared</b>	<b>Code #</b>	<b>Violation Description</b>
08/02/2011	08/02/2011	CFC 605.6	Discontinue use of extension cords.
07/30/2009	09/12/2009	CFC 904.11.f	Service auto-extinguishing system semi-annually.

**Violation List for  
STATE FARM INS.  
10382 STANFORD Ave H**

---

<b>Date Issued</b>	<b>Date Cleared</b>	<b>Code #</b>	<b>Violation Description</b>
08/02/2011	08/02/2011	CFC 901.6	Service and tag Fire Extinguishers.
07/30/2009	09/17/2009	CFC 906.1	Provide extinguisher(s)
07/05/2006	07/09/2007	CFC 1001.5.	Service and tag Fire Extinguishers.
07/28/2003	08/29/2003	1001.5.1	Hang extinguishers on bracket, maximum 5' from floor.
07/28/2003	08/29/2003	1001.5.1	Service and tag extinguishers.