



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

4/5/17

Chris Hayden
HEI Corporation
(714) 875-1362

RE: Records Search for 10532 Trask Ave., Garden Grove CA

Dear Chris Hayden:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

A handwritten signature in black ink, appearing to read 'Brad Spell', written in a cursive style.

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
PACIFIC MACHINE CO
10532 TRASK Ave A/B**

Date Issued	Date Cleared	Code #	Violation Description
05/22/2014	06/19/2014	CFC 315.3.2	REMOVE STORAGE UNDER STAIRWAY. 0021-RAQUEL ALTMA
05/22/2014	06/19/2014	CFC 901.6	Service and tag Fire Extinguishers.
05/22/2014	06/19/2014	CFC 3003.5.1	Secure compressed gas cylinders.
05/22/2014	06/19/2014	CFC 1011.2	Provide illuminated exit sign(s).
05/22/2014	00/00/00	HSC 25505(e)	Failure to submit a Business Emergency Plan.
09/11/2012	10/01/2012	CFC 3003.5.1	Secure compressed gas cylinders.
09/11/2012	10/01/2012	CFC 2701.5.1	Complete Haz Mat Disclosure packet
09/21/2011	10/05/2011		Patch Ceiling. OK 10/5
09/21/2011	10/05/2011	CFC 2701.5.1	Complete Haz Mat Disclosure packet
12/01/2010	12/01/2010		Housekeeping - Sweep metal shavings
12/01/2010	12/01/2010	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
10/21/2008	10/27/2008	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
09/08/2008	09/08/2008	HSC 25509	Chemical inventory is incomplete / requires update.
10/01/2002	10/29/2002	CFC-8509	Electrical panel clearance 30"
10/01/2002	10/29/2002	CFC-8506.1	Remove extension cords
10/01/2002	10/29/2002	CFC-1001.5.	Fire Extinguishers Service
10/01/2002	10/29/2002	CFC - 1002.1	Provide Fire Extinguishers