

INCIDENT REPORT

INCIDENT

Fire Department: Garden Grove Fire Department
Incident Number: G1704481
Exposure Number: 00
Multi-Agency IC#: A1711088
Incident Date: 04/15/17
Dispatch Time: 00:14:05
Arrival Time: 00:20:08
Controlled Time: 00:35:52
Ending Time: 01:23:20
First-In Company: GE6
District: G2224
Incident Type: Fire, other
Mutual Aid: None
Method of Alarm: Telephone
Type of Weather:
Air Temperature: 55
Address, CSZ: 12271 BLUEBELL AV
Census Tract:
Fire Haz Sev Zone: Medium

RESOURCES & CASUALTIES

Actions Taken 1: Extinguishment by fire service personnel
Actions Taken 2:
Actions Taken 3:
#Apparatus Resp Engine: 2
#Apparatus Resp Trk: 1
#Apparatus Resp Med: 1
#Apparatus Resp Oth: 1
Fire Svs Injury: 0
Fire Svs Fatal: 0
Non-FS Injury: 0
Non-FS Fatal: 0

PROPERTY & STUDIES

Property Losses: \$5,000
Content Losses: \$1,000
Property Value:
Contents Value:
Insurance Co:
Building Ins:
Mixed Prop Use:
Property Use: 1 or 2 family dwelling
Detector: Detector did not alert occupants

INCIDENT REPORT

Hazmat Rel: None
Critical Inc:
Special Studies:

FIRE/ EXPLOSION SITUATION

Residential Units:
Bldgs. Involved: 0
Acres Burned:
On-Site Mat/Stor:
Area of Origin Attic: vacant, crawl space above top story, cupola
Heat Source: Hot or smoldering object, other
First Item: Undetermined
Confined to Object: Natural product, other
Material Type: Insufficient Information
Factor Causing: Unintentional
Contributing Factors 1: Electrical failure, malfunction, other
Contributing Factors 2:
Human Factor Cont 1: None
Human Factor Cont 2:
Human Factor Cont 3:
Age
Sex
Equip Involved: Electrical wiring, other
Equip Brand:
Equip Model:
Equip Serial Number:
Equip Year:
Equip Power Source: Electrical, other
Equip Portability: Stationary
Mobile Prop Inv:
Mobile Prop Type:
Mobile Prop Make:
Mobile Prop Model:
Mobile Prop Year:
Mobile Prop Lic. Plate:
Mobile Prop Lic. State:
Mobile Prop VIN Number:
Mobile Prop Stolen?:
Suppression Factors:

COMMENTS

***** GE6 *****

STRUCTURE FIRE

INCIDENT REPORT

GE6 RESPONDED TO A SINGLE STORY HOUSE WITH LIGHT SMOKE COMING FROM THE ATTIC VENTS, GE6 FOUND A WIRE FROM THE CLOSET AREA THAT BURNT THE TOP PLATE AND CHARRED THE RAFTER GOING TO A BEDROOM LIGHT. GE6 OPENED A HOLE IN THE FRONT BEDROOM TO EXPOSE THE BURNT RAFTER.

CAPT ACOSTA