CITY OF GARDEN GROVE PUBLIC WORKS FIRE HYDRANT FLOW TEST

Ty	pe of F.H. LONG	BEACH / WET B	ARREL Atlas She		eet Al 19	
Fire Hyd. #			Location of flow	ed FH	12242 Weste	rn
Date of Test 10-05-		5-2016	Weather Conditions		Cloudy	
Pressure gauge placed on fire hydrant at:		12242 Western				
		e ·	Test1		Test2	
1.	Static pressure before test		65	_ psi		_ psi
2.	Size of outlet to be flowed		2.5	inch	YI B	inch
3.	Time of flow test		09:16:56 AM	≅	4	-
4.	Average pitot reading during flow		42	_ psi		_ psi
5.	Average pressure reading during flow (Residual Pressure)		56	_ psi	n	psi
6.	Drawdown (1 minus 5)		9	psi		psi
7.	Rate of flow computed at residual press		1088	gpm		gpm
8.	Rate of flow computed at 20 psi residual		2590	gpm		gpm
9.	Time of day flow ended		09:18:08 AM	<u>-</u> 8		<u>=</u>
10.	Pressure reading after flow at hose bib		64	psi	~	psi
11.	Total time water flowed (3 minus 9)		1.194	min	9	min
12.	Water wasted during test (7 times 11)		1299	gals		gals
					*	
REMARKS:						
Test	t Conducted By :	Scott, Mike				22 E
Test	t Reviewed By Engineer:	Rebecca	The	No		
Test	t Posted By:	Scott	(a)			