



## GARDEN GROVE PUBLIC WORKS DEPARTMENT SERVICE REQUEST #424367

**Service Request:** 424367

**Department:** Public Works

**Status:** CLOSED

**Priority:** HIGH

**Created at:** April 17, 2017 09:09AM

**Requester:** Holmon

**Home Phone:**

**Work Phone:** 741-5956

**Other Phone:**

**Created by:** allens

**Request:** NPDES COMMERCIAL, FSE INSPECTION OF SHERATON GARDEN GROVE - ANAHEIM SOUTH

**Location:** 12221 HARBOR BLVD,

**Public Property:** NO

**Square Feet:**

**Eng. Permit:**

**Police Num.:**

**Fire Num.:**

---

**Note #1 (04/17/17 by allens):** Met with Xerxes Banayos, advised of city's policies & NPDES regulations, advised to provide screens/strainers in all sinks & drains, provide receipt invoice for servicing of the interceptor & used cooking oil within 5 days, replace fossil filter socks and clean area regularly at the storm drain grate WQMP on the Southside of the property. Verbal on site.

**Note #2 (04/21/17 by liag):** ON 4/20/2017,INVOICES FOR UCO/GREASE INTERCEPTOR SERVICE WERE PROVIDED VIA EMAIL. ALL VIOLATIONS WERE CORRECTED.

---

### Task #1

**Status:** CLOSED on April 17, 2017 09:09AM by Allen Serna

**Description:** NPDES COMMERCIAL, FSE INSPECTION OF SHERATON GARDEN GROVE - ANAHEIM SOUTH

**Category:** 115 NPDES INSPECTION

**Assigned to:** Albert Holmon III

**Division:** ENVIRONMENTAL COMP

**Requester contacted:**

**Completed by:** Allen Serna

**ECD:**

**Actions:** 115.3 COMMERCIAL, 115.1L VERBAL WARNING, 115.17 BMP PARTIALLY IMPLEMENTED, A HIGH PRIORITY, 115.12 COMPLETED INSPECTION FORM, 115.10 EXPLAINED NPDES POLICIES, 115.15 OTHER (SEE COMMENTS), 115.3G1 EATING OR DRINKING ESTABLISHMENTS, 115.11 PROVIDED EDUCATIONAL BROCHURES, 115.3a FOOD SERVICE ESTABLISHMENT