



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

5/16/17

Alicia Jansen
Stantec Consulting Services
(909) 255-8213

RE: Records Search for 12821 Knott Street, Garden Grove CA

Dear Alicia jansen:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
NEXT LEVEL SPORTS COMPLEX
12821 KNOTT St**

Date Issued	Date Cleared	Code #	Violation Description
12/14/2016	01/09/2017	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
12/14/2016	01/09/2017	CFC 906.1	Provide extinguisher(s)
12/14/2016	00/00/00	CFC 605.3	Keep 30" clear in front of elec. panel
12/14/2016	01/09/2017	CFC 605.1	Provide/ replace electrical
12/14/2016	00/00/00	CFC 1011.2	Provide illuminated exit sign(s).
12/14/2016	00/00/00	CFC 1008.1.1	Provide approved panic hardware
12/14/2016	00/00/00	CFC 1004.3	Post maximum occupancy load sign
12/14/2016	00/00/00	CFC 901.6	Service and tag Fire Extinguishers.
12/03/2015	05/02/2016	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
10/22/2015	00/00/00	CFC 105	Needs permit..
10/22/2015	05/02/2016	NFPA 25	Replace Target Plates for PIV #1 and #2
10/22/2015	12/03/2015	CFC 703.1	Replace ceiling tiles 2nd Lvl South Stairs and in room 109 Open
10/22/2015	01/06/2016	CFC 901.6	Service and tag Fire Extinguishers.
10/22/2015	01/06/2016	CFC 315.2.1	Lower storage
10/22/2015	12/03/2015	CFC 1028.3	Remove exit obstruction
10/22/2015	12/03/2015	CFC 1011.2	Provide illuminated exit sign(s).
10/22/2015	12/03/2015	CFC 1008.1.1	Provide approved panic hardware
10/22/2015	12/03/2015	CFC 9	Clean/Dust fire sprinkler heads located inside the control booth
10/03/2013	09/23/2013	CFC 901.6	Service and tag Fire Extinguishers.
10/03/2013	09/23/2013	CFC 605.1	Provide/ replace electrical
10/03/2013	09/23/2013	CFC 1011.2	Provide illuminated exit sign(s).
10/03/2013	09/23/2013	CFC 906.1	Provide extinguisher(s)
10/03/2013	09/23/2013	CFC 1008.1.1	Provide approved panic hardware
10/15/2012	10/03/2013	CFC 1004.3	Post maximum occupancy load sign
00/00/00	10/03/2013		Waiting for plan for the old Radio Shack, ceiling tile maybe required

**Violation List for
LEARN 4 LIFE
12821 KNOTT St**

Date Issued	Date Cleared	Code #	Violation Description
10/22/2015	12/03/2015	CFC 901.6	Service and tag Fire Extinguishers.
10/22/2015	12/03/2015	CFC 703.1	Replace missing ceiling tiles in South stairwell and in room 109
10/22/2015	12/03/2015	CFC 1011.2	Provide illuminated exit sign(s).