



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

5/16/2017

Susie Andruss
Zoning Info, Inc.
(405) 525-2998

RE: Records Search for Orangewood and Knott, Grove Blvd., Garden Grove
CA

Dear Susie Andruss:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

A handwritten signature in black ink, appearing to read 'Brad Spell', written in a cursive style.

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
B.O.B. DENTAL LAB INC
7052 ORANGEWOOD St # 3**

Date Issued	Date Cleared	Code #	Violation Description
09/13/2011	09/13/2011	CFC 605.3	Keep 30" clear in front of elec. panel
09/13/2011	09/13/2011	CFC 901.6	Service and tag Fire Extinguishers.
09/28/2009	10/12/2009	CFC 3003.5.1	Secure compressed gas cylinders.
09/28/2009	10/12/2009	CFC 605.1	Provide/ replace electrical
09/28/2009	10/12/2009	CFC 901.6	Service and tag Fire Extinguishers.
09/28/2009	10/12/2009	CFC 906.1	Provide extinguisher(s)

**Violation List for
FIRST CARE INDUSTRIES/ HEALTHPOINT
7052 ORANGEWOOD Ave 6**

Date Issued	Date Cleared	Code #	Violation Description
05/08/2008	07/07/2008	CFC 901.6	Service and tag Fire Extinguishers.

**Violation List for
TEKNOPRINT, INC.
11542 KNOTT St 8 & 9**

Date Issued	Date Cleared	Code #	Violation Description
04/17/2017	04/17/2017	CFC 901.6	Service and tag Fire Extinguishers.
04/01/2017	04/17/2017	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor

**Violation List for
ARGOS HOME SYSTEMS
11542 KNOTT St 5**

Date Issued	Date Cleared	Code #	Violation Description
03/19/2009	08/27/2009	CFC 901.6	Service and tag Fire Extinguishers.
03/19/2009	08/27/2009	CFC 901.6	Service and tag Fire Extinguishers.

**Violation List for
IN-TRANSIT DESIGN INC
11542 KNOTT St 6**

Date Issued	Date Cleared	Code #	Violation Description
04/17/2017	04/17/2017	CFC 901.6	Service and tag Fire Extinguishers.
04/04/2011	05/19/2011		Get extinguisher for storage room.
04/04/2011	04/18/2011	CFC 904.11.6	Service auto-extinguishing system semi-annually.
04/04/2011	05/19/2011	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
04/04/2011	05/19/2011	CFC 1011.2	Provide illuminated exit sign(s).

**Violation List for
Earth Construction & Mining
11542 KNOTT St 10**

Date Issued	Date Cleared	Code #	Violation Description
04/06/2009	04/14/2009	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
04/06/2009	04/14/2009	CFC 901.6	Service and tag Fire Extinguishers.
02/27/2008	04/08/2008	CFC 906.1	Provide extinguisher(s)

**Violation List for
INDUCTOR SUPPLY, INC.
11542 KNOTT St 3**

Date Issued	Date Cleared	Code #	Violation Description
04/17/2017	04/17/2017	CFC 904.11.6	Service auto-extinguishing system semi-annually.
04/17/2017	04/17/2017	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor

**Violation List for
ROGER INDUSTRY
11552 KNOTT St Unit 5**

Date Issued	Date Cleared	Code #	Violation Description
01/10/2017	00/00/00	CFC 1010.1.1	Repair rear door exit. Hardware is unable to be opened
01/10/2017	00/00/00	CFC 605.5	Discontinue extension cables and linking power strips
08/10/2012	08/31/2012	CFC 605.6	Discontinue use of extension cords.
04/14/2008	05/21/2008		Remove beds / washer/ shower
04/14/2008	05/21/2008		Place containers in blammable cabinets.
04/14/2008	05/21/2008		Door shall remain unlocked during business hours - signs.
04/14/2008	05/21/2008		Replace deadbolt on back door.
04/14/2008	05/21/2008		Place exit over door in back - 3 doors
04/14/2008	05/21/2008	CFC 605.1	Provide/ replace electrical
06/09/2003	06/23/2003	105.1	Obtain fire permit for 2 55 gal drums alcohol / will downsize to 35 ga

**Violation List for
TERMINEX
11552 KNOTT St 8 & 9**

Date Issued	Date Cleared	Code #	Violation Description
08/27/2015	08/27/2015	CFC 901.6	Service and tag Fire Extinguishers.

**Violation List for
SIND
11562 KNOTT St # 6**

Date Issued	Date Cleared	Code #	Violation Description
04/09/2014	06/02/2014	CFC 901.6	Service and tag Fire Extinguishers.
04/09/2014	06/02/2014	CFC 906.1	Provide extinguisher(s)

**Violation List for
OMANA GROUP INC
11562 KNOTT St 5**

Date Issued	Date Cleared	Code #	Violation Description
03/26/2007	04/16/2007	CFC 1001.5.	Service and tag Fire Extinguishers.

**Violation List for
LINDALE PRINTING
11562 KNOTT St 10**

Date Issued	Date Cleared	Code #	Violation Description
04/06/2006	06/29/2006	CFC 1001.5.	Service and tag Fire Extinguishers.

**Violation List for
SOA Sales Office Accessories INC.
11562 KNOTT St 8**

Date Issued	Date Cleared	Code #	Violation Description
04/09/2014	06/02/2014	CFC 901.6	Service and tag Fire Extinguishers.

**Violation List for
BEST LAUNDRY
11562 KNOTT St 15/16**

Date Issued	Date Cleared	Code #	Violation Description
07/15/2009	07/30/2009		18" clearance around water heater.
07/15/2009	07/30/2009		Repair hole in front office, assembly area, wash side, water heater, v
07/15/2009	07/30/2009	CFC 1011.2	Provide illuminated exit sign(s).
07/15/2009	07/30/2009	CFC 1028.3	Remove exit obstruction
03/31/2006	05/24/2006		Housecleaning - clean up excessive lint build-up on equip.
03/31/2006	05/24/2006		Repair broken hi pressure valve piping on boiler. Replace missing se
03/31/2006	05/24/2006		Provide current business license.
03/31/2006	05/24/2006	CFC 8506	Discontinue use of extension cords.- provide permanent wiring to ma

**Violation List for
SYBATEK
11602 KNOTT St 6**

Date Issued	Date Cleared	Code #	Violation Description
01/23/2017	02/06/2017	CFC 901.6	Service and tag Fire Extinguishers.
01/23/2017	02/06/2017	CFC 605.1	Provide/ replace electrical

**Violation List for
MATRIXTEK
11602 KNOTT St 5**

Date Issued	Date Cleared	Code #	Violation Description
04/21/2011	05/10/2011	CFC 901.6	Service and tag Fire Extinguishers.
04/21/2011	04/10/2011	CFC 906.1	Provide extinguisher(s)

Violation List for
AMERICAN SHIELD PRIVATE
11602 KNOTT St D

Date Issued	Date Cleared	Code #	Violation Description
04/21/2011	05/19/2011	CFC 901.6	Service and tag Fire Extinguishers.

**Violation List for
VISITING ANGELS
11602 KNOTT St 7**

Date Issued	Date Cleared	Code #	Violation Description
05/12/2007	05/14/2007	CFC 1001.5.	Service and tag Fire Extinguishers.
00/00/00	05/26/2005	1002.1	Provide 1 extinguisher 2A10BC

**Violation List for
FOCUS MEDIA GROUP
11612 KNOTT St 2**

Date Issued	Date Cleared	Code #	Violation Description
11/20/2014	12/10/2014	CFC 105.3.5	POST BUSINESS LICENSE.
11/20/2014	12/10/2014	CFC 901.6	Service and tag Fire Extinguishers.
07/13/2007	07/26/2007	CFC 1001.5.	Service and tag Fire Extinguishers.

**Violation List for
KHALI VAPORS
11612 KNOTT St 16**

Date Issued	Date Cleared	Code #	Violation Description
02/26/2008	04/23/2008	CFC 1011.2	Provide illuminated exit sign(s).

**Violation List for
IMPERIUM-VINYL WINDOWS & DOORS
11612 KNOTT St 3 & 4**

Date Issued	Date Cleared	Code #	Violation Description
11/20/2014	12/04/2014	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
11/20/2014	12/04/2014	CFC 1028.3	Remove exit obstruction

**Violation List for
RSA CONSULTING
11642 KNOTT St 14-16**

Date Issued	Date Cleared	Code #	Violation Description
08/17/2011	08/24/2011	CFC 901.6	Service and tag Fire Extinguishers.
08/31/2009	02/23/2010	CFC 901.6	Service and tag Fire Extinguishers.
09/20/2004	11/04/2004	1002.1	Provide one extinguisher - 2A10BC

**Violation List for
HYPNOBABIES (Suite 2 & 3)
11642 KNOTT St # 3**

Date Issued	Date Cleared	Code #	Violation Description
10/06/2014	12/05/2014	CFC 901.6	Service and tag Fire Extinguishers.

**Violation List for
ORANGE COUNTY HEAT PRESS
11642 KNOTT St 13**

Date Issued	Date Cleared	Code #	Violation Description
10/05/2005	10/21/2005	CFC 1001.5.	Service and tag Fire Extinguishers.
10/05/1005	10/21/2005	1002.1	Provide 1 extinguisher

**Violation List for
EMSL ANALYTICAL INC / LA TESTING
11652 KNOTT St F5**

Date Issued	Date Cleared	Code #	Violation Description
06/09/2014	10/21/2014	CFC 605.3	Keep 30" clear in front of elec. panel
06/09/2014	10/21/2014	HSC 25505(a)	Failure to submit a Business Emergency Plan.
01/31/2013	01/31/2013		No violations , Need to resubmit 1/31/2013
01/13/2011	02/22/2011		EXTENTION-TAPE DOWN REAR EXIT
01/13/2011	02/22/2011		AA - LAB - ACID ROOM LABEL
01/13/2011	02/22/2011	CFC 3003.5.1	Secure compressed gas cylinders.
01/13/2011	02/22/2011	CFC 2701.5.1	Complete Haz Mat Disclosure packet
01/13/2011	02/22/2011	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
01/13/2011	02/22/2011	CFC 901.6	Service and tag Fire Extinguishers.
01/13/2011	02/22/2011	CFC 906.1	Provide extinguisher(s)
01/13/2011	03/07/2011	CFC 2703.5	Provide Haz Mat placard

**Violation List for
LA TESTING
11652 KNOTT St 5**

Date Issued	Date Cleared	Code #	Violation Description
12/08/2013	01/08/2014	CFC 901.6	Service and tag Fire Extinguishers.