



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

6/6/17

Rhonda Cain
American Zoning Services
(405) 406-9605

RE: Records Search for 11931 Harbor Blvd., Garden Grove CA

Dear Rhonda Cain:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Brad Spell', written in a cursive style.

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
RESIDENCE INN ANAHEIM (MANDATORY)
11931 HARBOR Blvd**

Date Issued	Date Cleared	Code #	Violation Description
02/21/2017	00/00/00	CFC 5003.5	Update NFPA 704 Placards and separate any incompatible material
02/21/2017	00/00/00	CFC 904.11.6	Service auto-extinguishing system semi-annually.
02/21/2017	00/00/00	CFC 605.1	Provide/ replace electrical
02/21/2017	00/00/00	CFC 506.1	Provide outside Knox Box
02/21/2017	00/00/00	CFC 1006.1	Provide and maintain approved emergency lighting.
02/21/2017	03/28/2017	CFC 901.3	Provide maintenance records for alarm and smoke control. Panel is
02/21/2017	00/00/00	CFC 605.6	Discontinue use of extension cords.
02/21/2017	00/00/00	CFC 903	Sprinkler head in the laundry room needs to be lowered.
04/18/2016	04/18/2016	CFC 50	Provide either a cabinet or a water-proof shelter for the chlorine cherr
04/18/2016	04/18/2016	CFC 1004.3	Post maximum occupancy load sign
03/30/2016	04/18/2016	CFC 1028.3	Remove exit obstruction
03/30/2016	04/18/2016	CFC 1008.1.1	Provide approved panic hardware
03/30/2016	04/18/2016	CFC ARTICL	PLACARDING AND SIGNS
03/30/2016	04/18/2016	CFC 903	Provide paper for FACP printer.
03/30/2016	04/18/2016	CFC 903	Fire Alarm Panel is in trouble status. Panel cleared and updated con
02/29/2016	04/18/2016	CFC 315.2.1	Lower storage
02/29/2016	03/30/2016	CFC 1006.1	Provide and maintain approved emergency lighting.
02/29/2016	03/30/2016	CFC 1008.1.1	Provide approved panic hardware
02/29/2016	03/30/2016	CFC 605.1	Provide/ replace electrical
02/29/2016	03/30/2016	CFC 901.6	Service and tag Fire Extinguishers.
09/23/2014	03/03/2015	CFC 1011.2	Provide illuminated exit sign(s).
09/23/2014	03/03/2015	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
09/26/2013	12/21/2013	CFC 906.1	Provide extinguisher(s)
09/26/2013	12/21/2013	CFC 2701.5.	Complete Haz Mat Disclosure packet
09/26/2013	12/21/2013		PROVIDE ANNUAL SPRINKLER AND ALARM DOCUMENTATION
09/26/2013	12/21/2013		CLEAN 4TH FL STORAGE AND ORGANIZE CHEMICALS
09/26/2013	12/21/2013		REPAIR WALL - 5TH FL LINEN
09/26/2013	12/21/2013		ADJUST FIRE DOORS TO CLOSE AND LATCH COMPLETELY: 8'
09/26/2013	12/21/2013	CFC 901.6	Service and tag Fire Extinguishers.
08/24/2011	11/09/2011		Provide annual sprinkler & alarm documentation on site
08/24/2011	11/09/2011		Complete NFPA 704 placards (generator & poolroom) w/appropriate
08/24/2011	11/09/2011		Complete fire door to close and latch completely; 4th left elevator; 3r

**Violation List for
RESIDENCE INN ANAHEIM (MANDATORY)
11931 HARBOR Blvd**

Date Issued	Date Cleared	Code #	Violation Description
08/24/2011	11/09/2011		Remove all propane from 6th fl. storage
08/24/2011	11/09/2011	CFC 3003.5.1	Secure compressed gas cylinders.
08/24/2011	11/09/2011	CFC 2701.5.1	Complete Haz Mat Disclosure packet
08/24/2011	11/09/2011	CFC 904.11.1	Service auto-extinguishing system semi-annually.
08/24/2011	11/09/2011	CFC 1011.2	Provide illuminated exit sign(s).
08/19/2010	09/16/2010		REPAIR FIRE DOOR TO CLOSE AND LATCH COMPLETELY: 5TH
08/19/2010	09/16/2010		PATCH HOLE IN WALL: OUTSIDE WALL BY STAIRS BY LAUNDRY
08/27/2009	10/29/2009		Repair laundry venting.
08/27/2009	10/29/2009		North side 1st floor housekeeping.
08/27/2009	10/29/2009		Adjust fire door 5th fl; 2nd fl - magnet nonfunctioning.
02/23/2009	02/23/2009	CFC 2701.5.1	Complete Haz Mat Disclosure packet
10/10/2008	01/08/2009		Rearrange storage 7th fl, 4th fl.
10/10/2008	01/08/2009		Fire door : 8th fl elevator 3; 5th floor; 5th fl elevators; 3rd fl elevator 3
10/10/2008	02/11/2009	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
09/27/2007	11/16/2007		Provide for outside standpipe caps. (on order)
09/27/2007	11/20/2007		Repair magnet fire door 2nd fl. SS.
09/27/2007	11/16/2007		Remove storage wnd fl electrical.
09/27/2007	11/20/2007		Adjust fire door to close and latch: 8th fl. SS, 6th SS, 5th SS & eleva
09/27/2007	11/20/2007	CFC 8506	Discontinue use of extension cords.- office
09/27/2007	11/12/2007	CFC 1005.2.1	Service auto-extinguishing system semi-annually.- kitchen
09/27/2007	11/16/2007	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
09/12/2006	09/26/2006		Fire doors - 4th floor by stair 2, 5th floor right elevator fire door.
09/12/2006	09/26/2006		Repair exit sign midway 6th floor.
09/12/2006	09/26/2006		Remove treadmill from electrical room (1st floor)
09/07/2005	10/13/2005		Check all emergency doors on all floors.
09/07/2005	10/13/2005		Fire control panel- trouble
09/07/2005	10/13/2005		6th floor - elevator, storage
09/07/2005	10/13/2005		7th floor hse cor & elevator door
09/07/2005	10/13/2005		8th floor - elevator doors, SE stairway
10/04/2004	10/04/2004	1103	Provide housekeeping to generator room.
10/04/2004	12/15/2004	1001.5	Replace painted sprinkler head in elect. room - 6th floor.
10/04/2004	12/15/2004		Post meeting room for 201 when room is not divided & 118 when ro

**Violation List for
RESIDENCE INN ANAHEIM (MANDATORY)
11931 HARBOR Blvd**

Date Issued	Date Cleared	Code #	Violation Description
10/04/2004	12/15/2004	1111	Provide electromagnet door holders to fire doors wedged open. -1st
10/04/2004	12/15/2004	1207.3	Provide panic hardware on exit "door" from trash area & gate toward
10/04/2004	12/15/2004	1212	Provide exit signs for exit path from west stairwell. Signs shall be illu
10/04/2004	10/04/2004	8500	remove propane storage from main electrical room.
10/04/2004	12/15/2004	1001.5	Provide copies of annual test for fire alarm system, fire pump & gener
10/04/2004	12/15/2004	1005.2.8	Service auto-extinguishing system semi annually.- Kitchen
00/00/00	08/22/2012		Haz pac complete 2/20/2009 inspection complete Capt. Janovick