



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

6/13/15

Sara Spinuzzi
Orange County Coastkeeper
(714) 850-1965

RE: Records Search for 7061 Patterson Drive., Garden Grove CA

Dear Sara Spinuzzi:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

A handwritten signature in black ink, appearing to read 'Brad Spell', written in a cursive style.

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
COASTLINE METAL FINISHING CORPORATION
7061 PATTERSON Dr**

Date Issued	Date Cleared	Code #	Violation Description
05/03/2006	05/17/2006	CFC 8506	Discontinue use of extension cords.- planning, plating console
09/17/2015	09/17/2015	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
04/16/2013	05/21/2013	CFC 315.2.1	Lower storage
04/11/2007	04/16/2007	CFC 7401.6.	Secure cylinders.
05/01/2008	05/01/2008		Provide documentation of annual sprinkler and alarm service.
04/16/2013	05/21/2013	CFC 503.4	Remove obstructions to fire apparatus access
04/15/2010	06/16/2010	CFC 901.6	Service and tag Fire Extinguishers.
04/15/2010	06/16/2010	CFC 605.6	Discontinue use of extension cords.
04/15/2010	06/16/2010	CFC 3003.5.:	Secure compressed gas cylinders.
04/15/2010	06/16/2010		Annual sprinkler paperwork shall be maintained on site.
04/18/2011	04/27/2011		Verbal: 5 year cert. due in Oct. Patch hole in wall behind inspection.
04/12/2012	05/23/2012	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.