



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

6/29/17

Christine Nguyen
Partner ESI

RE: Records Search for 12032 Harbor Blvd., and 12542 Chapman Ave.,
Garden Grove CA

Dear Christine Nguyen:

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
COCO'S (#231)
12032 HARBOR Blvd**

Date Issued	Date Cleared	Code #	Violation Description
10/24/2016	11/07/2016	1006.3	In the event of power supply failure, an emergency electrical system
10/24/2016	12/19/2016	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
10/24/2016	11/07/2016	CFC 901.6	Service and tag Fire Extinguishers.
06/15/2015	07/06/2015	CFC 904.11.1	Service auto-extinguishing system semi-annually.
06/19/2012	07/01/2012	CFC 904.11.1	Service auto-extinguishing system semi-annually.
06/19/2012	07/01/2012	CFC 901.6	Service and tag Fire Extinguishers.
06/19/2012	07/01/2012	CFC 904.11.1	Clean filters, ducts, hood above cooking surface
04/01/2009	05/13/2009		Replace cap on hood system.
04/01/2009	05/13/2009	CFC 505.1	Provide address visible from the street
04/16/2008	05/07/2008	CFC 315.2.1	Lower storage
04/16/2008	05/07/2008	CFC 605.3	Keep 30" clear in front of elec. panel
04/16/2008	05/07/2008	CFC 1011.2	Provide illuminated exit sign(s).
04/16/2008	05/07/2008	CFC 1028.3	Remove exit obstruction
04/14/2008	05/07/2008	CFC 505.1	Provide address visible from the street
04/12/2007	05/03/2007	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
04/12/2007	05/03/2007	CFC 1001.5.	Service and tag Fire Extinguishers.
05/04/2004	06/02/2004		Remove tape from circuit breaker
05/04/2004	06/02/2004	1212.4	Provided illuminated exit signs - west & south

**Violation List for
ROCKY'S MARKET
12542 CHAPMAN Ave**

Date Issued	Date Cleared	Code #	Violation Description
03/01/2011	03/01/2011	CFC 901.6	Service and tag Fire Extinguishers.