

## INCIDENT REPORT

## INCIDENT

Fire Department: Garden Grove Fire Department  
Incident Number: G1709288  
Exposure Number: 00  
Multi-Agency IC#: 17-088060 A1723824  
Incident Date: 08/12/17  
Dispatch Time: 09:03:08  
Arrival Time: 09:09:01  
Controlled Time:  
Ending Time: 11:05:54  
First-In Company: GE7  
District: G2721  
Incident Type: Self-propelled motor home or recreational vehicle  
Mutual Aid: None  
Method of Alarm: E911  
Type of Weather:  
Air Temperature: 68  
Address, CSZ: PRO TIRE & AUTO SERVICE, 10602  
Census Tract:  
Fire Haz Sev Zone: Medium

## RESOURCES &amp; CASUALTIES

Actions Taken 1: Extinguishment by fire service personnel  
Actions Taken 2:  
Actions Taken 3:  
#Apparatus Resp Engine: 3  
#Apparatus Resp Trk: 1  
#Apparatus Resp Med: 0  
#Apparatus Resp Oth: 2  
Fire Svcs Injury: 0  
Fire Svcs Fatal: 0  
Non-FS Injury: 0  
Non-FS Fatal: 0

## PROPERTY &amp; STUDIES

Property Losses: \$100,000  
Content Losses: \$5,000  
Property Value:  
Contents Value:  
Insurance Co:  
Building Ins:  
Mixed Prop Use:  
Property Use: Service station, gas station  
Detector

## INCIDENT REPORT

Hazmat Rel: None  
Critical Inc:  
Special Studies:

## COMMENTS

\*\*\*\*\* GE7 \*\*\*\*\*

## VEHICLE FIRE

GROVE ENGINE 7 RESPONDED TO 10602 WESTMINSTER AVENUE ON A SINGLE ENGINE RESPONSE TO FIND A MOTORHOME VEHICLE FULLY INVOLVED WITH HEAVY EXTENSION TO THE ADJACENT GAS PUMPS, OVERHEAD STRUCTURE AND A ADJOINING VEHICLE. GE7 UPGRADED TO A STRUCTURE ASSIGNMENT AND BEGAN FIRE ATTACK. IMMEDIATELY UPON ARRIVAL THE GAS TO TO FUEL PUMPS AND PROPANE TANKS WAS SHUT DOWN AS WELL AS ELECTRICAL TO THE OVERHEAD STRUCTURE. FUEL SPILLED FROM THE GAS PUMPS AS WELL AS GAS FROM THE ON BOARD PROPANE TANKS FROM THE MOTORHOME REQUIRED THE USE OF FOAM TO ASSIST IN EXTINGUISHMENT.

THE OWNER OF THE MOTORHOME WHERE THE FIRE STARTED HAD LEFT THE SCENE PRIOR TO GE7 ARRIVAL. THE PROPERTY WAS SECURED AND RELEASED BACK TO THE PROPERTY OWNER. GARDEN GROVE BUILDING DEPARTMENT ARRIVED AND INVESTIGATED THE PROPERTY STABILITY.

CAPTAIN RIETH