## INCIDENT REPORT

\_\_\_\_\_\_ INCIDENT Fire Department: Garden Grove Fire Department
Incident Number: G1702962
Exposure Number: 00
Multi-Agency IC#: A1707296 17-027907
Incident Date: 03/10/17 03/10/17 15:47:22 15:54:29 Incident Date: Dispatch Time: Arrival Time: Controlled Time: 17:45:00 Ending Time: 18:09:08 First-In Company: GE6 District G2325 Incident Type:
Mutual Aid: Natural vegetation fire, other None Mutual Aid: Method of Alarm: Telephone Type of Weather: Air Temperature 73 Address, CSZ: 12081 BANGOR ST Census Tract: Fire Haz Sev Zone: Medium \_\_\_\_\_\_ RESOURCES & CASUALTIES \_\_\_\_\_\_ Actions Taken 1: Extinguishment by fire service personnel Actions Taken 2: Actions Taken 3: #Apparatus Resp Engine: 3 #Apparatus Resp Trk: 1 #Apparatus Resp Med: 1
#Apparatus Resp Oth: 1 Fire Svs Fatal: 0
Non-FS Injury: 0
Non-FS Fatal: 0 Non-FS Fatal: PROPERTY & STUDIES Property Losses: \$5,000 Content Losses: \$1,000 Property Value: Contents Value: Insurance Co:

Detector

Building Ins:

Mixed Prop Use:

Property Use: 1 or 2 family dwelling

## INCIDENT REPORT

На	Z	m	a	t		R	e	1	:	
Cr	4	+	4	_	_	1		т	~	_

None

Critical Inc: Special Studies:

·

## EMERGENCY MEDICAL SERVICE

\_\_\_\_\_\_

Number of Patients:

Billing Care:

Status:

Transported to:

# Patients Trans - Fire:

# Patients Trans - Amb:

COMMENTS

\*\*\*\* GE6 \*\*\*\*

Fire- Veg/tree fire

GE6 responded to the above address for a structure fire. Upon arrival GE6 had heavy smoke showing from the backyard of the residents. GE6 investigated and found multiple trees and vegetation on fire with high voltage electrical lines down. E6 went into the attack mode and started extinguishing the fire with 150ft pre-connect hose line. Fire did extend to one side of the detached garage but we were able to get an aggressive attack to keep it from spreading any further. Ge1 assumed command and assigned GE6 fire attack and GT1 vent group. Command was transferred over to GB1 once he arrived on scene. GB1 assigned GE3 to Div D. and expedited SCE for the wires down. Fire was knocked down/controlled with hose lines in place and kept to the area of origin. SCE arrived on scene shortly after and cut power to the entire block. No injuries to the homeowner or firefighters.

Cause of the fire appears to be electrical do to the high voltage lines that where found down at the scene. Homeowner did state he heard a loud explosion/pop prior to the fire. The property was released back to the homeowner and fire personnel went back into service.

Captain Trenholm