

**Violation List for
THOMASVILLE
12622 MONARCH St Ste A**

Date Issued	Date Cleared	Code #	Violation Description
10/14/2013	10/22/2013	CFC 605.3	Keep 30" clear in front of elec. panel
05/25/2011	06/01/2011	CFC 1011.2	Provide illuminated exit sign(s).