



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

11/09/17

Ann Beabout
PZR

RE: Records Search: 12021 Harbor Blvd., Garden Grove CA

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
WYNDHAM ANAHEIM GARDEN GROVE (MANDATORY)
12021 HARBOR Blvd**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|--|
| 02/27/2015 | 07/29/2015 | | Repair holes in walls: 7th floor staff elevator room and 8th floor C sta |
| 01/16/2014 | 01/30/2014 | | REPLACE MISSING SPRINKLER ESCUTCHEON: OUTSIDE JR'S |
| 01/16/2014 | 01/30/2014 | CFC 605.1 | Provide/ replace electrical |
| 01/16/2014 | 01/30/2014 | CFC 315.2.1 | Lower storage |
| 09/30/2013 | 10/03/2013 | | Final notice E6 called in for fire alarm system down for 2 months. Fa |
| 08/20/2013 | 09/30/2013 | CFC 2701.5.: | Complete Haz Mat Disclosure packet |
| 01/29/2013 | 02/12/2013 | | REDUCE STROAGE IN MECHANICAL - MEZZANINE. |
| 01/29/2013 | 02/12/2013 | | ADJUST FIRE DOORS TO CLOSE AND LATCH COMPLETELY: L |
| 01/29/2013 | 02/12/2013 | CFC 3003.5.: | Secure compressed gas cylinders. |
| 01/29/2013 | 02/12/2013 | CFC 605.3 | Keep 30" clear in front of elec. panel |
| 01/29/2013 | 02/12/2013 | CFC 605.6 | Discontinue use of extension cords. |
| 05/02/2012 | 05/02/2012 | | Remove temp ceiling in storage on 9th by 901 - obstructs sprinkler. |
| 05/02/2012 | 05/02/2012 | CFC 605.3 | Keep 30" clear in front of elec. panel |
| 11/01/2010 | 11/22/2010 | | Repair fire door to close and latch; |
| 11/01/2010 | 11/22/2010 | | Repair holes in wall: outer roof access door (stairways) |
| 11/01/2010 | 11/22/2010 | | Reduce storage in roof elevator |
| 11/01/2010 | 11/22/2010 | | Verbal: 5 year cert. due in March for sprinkler system |
| 11/01/2010 | 11/22/2010 | Title 19 Sec. | Hang extinguisher(s) 3.5'-5' from floor |
| 11/01/2010 | 11/22/2010 | CFC 901.6 | Service and tag Fire Extinguishers. |
| 11/01/2010 | 11/22/2010 | CFC 906.1 | Provide extinguisher(s) |
| 11/01/2010 | 11/22/2010 | CFC 1011.2 | Provide illuminated exit sign(s). |
| 11/01/2010 | 11/22/2010 | CFC 605.3 | Keep 30" clear in front of elec. panel |
| 11/04/2009 | 12/14/2009 | | Replace fire rated door in shell vacations snack room, X3 csl kitchen |
| 11/04/2009 | 12/14/2009 | | Replace sprinkler escutcheon 3rd floor elevator lobby, kitchen X2, fc |
| 11/04/2009 | 12/14/2009 | | Repair elevator doors (fire doors) to close and latch completely, 9th |
| 11/04/2009 | 12/14/2009 | CFC 605.1 | Provide/ replace electrical |
| 10/09/2008 | 10/23/2008 | | Provide faceplate for junction box by exit / electrical room 1st fl. |
| 10/09/2008 | 10/23/2008 | | Replace ceiling tile in banquet storage |
| 10/09/2008 | 10/23/2008 | | Repair hole in wall mechanical eletrical 2nd fl (behind door) |
| 10/09/2008 | 10/23/2008 | | Repair fire door to close and latch- 9th fl (left), 1st fl (left) |
| 10/09/2008 | 10/23/2008 | | Provide annual fire pump test. |
| 10/09/2008 | 10/23/2008 | CFC 3003.5.: | Secure compressed gas cylinders. |

**Violation List for
WYNDHAM ANAHEIM GARDEN GROVE (MANDATORY)
12021 HARBOR Blvd**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|--|
| 10/30/2007 | 11/13/2007 | | Replace 2 telephone handsets in fire control room. |
| 10/30/2007 | 11/13/2007 | | Fix fire door to close and latch completely.- 2nd fl (left) |
| 10/30/2007 | 11/13/2007 | | Loosen standpipe caps on roof (stair 4- right) |
| 10/30/2007 | 11/13/2007 | CFC 8506 | Discontinue use of extension cords. |
| 10/30/2007 | 11/13/2007 | CFC 1001.5. | Service and tag Fire Extinguishers. |
| 11/02/2006 | 11/02/2006 | | Remove bench obstructing far right Mazzanine elevator (abatefd wh |
| 11/02/2006 | 11/16/2006 | | Repair fir doors to close and latch completely: 9th left ad right; 8th le |
| 11/02/2006 | 11/16/2006 | | Remove combustible storage on roof. |
| 11/02/2006 | 11/16/2006 | Title 19 Sec. | Hang extinguisher(s) 3.5'-5' from floor |
| 11/02/2006 | 11/16/2006 | CFC 1001.5. | Service and tag Fire Extinguishers.- elevator mech room- roof; fire c |
| 10/18/2005 | 11/16/2005 | | Remove combustible storage from electrics room in 4,5 & 7 and fron |
| 10/18/2005 | 11/16/2005 | | Maintain caps on roof standpipes handtight. |
| 10/18/2005 | 11/16/2005 | | Repair pull station on 3rd floor in front of elevators - also pull station |
| 10/18/2005 | 11/16/2005 | | Clear chairs in electrical room 2nd floor. |
| 10/18/2005 | 11/16/2005 | 8509.2 | Keep 30" clear for access in front of electrical panel - Mechanical Rc |
| 01/27/2005 | 04/11/2005 | | If possible, program elevators to by-pass mezzanine during after- hc |
| 01/27/2005 | 04/11/2005 | CFC appdx F | Re-program (if not already done) elevator recall to 2nd floor. |
| 01/27/2005 | 04/11/2005 | 1207.3 & 100 | Provide panic hardware on wrought iron gate on mezzanine stairs. |
| 09/21/2004 | 01/27/2005 | 1111.2 | Provide magnetic door holders to 1st floor service area & elect. room |
| 09/21/2004 | 01/27/2005 | 1111.1 | Provide fire stop to sprinkler pipe in electric & linen rooms on all gue |
| 10/27/2003 | 09/20/2004 | 1103 & 1203 | Post sign stating "No Storage" in west banquet storage corridor. |
| 10/27/2003 | 09/20/2004 | 1001.5 | Mail or fax reports (when completed) on quarterly sprinkler tests, an |
| 10/27/2003 | 09/20/2004 | 8509 | Remove & maintain clear all doors to electric rooms to be free of car |
| 10/27/2003 | 09/20/2004 | 1103 | Provide housekeeping to 2nd floor store room. |
| 10/25/2003 | 12/02/2003 | HSC 25503.5 | Failure to establish / implement a Business Emergency Plan. |
| 02/06/2003 | 02/06/2003 | 1203.7 | Maintain all exits clear during all conferences in banquet rooms. |
| 11/14/2002 | 09/20/2004 | 8001.7 | PROVIDE A 704 PLACARD ON THE POOL PUMP ROOM |
| 11/14/2002 | 09/20/2004 | 8001 | STORE AND MAINTAIN POOL ACID 20' AWAY FROM CHLORINE |
| 11/14/2002 | 09/20/2004 | 1103 | REMOVE COMBUSTIBLE STORAGE FROM ELECTRIC ROOMS / |
| 11/14/2002 | 09/20/2004 | 8509 | MAINTAIN CLEARANCE AROUND ELECTRIC PANELS |
| 11/14/2002 | 09/20/2004 | 1112 | APPLY FIRE CAULK IN THE ELECTRIC ROOMS IN FLOOR AND I |
| 11/14/2002 | 09/20/2004 | 1002 | MOVE FIRE EXTINGUISHER IN PENTHOUSE |

**Violation List for
WYNDHAM ANAHEIM GARDEN GROVE (MANDATORY)
12021 HARBOR Blvd**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|--|
| 11/14/2002 | 09/20/2004 | 1001.5 | REPAIR FIRE ALARM SYSTEM; SYSTEM SHOWS ALARM |