



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

1/8/17

Ronald Willut

RE: Records Search 10700 W. Katella Ave., Garden Grove CA

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
SOTELO TIRE SERVICE
10700 KATELLA Ave # A**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|--|
| 05/05/2015 | 05/12/2015 | CFC 605.3 | Keep 30" clear in front of elec. panel |
| 05/05/2015 | 05/12/2015 | CFC 105.3.5 | POST FIRE DEPARTMENT PERMIT. 0051-MATTHEW NEWBERF |
| 05/05/2015 | 05/12/2015 | CFC 1028.3 | Remove exit obstruction |
| 06/03/2014 | 05/12/2015 | HSC 25505(e) | Failure to submit a Business Emergency Plan. |
| 06/03/2014 | 05/12/2015 | CFC 901.6 | Service and tag Fire Extinguishers. |
| 01/26/2012 | 05/10/2012 | | Secondary containment for used oil drum. |
| 01/26/2012 | 05/10/2012 | | Do not use camp stove indoors |
| 02/01/2010 | 03/01/2010 | | Provide secondary conatainment. |
| 02/01/2010 | 03/01/2010 | CFC 605.1 | Provide/ replace electrical |
| 02/01/2010 | 03/01/2010 | CFC 901.6 | Service and tag Fire Extinguishers. |
| 01/18/2009 | 01/28/2009 | | Portable stove use outside |
| 01/18/2009 | 01/28/2009 | | General housekeeping |
| 01/18/2009 | 01/28/2009 | | Post fire dept permit |
| 01/18/2009 | 01/28/2009 | Title 19 Sec. | Hang extinguisher(s) 3.5'-5' from floor |
| 02/11/2008 | 02/20/2008 | CFC 901.6 | Service and tag Fire Extinguishers. |
| 01/19/2006 | 02/14/2006 | CFC 1001.5. | Service and tag Fire Extinguishers. |
| 01/19/2006 | 02/28/2006 | 901.44 | Provide address visible from the street. |
| 02/24/2003 | 03/17/2003 | 1001.5.1 | hang extinguisher(s) on bracket, maximum 5 feet from floor |
| 02/24/2003 | 03/17/2003 | 1001.5.1 | Service and tag extinguisher(s) |

**Violation List for
DYNASTY MOVERS
10700 KATELLA Ave H**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|---|
| 04/04/2013 | 12/02/2014 | Title 19 Sec. | Hang extinguisher(s) 3.5'-5' from floor |
| 04/04/2013 | 12/02/2014 | CFC 906.1 | Provide extinguisher(s) |
| 07/27/2012 | 02/22/2012 | CFC 315.2.1 | Lower storage |
| 07/27/2011 | 02/23/2012 | CFC 605.1 | Provide/ replace electrical |
| 07/27/2011 | 02/22/2012 | CFC 901.6 | Service and tag Fire Extinguishers. |
| 01/24/2007 | 02/08/2007 | 1103.3.3.2 | Lower stroage 2' from ceiling. |
| 01/24/2007 | 02/08/2007 | Title 19 Sec. | Hang extinguisher(s) 3.5'-5' from floor |
| 01/24/2007 | 02/08/2007 | CFC 1001.5. | Service and tag Fire Extinguishers. |

**Violation List for
G AND G AUTO PERFORMANCE
10700 KATELLA Ave C**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|--|
| 08/30/2013 | 10/17/2013 | CFC 2701.5. | Complete Haz Mat Disclosure packet |
| 02/05/2013 | 02/05/2013 | CFC 605.6 | Discontinue use of extension cords. |
| 01/29/2010 | 02/18/2010 | | Replace battery in smoke detector in office. |
| 01/29/2010 | 02/18/2010 | CFC 2701.5. | Complete Haz Mat Disclosure packet |
| 01/29/2010 | 02/18/2010 | CFC 605.6 | Discontinue use of extension cords. |
| 01/29/2010 | 02/18/2010 | CFC 901.6 | Service and tag Fire Extinguishers. |

**Violation List for
PC AUTO CUSTOM
10700 KATELLA Ave # B**

| Date Issued | Date Cleared | Code # | Violation Description |
|--------------------|---------------------|---------------|-------------------------------------|
| 05/21/2014 | 11/20/2014 | CFC 105.3.5 | POST FIRE DEPARTMENT PERMIT. |
| 04/14/2011 | 04/28/2011 | CFC 1011.2 | Provide illuminated exit sign(s). |
| 04/14/2011 | 04/28/2011 | CFC 1008.1.1 | Remove exit door/hardware |
| 03/09/2010 | 04/05/2010 | CFC 901.6 | Service and tag Fire Extinguishers. |
