



CITY OF GARDEN GROVE
FIRE DEPARTMENT

Tel: (714) 741-5600
Fax: (714) 741-5640

1/8/17

Brittney
Partner ESI

RE: Records Search 12271 Monarch St., Garden Grove CA

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks or clean-up, as that information is provided through the County of Orange Health Dept.

Sincerely,

A handwritten signature in black ink, appearing to read 'Brad Spell', written over a white background.

Brad Spell
Fire Captain/Senior Fire Protection Specialist

**Violation List for
ITW POLYMERS SEALANTS NORTH AMERICA
12271 MONARCH St**

Date Issued	Date Cleared	Code #	Violation Description
10/28/2015	11/10/2015	NFPA 25	Replace 4 escutcheon cups for sprinkler heads in the office.
10/28/2015	11/10/2015	CFC 315.2.1	Lower storage
10/28/2015	11/10/2015	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
05/28/2013	11/10/2015		CHEMICAL INVENTORY REQUIRES UPDATE
03/31/2011	05/03/2011		Maintain annual sprinkler documentation on site.
03/31/2011	05/03/2011		Patch hole near electrical socket in maintenance mangers office.
03/31/2011	05/03/2011	CFC 605.6	Discontinue use of extension cords.