

**Violation List for
PACIFIC WEST FOAM INDUSTRIES
10511 GARDEN GROVE Blvd**

Date Issued	Date Cleared	Code #	Violation Description
03/21/2005	03/28/2005	1002.1	Provide 1 extinguisher - 2A10BC
03/21/2005	03/28/2005	CFC 1001.5:	Service and tag Fire Extinguishers.

**Violation List for
CALI BEAUTY SUPPLY
10531 GARDEN GROVE Blvd**

Date Issued	Date Cleared	Code #	Violation Description
11/23/2015	00/00/00	CFC 503.4	Remove obstructions to fire apparatus access
11/23/2015	00/00/00	CFC 1028.3	Remove exit obstruction
11/23/2015	00/00/00	CFC 1008.1.1	Remove exit door/hardware
11/23/2015	00/00/00	CFC 1011.2	Provide illuminated exit sign(s).
11/23/2015	00/00/00	CFC 2703.5	Provide Haz Mat placard
11/23/2015	00/00/00	CFC 1008.1.1	Provide approved panic hardware
11/23/2015	00/00/00	CFC 3404.3.1	Provide approved flammable liquid cabinet
11/23/2015	00/00/00	CFC ARTICL	PLACARDING AND SIGNS
11/23/2015	00/00/00	CFC 8003.1.1	LIQUIDS AND SPILL CONTROL
11/23/2015	00/00/00	HSC 25504(t	Emergency Response Plan is inadequate.
11/23/2015	00/00/00	CFC 2701.5.1	Complete Haz Mat Disclosure packet
11/23/2015	00/00/00	HSC 25509	Chemical inventory is incomplete / requires update.
07/21/2011	07/26/2011	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
07/21/2011	07/26/2011	CFC 901.6	Service and tag Fire Extinguishers.

**Violation List for
CALI BEAUTY SUPPLY
10561 GARDEN GROVE Blvd**

Date Issued	Date Cleared	Code #	Violation Description
06/19/2017	06/21/2017	CFC ARTICL	PLACARDING AND SIGNS
06/19/2017	06/21/2017	CFC 605.6	Discontinue use of extension cords.
11/23/2015	00/00/00	HSC 25509	Chemical inventory is incomplete / requires update.
11/23/2015	00/00/00	CFC 503.4	Remove obstructions to fire apparatus access
11/23/2015	00/00/00	CFC 1028.3	Remove exit obstruction
11/23/2015	00/00/00	CFC 1008.1.1	Remove exit door/hardware
11/23/2015	00/00/00	CFC 1011.2	Provide illuminated exit sign(s).
11/23/2015	00/00/00	CFC 2703.5	Provide Haz Mat placard
11/23/2015	00/00/00	CFC 3404.3.1	Provide approved safety container(s) for flammable liquids.
11/23/2015	00/00/00	CFC 1008.1.1	Provide approved panic hardware
11/23/2015	00/00/00	CFC 3404.3.4	Provide approved flammable liquid cabinet
11/23/2015	00/00/00	CFC ARTICL	PLACARDING AND SIGNS
11/23/2015	00/00/00	CFC 8003.1.1	LIQUIDS AND SPILL CONTROL
11/23/2015	00/00/00	CFC 2701.5.1	Complete Haz Mat Disclosure packet
11/23/2015	00/00/00	HSC 25509	Chemical inventory is incomplete / requires update.
08/30/2011	09/13/2011		Replace ceiling tiles.
08/30/2011	09/13/2011		Must keep the aisles clear (housekeeping).
08/30/2011	09/13/2011	CFC 605.3	Keep 30" clear in front of elec. panel
08/30/2011	09/13/2011	CFC 1028.3	Remove exit obstruction
08/30/2011	09/13/2011	CFC 901.6	Service and tag Fire Extinguishers.
09/01/2009	10/08/2009		Remove shower, stove, washer/dryer, bed.
09/01/2009	10/08/2009	CFC 2701.5.1	Complete Haz Mat Disclosure packet
09/01/2009	10/08/2009		Provide outside Knox Box
09/01/2009	10/08/2009	CFC 505.1	Provide address visible from the street
07/14/2009	10/08/2009	CFC 605.6	Discontinue use of extension cords.
07/01/2009	10/08/2009	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
07/01/2009	10/08/2009	CFC 901.6	Service and tag Fire Extinguishers.



Form: FPB Fire & Life Safety Survey

Garden Grove Fire Department

Occupancy: **CALI BEAUTY SUPPLY**
Occupancy ID: **7436**
Address: **10531 GARDEN GROVE BLVD**
GARDEN GROVE CA 92843

Inspection Type: **Complaint**

Inspection Date: **10/2/2017**

Time In: **10:00**

Authorized Date: **Not Authorized** By:

By: [REDACTED]

Time Out: **10:49**

Next Inspection Date: **04/01/2019 Biennial Inspection**

Inspection Topics:

Fire Access/Signs

Provide outside Knox Box for structure, Knox Override for vehicle gates, and/or Knox Padlock for rapid entry. CFC 506.1
Fire fighter rapid entry access. Application may be obtained from the Garden Grove Fire Department Fire Prevention Bureau.

Status:

Notes:

Provide hazardous materials warning signs, NFPA 704. CFC 5003.5

Clearly identify hazard levels inside a building for emergency personnel.

Status: Correction Required

Notes: Immediately placard the front and rear of the building with NFPA 704 placards identifying the most hazardous material onsite.

Post maximum occupant load sign. CFC 1004.3

Required for any occupant load greater than 50 to ensure proper life safety features are in place.

Status:

Notes:

Provided address numbers clearly visible from the street. CFC 505.1

Address numbers are critical to help emergency personnel find people who may need some sort of aid. The numbers must contrast with their background for greatest visibility.

Status:

Notes:

Remove obstructions and provide access in fire lanes. A minimum of 20 feet in width and 13 feet 6 inches in height of clearance is required. CFC 503.4

Large fire apparatus need room to effectively maneuver in the event of an emergency.

Status: Correction Required

Notes: Rear roll up door is block of inventory

Exits

Repair or maintain exit doors and hardware to operate properly. CFC 1010.1.10

Well maintained exit doors and panic hardware provide safe and easy egress from a building.

Status:

Notes:

Remove obstructions from exits, aisles, corridors, and stairways. CFC 1003.6

Clear exit access is essential to prevent panic or accidental falling of occupants during evacuation.

Status: Correction Required

Notes: Aisles throughout warehouse are being used for storage

Remove unapproved locks, latches, chains, bolts, or bars from exit doors. CFC 1010.1.9

Exit doors must be free to open without delay in the event of an emergency.

Status:

Notes:

Provide illuminated exit sign(s)/emergency lights. CFC 1013.1

Clearly identified exits enable persons to quickly and safely leave the building in an emergency.

Status:

Notes:

Housekeeping

Post valid City of Garden Grove business license.

Required license and permit(s) to conduct business.

Status: Correction Required

Notes:

Post valid Garden Grove Fire Department permit(s). CFC 105.3.5

Fire department permit(s) are required to ensure business are in compliance with applicable fire codes, and all occupants are not operating in an undue hazardous environment.

Status: Correction Required

Notes: Obtain fire permits for high pile storage and hazmat use and storage. Plan shall be submitted by a hazmat storage engineer and reviewed by the Garden Grove Fire Department for approval.

Remove all storage from under stairway. CFC 315.3.2

Storage under stairway may ignite, and prevent escape.

Status:

Notes:

Boiler, mechanical, and electrical panel rooms shall not be used for storage. CFC 315.3

Combustible materials in these equipment rooms often get put too close to sources of heat and a fire will likely result.

Status:

Notes:

Remove combustible decorative materials. CFC 807.3

Combustible decorative materials add to fuel load which will increase fire hazard.

Status: Correction Required

Notes: House keeping through out building

Electrical

Discontinue use of extension cords in lieu of permanent wiring. CFC 605.5

Temporary wire does not afford the durability, safety, and protection from shock or fire that is found in the construction of an enclosed electrical system.

Status:

Notes:

Maintain at least 30 inches clearance in front of electrical panel. CFC 605.3

Access to electrical panels must be cleared to allow for general inspection and emergency shutdown.

Status:

Notes:

Each outlet box shall have a cover face plate, receptacle, power strip. CFC 605.1

Covers protect people from being shocked by exposed wires, prevent spread of electrical current, and heat and flame during short circuits.

Status:

Notes:

Discontinue use of non-approved multi-plug adapters. CFC 605.4

Multi-plug adapters invite the overuse of the circuit that can result in overheating and a fire.

Status:

Notes:

Maintain wiring in good condition and protect from damage. CFC 605.5

Worn or broken wires and plugs present a fire hazard and risk of electrical short circuit that can result in a fire. Use cord protectors to prevent cord fraying/damage where susceptible to damage.

Status:

Notes:

Fire Protection Equipment & Systems

Mount extinguishers where readily available, not more than 5 feet above floor. CFC 906.9

Extinguishers must be easily within reach of all occupants, but not where they will be subject to damage.

Status:

Notes:

Post signs indicating location where extinguishers are not readily visible. CFC 906.6

Where extinguishers are not clearly visible, signs help occupants find the equipment in a hurry.

Status:

Notes:

Service and tag portable fire extinguisher(s). CFC 901.6

Annual maintenance will provide for properly charge and serviced extinguishing devices, and assure proper operation if needed to fight a small fire.

Status:

Notes:

Provide a minimum of (X) portable fire extinguisher of (X) minimum rating. CFC 906.1

Extinguishers provided need to be appropriate to the type of hazard. Travel distance shall not exceed 75 feet to any portable fire extinguisher.

Status:

Notes:

Provide annual fire protection alarm maintenance record. CFC 901.6

Perform maintenance of fire alarm systems and their components by a licensed alarm maintenance company.

Status:

Notes:

Service auto-extinguishing system(s) semi-annually. CFC 904.12.6.2

Hood systems to be serviced by a technician certified in UL300 auto-extinguishing system.

Status:

Notes:

Clean filters, ducts, hood above cooking surface. CFC 609.3.3

Hood extinguishing systems shall be of UL 300 standard, and shall be cleaned and maintained every six months.

Status:

Notes:

Five (5) year certification on sprinkler/standpipe system. CCR Title 19, Section 904

Service sprinkler and components by a C16-licensed company.

Status: 1.0 Pass

Notes: 10547 Nutwood
Nader Kashfian 818-652-5568

Storage

Lower storage to be at least 18 inches away from sprinkler heads or 2 feet away from the ceiling in non-sprinklered buildings. CFC 315.3.1

Maintaining an adequate distance away from sprinklers allows for spray patterns from sprinkler heads to have maximum reach through designed patterns.

Status:

Notes:

Secure compressed gas cylinders. CFC 5303.5.3

Prevents knocking over of compressed gas cylinders, and causing catastrophic damage to the cylinder resulting in injury to nearby occupants.

Status:

Notes:

Hazardous Materials - Safety Precautions

Storage of flammable liquids in excess of 10 gallons shall be in an approved cabinet. CFC 5704.3.4.4

In the event of a fire, flammable liquids can readily accelerate its spread. Confining the stored liquids to secure cabinets will limit this fire exposure.

Status: Correction Required

Notes: Flammable liquids throughout the whole building.

Provide approved safety container(s) for flammable liquids. CFC 5704.3.1

Safety containers for flammable or combustible liquids are designed to prevent flammable fumes from escaping or accidental spills.

Status: Correction Required

Notes: Provide proper storage and containment.

Provide hazardous materials disclosure to County of Orange Hazardous Materials Section through eSubmit website.

An inventory of hazardous materials may be utilized by public safety personnel, including the fire department to determine hazards on site.

Status: Correction Required

Notes: Provide updated hazmat inventory list to both OC Health and Garden Grove Fire Department.

Additional

Additional Code Violations

Additional items that are not listed in this form.

Status: Correction Required

Notes: Storage requirement Per CFC 2016 - S-1 Occupancy

Chapter 32 High pile storage storage

Chapter 50 Hazardous materials- General provisions

Chapter 57 Flammable & combustible liquids

Hazardous materials are not stored or contained properly per CFC 2016 Chapters 50 & 57.

IMMEDIATELY CEASE IN ALL NON-PERMITTED MANUFACTURING PROCESSES

Additional Time Spent on Inspection:

Category

Start Date / Time

End Date / Time

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Summary:

Overall Result: Final Notice

An immediate correction was identified or failure to comply and correct identified violations in the prescribed time.

Failure to correct may result in an administrative citation.

Inspector Notes: Numerous current California Fire Code violations have been observed. The business owner/representative is required to take immediate action to mitigate the existing violations and cease in the non-permitted manufacturing operations. A Notice and Order of Building Official is currently in place and will become enforceable September 30, 2017 at 1700. A fire department re-inspection will occur on Monday, October 2, 2017.

Inspector:

Name: Nguyen, Don
Rank: Senior Fire Protection Specialist
Work Phone(s): 714-711-5633
Email(s): dnguyen@ci.garden-grove.ca.us, dnguyen@ci.garden-grove.ca.us
Nguyen, Don




Signed on: 09/27/2017 14:02

Signature

Date

Representative Signature:

Signature of: Loc duong on 09/27/2017 14:03



Signature

Date



Garden Grove Fire Department

Occupancy: **CALI BEAUTY SUPPLY**
Occupancy ID: **7798**
Address: **10561 GARDEN GROVE BLVD**
GARDEN GROVE CA 92843

Form: FPB Fire & Life Safety Survey

Inspection Type: **Reinspection**

Inspection Date: **9/26/2017**

Time In: **11:25**

Authorized Date: **Not Author**

Time Out: **11:25**

By: **[REDACTED]**

Next Inspection Date: **10/01/2018 Annual**

Inspection Topics:

Fire Access/Signs

Provide outside Knox Box for structure, Knox Override for vehicle gates, and/or Knox Padlock for rapid entry. CFC 506.1
Fire fighter rapid entry access. Application may be obtained from the Garden Grove Fire Department Fire Prevention Bureau.

Status:

Notes:

Provide hazardous materials warning signs, NFPA 704. CFC 5003.5

Clearly identify hazard levels inside a building for emergency personnel.

Status: Correction Required

Notes: Immediately placard the Front and rear of the building with NFPA 704 placards identifying the most hazardous material onsite.

Post maximum occupant load sign. CFC 1004.3

Required for any occupant load greater than 50 to ensure proper life safety features are in place.

Status:

Notes:

Provided address numbers clearly visible from the street. CFC 505.1

Address numbers are critical to help emergency personnel find people who may need some sort of aid. The numbers must contrast with their background for greatest visibility.

Status:

Notes:

Remove obstructions and provide access in fire lanes. A minimum of 20 feet in width and 13 feet 6 inches in height of clearance is required. CFC 503.4

Large fire apparatus need room to effectively maneuver in the event of an emergency.

Status: Correction Required

Notes: Rear roll up door is block of inventory

Exits

Repair or maintain exit doors and hardware to operate properly. CFC 1010.1.10

Well maintained exit doors and panic hardware provide safe and easy egress from a building.

Status:

Notes:

Remove obstructions from exits, aisles, corridors, and stairways. CFC 1003.6

Clear exit access is essential to prevent panic or accidental falling of occupants during evacuation.

Status: Correction Required

Notes: Aisles though out warehouse

Remove unapproved locks, latches, chains, bolts, or bars from exit doors. CFC 1010.1.9

Exit doors must be free to open without delay in the event of an emergency.

Status:

Notes:

Provide illuminated exit sign(s)/emergency lights. CFC 1013.1

Clearly identified exits enable persons to quickly and safely leave the building in an emergency.

Status:

Notes:

Housekeeping

Post valid City of Garden Grove business license.

Required license and permit(s) to conduct business.

Status: Correction Required

Notes: Imediatly cease in the non-permitted manufacturing operations.

Post valid Garden Grove Fire Department permit(s). CFC 105.3.5

Fire department permit(s) are required to ensure business are in compliance with applicable fire codes, and all occupants are not operating in an undue hazardous environment.

Status:

Notes:

Remove all storage from under stairway. CFC 315.3.2

Storage under stairway may ignite, and prevent escape.

Status: Correction Required

Notes: Storage under stairs

Boiler, mechanical, and electrical panel rooms shall not be used for storage. CFC 315.3

Combustible materials in these equipment rooms often get put too close to sources of heat and a fire will likely result.

Status:

Notes:

Remove combustible decorative materials. CFC 807.3

Combustible decorative materials add to fuel load which will increase fire hazard.

Status: Correction Required

Notes: House keeping

Electrical

Discontinue use of extension cords in lieu of permanent wiring. CFC 605.5

Temporary wire does not afford the durability, safety, and protection from shock or fire that is found in the construction of an enclosed electrical system.

Status:

Notes:

Maintain at least 30 inches clearance in front of electrical panel. CFC 605.3

Access to electrical panels must be cleared to allow for general inspection and emergency shutdown.

Status:

Notes:

Each outlet box shall have a cover face plate, receptacle, power strip. CFC 605.1

Covers protect people from being shocked by exposed wires, prevent spread of electrical current, and heat and flame during short circuits.

Status:

Notes:

Discontinue use of non-approved multi-plug adapters. CFC 605.4

Multi-plug adapters invite the overuse of the circuit that can result in overheating and a fire.

Status:

Notes:

Maintain wiring in good condition and protect from damage. CFC 605.5

Worn or broken wires and plugs present a fire hazard and risk of electrical short circuit that can result in a fire. Use cord protectors to prevent cord fraying/damage where susceptible to damage.

Status:

Notes:

Fire Protection Equipment & Systems

Mount extinguishers where readily available, not more than 5 feet above floor. CFC 906.9

Extinguishers must be easily within reach of all occupants, but not where they will be subject to damage.

Status:

Notes:

Post signs indicating location where extinguishers are not readily visible. CFC 906.6

Where extinguishers are not clearly visible, signs help occupants find the equipment in a hurry.

Status:

Notes:

Service and tag portable fire extinguisher(s). CFC 901.6

Annual maintenance will provide for properly charge and serviced extinguishing devices, and assure proper operation if needed to fight a small fire.

Status:

Notes:

Provide a minimum of (X) portable fire extinguisher of (X) minimum rating. CFC 906.1

Extinguishers provided need to be appropriate to the type of hazard. Travel distance shall not exceed 75 feet to any portable fire extinguisher.

Status:

Notes:

Provide annual fire protection alarm maintenance record. CFC 901.6

Perform maintenance of fire alarm systems and their components by a licensed alarm maintenance company.

Status:

Notes:

Service auto-extinguishing system(s) semi-annually. CFC 904.12.6.2

Hood systems to be serviced by a technician certified in UL300 auto-extinguishing system.

Status:

Notes:

Clean filters, ducts, hood above cooking surface. CFC 609.3.3

Hood extinguishing systems shall be of UL 300 standard, and shall be cleaned and maintained every six months.

Status:

Notes:

Five (5) year certification on sprinkler/standpipe system. CCR Title 19, Section 904

Service sprinkler and components by a C16-licensed company.

Status:

Notes:

Storage

Lower storage to be at least 18 inches away from sprinkler heads or 2 feet away from the ceiling in non-sprinklered buildings. CFC 315.3.1

Maintaining an adequate distance away from sprinklers allows for spray patterns from sprinkler heads to have maximum reach through designed patterns.

Status:

Notes:

Secure compressed gas cylinders. CFC 5303.5.3

Prevents knocking over of compressed gas cylinders, and causing catastrophic damage to the cylinder resulting in injury to nearby occupants.

Status:

Notes:

Hazardous Materials - Safety Precautions

Storage of flammable liquids in excess of 10 gallons shall be in an approved cabinet. CFC 5704.3.4.4

In the event of a fire, flammable liquids can readily accelerate its spread. Confining the stored liquids to secure cabinets will limit this fire exposure.

Status: Correction Required

Notes: Flammable liquid stored through out business.

Provide approved safety container(s) for flammable liquids. CFC 5704.3.1

Safety containers for flammable or combustible liquids are designed to prevent flammable fumes from escaping or accidental spills.

Status: Correction Required

Notes: Provide proper storage and containment.

Provide hazardous materials disclosure to County of Orange Hazardous Materials Section through eSubmit website.

An inventory of hazardous materials may be utilized by public safety personnel, including the fire department to determine hazards on site.

Status: Correction Required

Notes: Provide updated hazmat inventory list to both OC Health and Garden Grove Fire Department.

Additional

Additional Code Violations

Additional items that are not listed in this form.

Status: Correction Required

Notes: CFC 2016- F-1 Occupancy
Chapter 22 Combustible dust production operations
Chapter 24 Flammable finishes

Immediately cease in the un-permitted manufacturing operations.

Additional Time Spent on Inspection:

Category

Start Date / Time

End Date / Time

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 0 minutes

Total Time: 0 minutes