



Garden Grove Fire Department
 Station: **G07**
 Shifts Or Platoon: **B**

Location: 13861 BROOKHURST ST Garden Grove CA 92640	Incident Type: 111 - Building fire
Lat/Long: N 33° 45' 39.67" W 117° 57' 23.21"	FDID: 30035 Incident #: 2018-802014 Exposure ID: 30192381 Exposure #: 0 Incident Date: 02/15/2018 Dispatch Run #: F180460116
Location Type: 1 - Street address Map Page: 828E1	

Report Completed by:	McGovern Jr. , Terry A	ID: 5537	Date: 03/02/2018
Report Reviewed by:	Nguyen , Thanh	ID: 0167	Date: 03/19/2018
Report Printed by:	Guardi, Lisa	ID: 4433	Date: 6/7/2018 Time: 15:04

Structure Type: Enclosed building	Property Use: 519 - Food and beverage sales, grocery store
Automatic Extinguishment System Present: <input checked="" type="checkbox"/>	Detectors Present: <input checked="" type="checkbox"/> Cause of Ignition: Unintentional
Aid Given or Received: None	Primary action taken: 11 - Extinguishment by fire service personnel
Losses	Pre-Incident Values
Property:	Property: Civilian Injuries: 0 Fire Service Injuries: 0
Contents:	Contents: Civilian Fatalities: 0 Fire Service Fatalities: 0
Total:	Total: Total Casualties: 0 Total Fire Service Casualties: 0
Total # of apparatus on call: 7	Total # of personnel on call: 17

Narrative from dispatch:

[02/15/18 11:32:26 M033] OCEAN BLUE REQUESTED AND ADVISED TO CALL GB1'S CELL
 [02/15/18 11:32:04 M033] GB1 COMMAND DISSOLVED
 [02/15/18 11:26:22 M063] GB1 REQ OCEAN BLUE
 [02/15/18 11:22:43 M033] DUPE 150
 [02/15/18 11:07:46 KOPS] OCFA HAS CLOSED CALL 18-018546
 [02/15/18 11:04:41 M085] PER OC HEALTH, WCB W/ ETA
 [02/15/18 11:02:14 M085] GB1 REQ ETA FOR OC HEALTH
 [02/15/18 11:00:41 M085] GB1 REQ ETA FROM OC HEALTH
 [02/15/18 10:54:45 M085] CB1 CLEAR
 [02/15/18 10:48:54 M085] GB1 OS GA1
 [02/15/18 10:36:25 M085] GB1 RELEASING GE2
 [02/15/18 10:36:14 M085] GE2 ALSO SHUT DOWN PIV AT THE STREET
 [02/15/18 10:36:01 M085] GE2 HAVE SYSTEM SHUT DOWN ON BRAVO SIDE
 [02/15/18 10:28:50 M085] GB1 ADV 15 MINS ON INC CLOCK, STOP THE CLOCK
 [02/15/18 10:28:38 M085] INCIDENT CLOCK STOPPED: 10:28:38
 [02/15/18 10:28:34 M085] GB1 STOP INC CLOCK
 [02/15/18 10:28:25 M085] INCIDENT CLOCK ACKED: 10:28:25
 [02/15/18 10:28:10 KOPS] INCIDENT CLOCK ELAPSED: 10:28:10
 [02/15/18 10:23:22 M058] OCHEALTH NOTIFIED, WCB FOR DETAILS
 [02/15/18 10:23:12 M085] GT1 TO HANDLE WATER VAC
 [02/15/18 10:21:27 M085] GB1 RELEASE CE64
 [02/15/18 10:20:53 M085] GE3 PRIMARY ALL CLEAR FOR WHOLE BLDG
 [02/15/18 10:20:21 M085] HT42 SALVAGE
 [02/15/18 10:20:09 M085] GDIV1 CONTACTED OC HEALTH TO RESPOND
 [02/15/18 10:19:47 M058] GDIV1 REQ OC HEALTH
 [02/15/18 10:19:20 M085] GE3 NO ATTIC EXTENTION
 [02/15/18 10:18:54 M085] GE3 DELTA SIDE CLEAR, WORKING ON BRAVO SIDE
 [02/15/18 10:18:28 M085] GT1 NO ACTIVE FIRE, WILL ASSIST W/ INTERIOR
 [02/15/18 10:16:22 M085] CB1 SAFETY
 [02/15/18 10:16:02 M085] GE3 ALSO CHECKING OTHER ADJACENT STRUCTURE UNITS
 [02/15/18 10:15:46 M085] GB1 GE3 TO EVACUATE MARKET
 [02/15/18 10:15:16 M085] GE3 LIGHT SMOKE IN GROCERY STORE
 [02/15/18 10:14:26 M085] GE2 SPRINKLERS SHUT DOWN AT THE STREET
 [02/15/18 10:14:03 M085] HT42 W/4
 [02/15/18 10:13:52 M085] INCIDENT CLOCK ACKED: 10:13:52

[02/15/18 10:13:44 M085] GB1 ADV 15 MIN ON INC CLOCK
 [02/15/18 10:13:10 KOPS] INCIDENT CLOCK ELAPSED: 10:13:10
 [02/15/18 10:13:02 M085] GT1 NO EXTENTION ON ROOF AT THIS TIME
 [02/15/18 10:11:28 M085] GE7 COMPLETE KNOCK DOWN
 [02/15/18 10:11:21 M085] GE7 PRIMARY AND SECONDARY SEARCHES ALL CLEAR
 [02/15/18 10:11:08 M085] GE7 INTERIOR
 [02/15/18 10:10:57 M085] GE7 INTERIOR
 [02/15/18 10:10:45 M085] GT1 HANDLING UTILITIES
 [02/15/18 10:10:23 M085] GT1 VENTILATION
 [02/15/18 10:10:11 M085] GE3 EXPOSURE
 [02/15/18 10:09:53 M085] GE3 ASSIST GE7
 [02/15/18 10:09:17 M085] GE7 REQ SPRINKLER SYSTEM SHUT DOWN
 [02/15/18 10:08:41 M085] GE7 INTERIOR ALL CLEAR, KNOCK DOWN, DOES NOT APPEAR TO BE EXTENTION ABOVE
 [02/15/18 10:08:12 M085] GB1 COMMAND POST WILL BE ON THE ALPHA SIDE OF THE STRUCTURE, OFF WESTMINSTER TO THE SOUTH, IN PLOT
 [02/15/18 10:07:28 M085] GE2 WF SYSTEM
 [02/15/18 10:07:08 M085] GE2 WF SYSTEM
 [02/15/18 10:06:57 M058] GM1 GLF1
 [02/15/18 10:06:57 M058] GT1 GLF1
 [02/15/18 10:06:52 M085] GE7 INTERIOR, EVAC, EXTENTIONS
 [02/15/18 10:06:33 M085] GB1 IC
 [02/15/18 10:04:57 M085] GE7 WORKING KITCHEN FIRE, HELD IN CHECK WITH SPRINKLER SYSTEM, SHOULD BE GOOD WITH 1ST ASSIGNMENT
 [02/15/18 10:02:56 M085] GE7 FIRE ATTACK
 [02/15/18 10:02:48 KOPS] CALL TRANSFER TO OCFA SUCCEEDED
 [02/15/18 10:02:47 M085] GE7 UPGRADE TO WORKING STRUCTURE FIRE
 [02/15/18 10:02:42 M063] Situation Updated: 167 (STRUCTURE FIRE-WORKING)
 [02/15/18 10:02:26 M085] GE7 SINGLE STORY COMMERCIAL STRIP, SMOKE SHOWING FROM VENTS
 [02/15/18 09:58:10 M063] INCIDENT CLOCK STARTED: 09:58:10 FOR 15 MINUTES
 [02/15/18 09:58:10 M063] Situation Updated: 165 (STRUCTURE FIRE-COMMERCIAL)

NARRATIVE (2)

Narrative Title: n/a

Narrative Author: Fellner, Steve

Narrative Date: 02/15/2018 20:19:44

Narrative Apparatus ID: GE3

Narrative:

GE3 SECURED WATER FOR GE7. GE3 WAS REASSIGNED TO EXPOSURE GROUP WITH OBJECTIVE TO EVACUATE AND CHECK FOR EXTENSION. GE3 ASSISSTED WITH WATER REMOVAL.

NARRATIVE (3)**Narrative Title:** n/a**Narrative Author:** Waldschmidt, David**Narrative Date:** 02/15/2018 20:24:57**Narrative Apparatus ID:** GE7**Narrative:**

Structure fire commercial

ge7 and first alarm units responded to single story commercial strip for structure fire. Upon arrival ge7 found pressurized smoke coming from roof vents. ge7 initiated fire attack with preconnect through front door. Fire located in kitchen area of business being held in check by sprinkler system. primary and secondary searches performed while 1st alarm units assisted with checking for extension, ventilation, salvage, and overhaul. After investigation fire appears to have started in or around oven area in kitchen with main body of fire initially found coming from that location. Fire cause is listed as undetermined and appears to be accidental in nature. Owner representative (Huy Trieu Manager telephone number 626 945 5739) on scene advised that sprinkler system shut down to property due to fused sprinkler heads in kitchen area with recommended 24 hour fire watch posted until sprinkler system evaluated by qualified technician. Additionally manager advised electrical shut down at panels servicing building. release and assumption of real property after emergency response signed by owner representative Huy Trieu. oc health dept on scene contact (laura albright 714 824 1686) and ocean blue contact(Daniel Gaeta (562 533 4986) for clean up. Area scanned via thermal imager prior to clear time with no evidence of any heat signatures

additional info:

Pham Thuy--- property owner 714 530 7353

Sun Belt Store Inc.

13861 Brookhurst

858 495 4900

Captain Waldschmidt

NARRATIVE (4)**Narrative Title:** n/a**Narrative Author:** Page, Anthony**Narrative Date:** 02/15/2018 17:13:34**Narrative Apparatus ID:** GM1**Narrative:**

RESPONDED AS LIGHT FORCE AND WAS ASSIGNED TO VENTILATION GROUP. ASSISTED GT1 WITH POSITIVE PRESSURE VENTILATION, OVERHAUL AND WATER REMOVAL FROM BUILDING.

FF/PM PAGE

NARRATIVE (5)**Narrative Title:** Fire**Narrative Author:** Truhill, Justin**Narrative Date:** 02/16/2018 06:52:48**Narrative Apparatus ID:** GB1**Narrative:**

Arrived on scene, located the CP and assumed Brookhurst IC. The following assignments were made.

GE7 Interior

GE3 Water supply/Exposure Group

GE2 Systems

GLF1 Ventilation Group

HT42 Assigned to assist Interior with salvage needs

CB1 Safety

NARRATIVE (6)**Narrative Title:** Structure Fire**Narrative Author:** Niblo, Fred**Narrative Date:** 02/19/2018 17:34:00**Narrative Apparatus ID:** GE2**Narrative:**

GE2 was assigned Systems. We shut down the sprinkler system at the PIV on Westminster and shut down the riser & drained the system on the Bravo side of the building. IC was notified when we completed our assignment.

Capt. Niblo

NARRATIVE (7)**Narrative Title:** fire**Narrative Author:** Gabbard, James**Narrative Date:** 02/20/2018 16:35:06**Narrative Apparatus ID:** GT1**Narrative:**

GT1 assigned vent group. Investigated duct system and any fire extension on roof. Completed overhaul ops via water removal.

NARRATIVE (8)**Narrative Title:** n/a**Narrative Author:** McGovern Jr., Terry**Narrative Date:** 03/02/2018 08:00:27**Narrative Apparatus ID:** GDIV1**Narrative:**

asisted GB1 as IC

APPARATUS			
Unit	GB1	Unit	GDIV1
Type:	Chief officer car	Type:	Chief officer car
Use:	Suppression	Use:	Suppression
Response Mode:	()	Response Mode:	()
# of People	1	# of People	1
Alarm	02 /15/2018 09:55:30	Alarm	02 /15/2018 09:55:30
Dispatched	02 /15/2018 09:56:30	Dispatched	02 /15/2018 09:56:30
Enroute	02 /15/2018 09:59:48	Enroute	02 /15/2018 10:05:14
Arrived	02 /15/2018 10:05:42	Arrived	02 /15/2018 10:08:57
Cancelled	-- /--/-- --:--:--	Cancelled	-- /--/-- --:--:--
Cleared Scene	02 /15/2018 12:02:44	Cleared Scene	02 /15/2018 11:00:00
In Quarters	02 /15/2018 12:02:44	In Quarters	-- /--/-- --:--:--
In Service	02 /15/2018 12:02:44	In Service	-- /--/-- --:--:--
Unit	GE2	Unit	GE3
Type:	Engine	Type:	Engine
Use:	Suppression	Use:	Suppression
Response Mode:	()	Response Mode:	()
# of People	4	# of People	3
Alarm	02 /15/2018 09:55:30	Alarm	02 /15/2018 09:55:30
Dispatched	02 /15/2018 09:56:30	Dispatched	02 /15/2018 09:56:30
Enroute	02 /15/2018 09:59:20	Enroute	02 /15/2018 10:00:27
Arrived	02 /15/2018 10:05:55	Arrived	02 /15/2018 10:05:44
Cancelled	-- /--/-- --:--:--	Cancelled	-- /--/-- --:--:--
Cleared Scene	02 /15/2018 10:47:41	Cleared Scene	02 /15/2018 11:41:52
In Quarters	-- /--/-- --:--:--	In Quarters	02 /15/2018 11:41:52
In Service	02 /15/2018 10:47:41	In Service	02 /15/2018 11:41:52
Unit	GE7	Unit	GM1
Type:	Engine	Type:	ALS unit
Use:	Suppression	Use:	EMS
Response Mode:	()	Response Mode:	()
# of People	3	# of People	2
Alarm	02 /15/2018 09:55:30	Alarm	02 /15/2018 09:55:30
Dispatched	02 /15/2018 09:56:30	Dispatched	02 /15/2018 09:56:30
Enroute	02 /15/2018 09:57:45	Enroute	02 /15/2018 10:00:34
Arrived	02 /15/2018 10:02:11	Arrived	02 /15/2018 10:06:13
Cancelled	-- /--/-- --:--:--	Cancelled	-- /--/-- --:--:--
Cleared Scene	02 /15/2018 12:30:00	Cleared Scene	02 /15/2018 11:49:15
In Quarters	-- /--/-- --:--:--	In Quarters	-- /--/-- --:--:--
In Service	-- /--/-- --:--:--	In Service	02 /15/2018 11:49:15
Unit	GT1		
Type:	Truck or aerial		
Use:	Suppression		
Response Mode:	()		
# of People	3		
Alarm	02 /15/2018 09:55:30		
Dispatched	02 /15/2018 09:56:30		
Enroute	02 /15/2018 10:00:02		
Arrived	02 /15/2018 10:06:11		
Cancelled	-- /--/-- --:--:--		
Cleared Scene	02 /15/2018 11:30:00		
In Quarters	-- /--/-- --:--:--		
In Service	-- /--/-- --:--:--		
Number Of People not on apparatus: 0			

FIRE			
Acres Burned	None or Less Than One	Acres Burn From Wildland Form	False
Area Of Fire Origin	Cooking area, kitchen	Heat Source	Undetermined
Item First Ignited	Undetermined	Fire Is Confined To Object Of Origin	
Type Of Material	Undetermined	Cause Of Ignition	Unintentional
Factor Contributing To Ignition	Undetermined		
Human Factors Contributing	None		
Equipment Involved In Ignition Flag	True	Equipment Involved	
Equipment Power Source	Undetermined	Equipment Portability	Stationary

STRUCTURE FIRE			
Structure Type	Enclosed building	Building Status	In normal use
# Of Stories At Above Grade	1	# Of Stories Below Grade	0
Square Feet	50000	Length	
Width		Floor Of Origin	1
Fire Spread	Confined to room of origin		
Minor Damage	0	Significant Damage	0
Heavy Damage	0	Extreme Damage	0
Presence Of Detectors	Present	Type Of Detection System	Undetermined
Detector Power Supply	Undetermined	Detector Operation	Undetermined
Presence OF AES	Present	Type Of AES	

PEOPLE -- PERSON 1			
Telephone Number	8008880444	Involvement	Caller
Name	SSD/#114	Date of Birth	
Address			

CUSTOM FIELDS FORM	
What happened?	We provided fire and rescue service
Fire Incident - What happened?	

PERSONNEL ON CALL			
Name	Personnel Rank	Role(s)	Apparatus
Furuta, Garret M	Firefighter / Paramedic		GM1
McGovern Jr., Terry A	Division Chief		GDIV1
Page, Anthony J	Firefighter / Paramedic		GM1

Member Making Report (Division Chief Terry A McGovern Jr.): _____

Supervisor (Captain Thanh Nguyen): _____