



**CITY OF GARDEN GROVE**  
**FIRE DEPARTMENT**

---

November 6, 2018

Pat Horton  
Armada Analytics

Re: 11848 Valley View St., Garden Grove CA

Dear Pat Horton,

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks and clean-up, as that information is provided through the County of Orange Health Department.

Sincerely,

  
Paul Whittaker

Division Chief of Administration

**Violation List for  
VALLEY VIEW GARDENS  
11848 VALLEY VIEW St**

<b>Date Issued</b>	<b>Date Cleared</b>	<b>Code #</b>	<b>Violation Description</b>
08/11/2003	08/22/2003	1001.5.1	Service automatic fire extinguishing systems semi-annually.
06/17/2004	06/30/2004	1212.4	Provide illuminated exit signs - kitchen.
06/17/2004	06/30/2004	T19 sec.904	5 yr certification on sprinkler / standpipe system.
06/17/2004	06/30/2004		Adjust fire door on north west side of building.
06/27/2013	07/31/2013	CFC 315.2.1	Lower storage
06/27/2013	07/31/2013	CFC 904.11.f	Service auto-extinguishing system semi-annually.
06/27/2013	07/31/2013		MAINTAIN FIRE DOORS TO CLOSE AND LATCH - B, D
06/27/2013	07/31/2013		MAINTAIN ANNUAL SPRINKLER DOCUMENTATION ONSITE
06/05/2008	06/17/2008	CFC 605.1	Provide/ replace electrical
06/05/2008	06/17/2008		Lock extinguisher cabinet in kitchen.
06/17/2009	07/13/2009	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
06/17/2009	07/13/2009	CFC 1004.3	Post maximum occupancy load sign
06/17/2009	07/13/2009	CFC 605.6	Discontinue use of extension cords.
06/17/2009	07/13/2009		Provide sprinkler wrench in spare sprinkler box
06/17/2009	07/13/2009		Clean behind dryers in laundry area of any lint and /or debris.
06/17/2009	06/17/2009		move paint into outside stroage from storage by C3- done while on ε
07/15/2010	08/09/2010	CFC 605.1	Provide/ replace electrical
07/15/2010	08/09/2010		Remove BBQ from telephone room.
07/15/2010	08/09/2010		Provide annual sprinkler and alarm documentation
10/07/2015	10/21/2015	CFC 1011.2	Provide illuminated exit sign(s).

**Violation List for  
VALLEY VIEW GARDENS  
11848 VALLEY VIEW St**

<b>Date Issued</b>	<b>Date Cleared</b>	<b>Code #</b>	<b>Violation Description</b>
10/07/2015	10/21/2015	CFC 1011.2	Provide illuminated exit sign(s).
06/27/2013	07/31/2013		MAINTAIN ANNUAL SPRINKLER DOCUMENTATION ONSITE
06/27/2013	07/31/2013		MAINTAIN FIRE DOORS TO CLOSE AND LATCH - B, D
06/27/2013	07/31/2013	CFC 904.11.6	Service auto-extinguishing system semi-annually.
06/27/2013	07/31/2013	CFC 315.2.1	Lower storage
07/15/2010	08/09/2010		Provide annual sprinkler and alarm documentation
07/15/2010	08/09/2010		Remove BBQ from telephone room.
07/15/2010	08/09/2010	CFC 605.1	Provide/ replace electrical
06/17/2009	06/17/2009		move paint into outside storage from storage by C3- done while on s
06/17/2009	07/13/2009		Clean behind dryers in laundry area of any lint and /or debris.
06/17/2009	07/13/2009		Provide sprinkler wrench in spare sprinkler box
06/17/2009	07/13/2009	CFC 605.6	Discontinue use of extension cords.
06/17/2009	07/13/2009	CFC 1004.3	Post maximum occupancy load sign
06/17/2009	07/13/2009	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
06/05/2008	06/17/2008		Lock extinguisher cabinet in kitchen.
06/05/2008	06/17/2008	CFC 605.1	Provide/ replace electrical
06/17/2004	06/30/2004		Adjust fire door on north west side of building.
06/17/2004	06/30/2004	T19 sec.904	5 yr certification on sprinkler / standpipe system.
06/17/2004	06/30/2004	1212.4	Provide illuminated exit signs - kitchen.
08/11/2003	08/22/2003	1001.5.1	Service automatic fire extinguishing systems semi-annually.