



CITY OF GARDEN GROVE
FIRE DEPARTMENT

February 28, 2019

Re: 9222 Trask Ave., Garden Grove CA

Dear Anonymous,

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks and clean-up, as that information is provided through the County of Orange Health Department.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Paul Whittaker', is positioned above the printed name.

Paul Whittaker

Division Chief of Administration

**Violation List for
OC NISSAN OF GARDEN GROVE
9222 TRASK Ave**

Date Issued	Date Cleared	Code #	Violation Description
07/21/2011	07/28/2011		Close inspection latch on valve upstairs.
07/21/2011	07/28/2011		Discontinue use of space heaters/unplug not in use.
07/21/2011	07/28/2011	CFC 605.3	Keep 30" clear in front of elec. panel
07/21/2011	07/28/2011	CFC 315.2.2	Remove storage under stairway.
07/21/2011	07/28/2011	CFC 901.6	Service and tag Fire Extinguishers.
08/18/2010	09/15/2010		MOVE VEHICLES ON EAST SIDE OF LOT TO ENSURE FIRE ACC
08/18/2010	09/15/2010		KEEP OILY RAGS IN APPROVED CONTAINERS
08/18/2010	09/15/2010		MOVE ITEMS FROM UNDERNEATH STAIRS
08/18/2010	09/15/2010		PATCH HOLES NEAR ROLL UP DOORS
08/18/2010	09/15/2010	CFC 3003.5.1	Secure compressed gas cylinders.
08/18/2010	09/15/2010	CFC 901.6	Service and tag Fire Extinguishers.
08/18/2009	03/10/2010		Move cars from East gate.
08/18/2009	03/10/2010		sprinkler hanger - text manual room.
08/18/2009	03/10/2010		Top floor fire extinguisher cabinet needs repair (sticks)
08/18/2009	03/10/2010		Storage under stair - cleaning closet.
08/18/2009	03/10/2010		Space heater - under desk - remove or timer - all
08/18/2009	03/10/2010		Change lock out - 2nd floor breakroom.
08/18/2009	03/10/2010	CFC 3003.5.1	Secure compressed gas cylinders.
08/18/2009	03/10/2010	CFC 605.1	Provide/ replace electrical
08/18/2009	03/10/2010	CFC 605.3	Keep 30" clear in front of elec. panel
08/18/2009	03/10/2010	Title 19, Sec.	5 yr. certification on sprinkler / standpipe system.
08/18/2009	03/10/2010	CFC 901.6	Service and tag Fire Extinguishers.
08/18/2009	03/10/2010		Label electrical room door.
08/18/2009	03/10/2010	CFC 2703.5	Provide Haz Mat placard
01/13/2009	01/13/2009		HAZMAT PACKET COMPLETED AND UPDATED 01/13/2009 BY R