



**CITY OF GARDEN GROVE**  
**FIRE DEPARTMENT**

---

July 1, 2019

Joanie Phelan

Zoning Info

Re: 7422 Chapman, Garden Grove CA

Dear Joanie Phelan

Enclosed are the records found concerning the history of the above-mentioned site(s), especially as it pertains to fire code violation history, permits, the use, storage, or disposal of hazardous substances, and the installation or removal of underground flammable or combustible liquid storage tanks.

The City of Garden Grove Fire Department has utilized its best efforts to locate the records requested. However, the City makes no representation as to the accuracy of the records or that all records requested were retained or located. The City does not provide records on spills, leaks and clean-up, as that information is provided through the County of Orange Health Department.

Sincerely,

  
Paul Whittaker

Division Chief of Administration

**Violation List for  
EVANS MANUFACTURING INC.  
7422 CHAPMAN Ave**

<b>Date Issued</b>	<b>Date Cleared</b>	<b>Code #</b>	<b>Violation Description</b>
10/06/2015	10/28/2015	CFC 2703.5	Provide Haz Mat placard
02/08/2011	02/24/2011	CFC 605.6	Discontinue use of extension cords.
03/04/2010	03/18/2010		Michelle's office - hole in wall needs patching.
03/04/2010	03/18/2010	CFC 1006.1	Provide and maintain approved emergency lighting.
01/22/2009	02/05/2009	CFC 605.3	Keep 30" clear in front of elec. panel
01/22/2009	02/05/2009	CFC 605.6	Discontinue use of extension cords.
02/14/2008	02/26/2008	CFC 315.2.1	Lower storage
02/14/2008	02/26/2008	CFC 3404.3.4	Provide approved flammable liquid cabinet
02/14/2008	02/26/2008	Title 19 Sec.	Hang extinguisher(s) 3.5'-5' from floor
02/14/2008	02/26/2008	CFC 1006.1	Provide and maintain approved emergency lighting.
01/26/2004	03/02/2004	1001.5	Label PIV to indicate address on placard.
01/26/2004	03/02/2004	1001.5	Log or provide info on log of quarterly fire sprinkler tests.
01/26/2004	03/02/2004	1001.5	Remove or repair aluminum sheets from ceiling deck to maintain sp
01/26/2004	03/02/2004	1203	Remove storage from blocking aisle near weigh station.
03/10/2003	03/31/2003	8104.3	Provide & maintain longitudinal flue spaces on rack storage clear by
03/10/2003	03/31/2003	1001.5.1	Remove aluminum insulation sheets hanging down to allow adequat
03/10/2003	03/31/2003	1002.1	Move fire extinguisher & mark location (by shop area exit door).
03/10/2003	03/31/2003	8504	Replace or repair electrical wiring on press machine.
03/10/2003	03/31/2003	1001.5.1	Service and tag extinquisher(s)
03/10/2003	03/31/2003	1002.1	Provide 2A10BC fire extinguisher missing by lunch room.