

Table 1

SAMPLE STATION	PARAMETER ABBREVIATION	PARAMETER NAME	RESULT	UNITS	Above NL	Above RL
Well 19	PFOA	Perfluoro octanoic acid	17	ng/L	Y	
	PFOS	Perfluoro octane sulfonic acid	39	ng/L	Y	
	PFOAOS	PFOS + PFOS	55	ng/L		N
Well 21	PFOA	Perfluoro octanoic acid	16	ng/L	Y	
	PFOS	Perfluoro octane sulfonic acid	40	ng/L	Y	
	PFOAOS	PFOS + PFOS	56	ng/L		N
Well 23	PFOA	Perfluoro octanoic acid	11	ng/L	N	
	PFOS	Perfluoro octane sulfonic acid	31	ng/L	Y	
	PFOAOS	PFOS + PFOS	42	ng/L		N
Well 28	PFOA	Perfluoro octanoic acid	21	ng/L	Y	
	PFOS	Perfluoro octane sulfonic acid	44	ng/L	Y	
	PFOAOS	PFOS + PFOS	66	ng/L		N
Well 29	PFOA	Perfluoro octanoic acid	11	ng/L	N	
	PFOS	Perfluoro octane sulfonic acid	28	ng/L	Y	
	PFOAOS	PFOS + PFOS	39	ng/L		N
Well 30	PFOA	Perfluoro octanoic acid	13	ng/L	N	
	PFOS	Perfluoro octane sulfonic acid	31	ng/L	Y	
	PFOAOS	PFOS + PFOS	44	ng/L		N

Notification Level (NL)

PFOA 14 ng/L

PFOS 13 ng/L

Response Level (RL)

PFOA + PFOS = 70 ng/L